



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

School District: SteilacoomHist
School Name: Saltars Point Elementary
School Code: 3827
School Address: 908 3rd St, Steilacoom Washington 98388
Number of Samples Collected: 64
Date Collected: 01/24/2020

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31292	other	other		<1	02/13/2020	Bottle Number 09563, 6:56 AM
31293	FirstDraw	Tap	Nurse's Office	1	02/13/2020	
31294	FirstDraw	Bubbler	Between Workroom and staffroom	<1	02/13/2020	Left
31295	FirstDraw	BottleFiller	Between Workroom and Staffroom	<1	02/13/2020	
31296	FirstDraw	Bubbler	Between Staff Room and Workroom	<1	02/13/2020	Right
31297	FirstDraw	Tap	Staff Room	<1	02/13/2020	Used this morning
31298	FirstDraw	Tap	Kitchen	<1	03/03/2020	Single compartment sink
31299	FirstDraw	Tap	2 compartment sink	<1	03/03/2020	Left, Used this morning
31300	FirstDraw	Tap	2-compartment sink	2	03/03/2020	Right, Used this morning
31301	FirstDraw	Bubbler	Across from Kitchen in Hallway	<1	02/13/2020	
31302	FirstDraw	BottleFiller	Across from Kitchen in Hallway	<1	02/13/2020	
31303	FirstDraw	Bubbler	Music Room	<1	02/13/2020	Erratic Flow, difficult to capture full flow
31304	FirstDraw	Tap	Music Room	1	02/13/2020	
31305	FirstDraw	Bubbler	Room 22	1	02/13/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31306	FirstDraw	Tap	Room 22	<1	02/13/2020	Warmer water, was used this morning by staff member
31307	FirstDraw	Bubbler	Wing 3 Hallway Fountain	2	02/13/2020	Left
31308	FirstDraw	Bubbler	Wing 3 Hallway Fountain	1	02/13/2020	Right
31309	FirstDraw	Bubbler	Room 14	<1	02/13/2020	
31310	FirstDraw	Tap	Room 14	1	02/13/2020	
31311	FirstDraw	Bubbler	Room 16	1	02/13/2020	
31312	FirstDraw	Tap	Room 16	1	02/13/2020	
31313	FirstDraw	Bubbler	Room 18	<1	02/13/2020	
31314	FirstDraw	Tap	Room 18	1	02/13/2020	
31315	FirstDraw	Bubbler	Room 17	<1	02/13/2020	
31316	FirstDraw	Tap	Room 17	1	02/13/2020	
31317	FirstDraw	Bubbler	Room 15	2	02/13/2020	
31318	FirstDraw	Tap	Room 15	1	02/13/2020	
31319	FirstDraw	Bubbler	Room 13	<1	02/13/2020	
31320	FirstDraw	Tap	Room 13	<1	02/13/2020	
31321	FirstDraw	Bubbler	OT/PR	5	02/13/2020	
31322	FirstDraw	Tap	OT/PT	3	02/13/2020	
31323	FirstDraw	Bubbler	Art/Technolc Room	6	02/13/2020	
31327	FirstDraw	Bubbler	Resource Room	1	02/13/2020	
31328	FirstDraw	Tap	Resource Room	1	02/13/2020	
31329	FirstDraw	Bubbler	Room 8	<1	02/13/2020	
31330	FirstDraw	Tap	Room 8	2	02/13/2020	
31331	FirstDraw	Bubbler	Room 10	<1	02/13/2020	Mineral deposits on bubbler
31332	FirstDraw	Tap	Room 10	1	02/13/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31333	FirstDraw	Bubbler	Room 12	8	02/14/2020	
31334	FirstDraw	Tap	Room 12	2	02/14/2020	
31335	FirstDraw	Bubbler	Room 11	<1	02/14/2020	
31336	FirstDraw	Tap	Room 11	1	02/14/2020	
31337	FirstDraw	Bubbler	Room 9	1	02/14/2020	Mineral deposits on bubbler
31338	FirstDraw	Tap	Room 9	<1	02/14/2020	Erratic and hard to capture full flow
31339	FirstDraw	Bubbler	Room 7	<1	02/14/2020	
31340	FirstDraw	Tap	Room 7	1	02/14/2020	
31341	FirstDraw	Bubbler	Room 2	1	02/14/2020	
31342	FirstDraw	Tap	Room 2	1	02/14/2020	
31343	FirstDraw	Bubbler	Room 4	1	02/14/2020	
31344	FirstDraw	Tap	Room 4	1	02/14/2020	
31345	FirstDraw	Bubbler	Room 6	<1	02/14/2020	
31346	FirstDraw	Tap	Room 6	1	02/14/2020	
31347	FirstDraw	Tap	Kitchen next to Room 6	18	02/14/2020	
31348	FirstDraw	Bubbler	Room 5	2	02/14/2020	
31349	FirstDraw	Tap	Room 5	2	02/14/2020	
31350	FirstDraw	Bubbler	Room 3	1	02/14/2020	Mineral deposits on tap
31351	FirstDraw	Tap	Room 3	1	02/14/2020	
31352	FirstDraw	Bubbler	Room 1	<1	02/14/2020	
31353	FirstDraw	Tap	Room 1	2	02/14/2020	
31354	FirstDraw	Bubbler	Modular Building Fountains	<1	02/14/2020	Left
31355	FirstDraw	Bubbler	Modular Building Fountains	<1	02/14/2020	Right
31356	FirstDraw	Tap	Room M-1	2	02/14/2020	Used this morning

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31357	FirstDraw	Tap	Room M-2	1	02/14/2020	
31358	FirstDraw	Tap	Library Workroom	4	02/14/2020	