



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: Please Note: The school district is following recommended measures to reduce children's overall exposure to lead.

School District: FederalWay

School Name: Lake Dolloff Elementary

School Code: 3738

School Address: 4200 South 308th St, Auburn Washington 98001

Number of Samples Collected: 62

Date Collected: 04/04/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
22234	other	other		<1	04/16/2019	02553, 7:02 AM
22235	FirstDraw	Tap	Staff Workroom	4	04/16/2019	
22236	FirstDraw	Tap	Health Room	1	04/16/2019	Used this morning
22237	FirstDraw	Bubbler	Hallway Fountain near Main Office	3	04/16/2019	
22238	FirstDraw	Tap	Staff Lounge	<1	04/16/2019	Used this morning
22239	FirstDraw	Bubbler	Room 18	1	04/16/2019	Leaks a little at base
22240	FirstDraw	Tap	Room 18	1	04/16/2019	
22241	FirstDraw	Bubbler	Room 19	1	04/16/2019	
22242	FirstDraw	Tap	Room 19	4	04/16/2019	
22243	FirstDraw	Bubbler	Room 20	<1	04/16/2019	
22244	FirstDraw	Tap	Room 20	1	04/16/2019	
22245	FirstDraw	Bubbler	Room 21	<1	04/16/2019	Some mineral deposits on mouth of bubbler
22246	FirstDraw	Tap	Room 21	<1	04/16/2019	
22247	FirstDraw	Bubbler	Room 22	2	04/16/2019	
22248	FirstDraw	Tap	Room 22	2	04/16/2019	Tap Drips
22249	FirstDraw	Bubbler	Room 23	1	04/16/2019	
22250	FirstDraw	Tap	Room 23	11	04/16/2019	
22251	FirstDraw	Bubbler	Room 24	4	04/16/2019	
22252	FirstDraw	Tap	Room 24	6	04/16/2019	Tap Drips
22253	FirstDraw	Bubbler	Room 25	2	04/16/2019	
22254	FirstDraw	Tap	Room 25	4	04/16/2019	
22255	FirstDraw	Bubbler	Room 1	4	04/16/2019	
22256	FirstDraw	Tap	Room 1	2	04/16/2019	
22257	FirstDraw	Bubbler	Room 2	<1	04/16/2019	Some mineral deposits on bubbler

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
22258	FirstDraw	Tap	Room 2	16	04/16/2019	
22259	FirstDraw	Bubbler	Music Room	<1	04/16/2019	
22260	FirstDraw	Tap	Music Room	1	04/16/2019	Tap Drips
22261	FirstDraw	Bubbler	Room 3	2	04/16/2019	
22262	FirstDraw	Tap	Room 3	6	04/16/2019	Water in sink, used this morning
22263	FirstDraw	Bubbler	Room 4	<1	04/16/2019	
22264	FirstDraw	Tap	Room 4	4	04/16/2019	
22265	FirstDraw	Bubbler	Room 6	4	04/16/2019	
22266	FirstDraw	Tap	Room 6	10	04/16/2019	
22267	FirstDraw	Bubbler	Room 7	2	04/16/2019	Used this morning
22268	FirstDraw	Tap	Room 7	1	04/16/2019	Used this morning
22269	FirstDraw	Bubbler	Room 8	1	04/16/2019	
22270	FirstDraw	Tap	Room 8	2	04/16/2019	
22271	FirstDraw	Bubbler	Room 9	1	04/16/2019	
22272	FirstDraw	Tap	Room 9	2	04/17/2019	
22273	FirstDraw	Bubbler	Room 10	<1	04/17/2019	
22274	FirstDraw	Tap	Room 10	1	04/17/2019	Tap Drips
22275	FirstDraw	Bubbler	Room 11	3	04/17/2019	Sink on Left
22276	FirstDraw	Tap	Room 11	1	04/17/2019	Sink on Left
22277	FirstDraw	Bubbler	Room 12	2	04/17/2019	Sink on Right
22278	FirstDraw	Tap	Room 12	<1	04/17/2019	Sink on Right
22279	FirstDraw	Bubbler	Room 13	6	04/17/2019	
22280	FirstDraw	Tap	Room 13	7	04/17/2019	
22281	FirstDraw	Bubbler	Room 14	2	04/17/2019	
22282	FirstDraw	Tap	Room 14	6	04/17/2019	
22283	FirstDraw	Bubbler	Room 15	3	04/17/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
22284	FirstDraw	Tap	Room 15	1	04/17/2019	
22285	FirstDraw	Bubbler	Room 16	<1	04/17/2019	
22286	FirstDraw	Tap	Room 16	1	04/17/2019	
22287	FirstDraw	Bubbler	Room 17	4	04/17/2019	
22288	FirstDraw	Tap	Room 17	2	04/17/2019	
22289	FirstDraw	Bubbler	Near Bathrooms and Conference Room 4	1	04/17/2019	Hallway Fountain
22290	FirstDraw	Tap	Cafeteria, West Side	3	04/17/2019	Far Left Sink
22291	FirstDraw	Tap	Cafeteria, West Side	<1	04/17/2019	2nd Sink from Left
22292	FirstDraw	Tap	Cafeteria, East Side	1	04/17/2019	2nd Sink From Right
22293	FirstDraw	Tap	Cafeteria, East Side	1	04/17/2019	Far Right Sink
22294	FirstDraw	Bubbler	Gym	<1	04/17/2019	Used this morning
22295	FirstDraw	Bubbler	Near Bathrooms and Room 23	<1	04/17/2019	Hallway Fountain