



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Aberdeen School District**

**School Name: Miller Junior High School**

**School Code: 2305**

**Address: 100 E Lindstrom Aberdeen WA 98520**

**Number of Samples Collected: 5/8/2018**

**Date Collected: 14**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	8581	First Draw	Blank	Blank	<1	05/26/2018	Blank
Sample 2	8582	First Draw	Tap	Kitchen	<1	05/26/2018	Double sink, same side of kitchen as office. May have been used
Sample 3	8583	First Draw	Bubbler	Outside Gym	1	05/26/2018	
Sample 4	8584	First Draw	Bubbler	Across from Rm. 123	<1	05/26/2018	
Sample 5	8585	First Draw	Bottle Filler	Across from Rm. 123	<1	05/26/2018	
Sample 6	8586	First Draw	Tap	Rm. 131	1	05/26/2018	Island Sink
Sample 7	8587	First Draw	Tap	Rm. 131	2	05/26/2018	Wall Sink, Leftmost
Sample 8	8588	First Draw	Tap	Rm. 131	7	05/26/2018	Wall Sink, Middle
Sample 9	8589	First Draw	Tap	Rm. 131	2	05/26/2018	Wall Sink, Rightmost
Sample 10	8590	First Draw	Bubbler	Next to Rm. 134	<1	05/26/2018	
Sample 11	8591	First Draw	Tap	Nurse	<1	05/26/2018	
Sample 12	8592	First Draw	Tap	Office Staff Room	<1	05/26/2018	
Sample 13	8593	First Draw	Bubbler	Across from Rm. 102	<1	05/26/2018	
Sample 14	8594	First Draw	Bubbler	Next to Rm. 121	12	05/26/2018	
Sample 15	8595	First Draw	Bubbler	Near Boy's Locker Room	<1	05/26/2018	