



Lead Sample Collection Information

School District Name: Nooksack Valley School District

School Name: Sumas Elementary School

School Code: 2489

Address: 1024 Lawson Street Sumas, WA 98295

Number of Samples Collected: 34

Date Collected: 2/16/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	1016	First Draw	Sink Tap	Room 12, Preschool Room	2	2/27/2018	
Sample 2	1017	First Draw	Left Tap	Kitchen 2 big sinks	9	02/27/2018	
Sample 3	1018	First Draw	Right Tap	Kitchen 2 big sinks	2	02/27/2018	
Sample 4	1015	First Draw	Hose Sprayer	Kitchen 2 big sinks	<1	02/27/2018	
Sample 5	1019	First Draw	Sink Tap	Room 201	3	02/27/2018	
Sample 6	1020	First Draw	Bubbler	Room 201	1	02/26/2018	Red gasket around button
Sample 7	1021	First Draw	Hallway Fountain	Across from Room 202	4	02/26/2018	
Sample 8	1022	First Draw	Sink Tap	Room 202	2	02/26/2018	
Sample 9	1023	First Draw	Bubbler	Room 202	<1	02/26/2018	
Sample 10	1025	First Draw	Sink Tap	Room 203	2	02/26/2018	
Sample 11	1024	First Draw	Bubbler	Room 203	2	02/26/2018	
Sample 12	1026	First Draw	Sink Tap	Room 204	16	02/26/2018	Aerator Type: BUBBLESTREAM
Sample 13	1027	First Draw	Bubbler	Room 204	2	02/26/2018	Type: HAWS, leaks a little
Sample 14	1028	First Draw	Sink Tap	Room 205	181	02/27/2018	Faucet turned off
Sample 15	1029	First Draw	Bubbler	Room 205	<1	02/26/2018	Leaks a little

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 16	1030	First Draw	Sink Tap	Room 206	<1	02/26/2018	
Sample 17	1031	First Draw	Sink Tap	Room 207	<1	02/26/2018	
Sample 18	1032	First Draw	Bubbler	Room 207	2	02/26/2018	Type: Central
Sample 19	1033	First Draw	Sink Tap	Room 106	11	02/26/2018	
Sample 20	1034	First Draw	Bubbler	Room 106	<1	02/26/2018	
Sample 21	1035	First Draw	Sink Tap	Room 105	1	02/26/2018	
Sample 22	1036	First Draw	Bubbler	Room 105	1	02/26/2018	
Sample 23	1037	First Draw	Sink Tap	Room 104	<1	02/26/2018	Aerator on tap
Sample 24	1038	First Draw	Bubbler	Room 104	<1	02/26/2018	
Sample 25	1039	First Draw	Sink Tap	Room 103	17	02/26/2018	Picture Taken
Sample 26	1040	First Draw	Bubbler	Room 103	1	02/26/2018	
Sample 27	1041	First Draw	Left Sink Tap	Room 101	6	02/26/2018	
Sample 28	1042	First Draw	Right Sink Tap	Room 101, next to microwave	5	02/26/2018	
Sample 29	1043	First Draw	Sink Tap	Health Room	3	02/26/2018	Aerator Type: SOFT-FLO
Sample 30	1044	First Draw	Sink Tap	Cafeteria	5	02/26/2018	weird flow

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 31	1045	First Draw	Sink Tap	Room 301	1	02/26/2018	
Sample 32	1046	First Draw	Drinking Fountain	Across from Room 207 & 106, south hallway	<1	02/26/2018	
Sample 33	1047	First Draw	Sink Tap	Speech Therapy Room	9	02/26/2018	No aerator
Sample 34	969	First Draw	Drinking Fountain	West hall drinking fountain, first hallway off main entrance	6	02/27/2018	