



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water. As soon as the school received the results, they replaced all fixtures that had detectable lead above 10ppb with certified lead free fixtures.

School District: Richland

School Name: White Bluffs Elementary

School Code: 5092

School Address: 1250 Kensington Way, Richland Washington 99352

Number of Samples Collected: 85

Date Collected: 01/07/2020

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29916	FirstDraw	other	Kitchen	<1	01/13/2020	Blank
29917	FirstDraw	Tap	Kitchen	<1	01/13/2020	
29918	FirstDraw	other	Kitchen	<1	01/13/2020	
29919	FirstDraw	Bubbler	Gymnasium	<1	01/13/2020	
29920	FirstDraw	Bubbler	Rm 129	<1	01/13/2020	
29921	FirstDraw	Tap	Rm 129	1	01/13/2020	
29922	FirstDraw	Bubbler	Rm 130	<1	01/13/2020	
29923	FirstDraw	Tap	Rm 130	2	01/13/2020	
29924	FirstDraw	Bubbler	Rm 123	<1	01/13/2020	
			music room			
29925	FirstDraw	Tap	Rm 123	4	01/13/2020	
			music room			
29926	FirstDraw	Bubbler	Rm 131	<1	01/13/2020	Cups
29927	FirstDraw	Tap	Rm 131	1	01/13/2020	
29928	FirstDraw	Bubbler	Rm 122	5	01/13/2020	
29929	FirstDraw	Tap	Rm 122	2	01/13/2020	
29930	FirstDraw	Tap	Rm 133	6	01/13/2020	
			staff			
29931	FirstDraw	Tap	Rm 132	<1	01/13/2020	
			staff			
29932	FirstDraw	Tap	Rm 121	<1	01/13/2020	Left Sink
			Art			
29933	FirstDraw	Tap	Rm 121 art	1	01/13/2020	Right sink
29934	FirstDraw	Bubbler	Main Office	<1	01/13/2020	
			hallway			
			Drinking			
			Fountain			
29935	FirstDraw	BottleFiller	Main office	<1	01/13/2020	
			hallway			
29936	FirstDraw	Bubbler	Rm 14	<1	01/13/2020	
29937	FirstDraw	Tap	Rm 14	4	01/13/2020	
29938	FirstDraw	Tap	Rm 19	1	01/13/2020	
			Nursing			
			Health			
			Room			
29939	FirstDraw	Bubbler	Rm 120	<1	01/13/2020	
29940	FirstDraw	Tap	Rm 120	1	01/13/2020	
29941	FirstDraw	Bubbler	Rm 119	<1	01/13/2020	
29942	FirstDraw	Tap	Rm 119	1	01/13/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29943	FirstDraw	Bubbler	Rm 111	<1	01/13/2020	
29944	FirstDraw	Tap	Rm 111	5	01/13/2020	
29945	FirstDraw	Bubbler	Rm 118	<1	01/13/2020	
29946	FirstDraw	Tap	Rm 118	1	01/13/2020	
29947	FirstDraw	Bubbler	Rm 112	1	01/13/2020	
29948	FirstDraw	Tap	Rm 112	1	01/13/2020	
29949	FirstDraw	Bubbler	Rm 117	<1	01/13/2020	
29950	FirstDraw	Tap	Rm 117	1	01/13/2020	
29951	FirstDraw	Bubbler	Rm 113	<1	01/13/2020	
29952	FirstDraw	Tap	Rm 113	1	01/13/2020	
29953	FirstDraw	Bubbler	Rm 116	<1	01/13/2020	
29954	FirstDraw	Tap	Rm 116	1	01/13/2020	
29955	FirstDraw	Bubbler	Rm 114	<1	01/13/2020	
29956	FirstDraw	Tap	Rm 114	2	01/13/2020	
29957	FirstDraw	Bubbler	Rm 115	<1	01/13/2020	
29958	FirstDraw	Tap	Rm 115	1	01/13/2020	Water bottles
29959	FirstDraw	Bubbler	Main hallway 2nd floor	<1	01/13/2020	
29960	FirstDraw	BottleFiller	Main hallway 2nd floor	<1	01/13/2020	
29961	FirstDraw	Bubbler	Rm 222	<1	01/13/2020	
29962	FirstDraw	Tap	Rm 222	2	01/13/2020	
29963	FirstDraw	Bubbler	Rm 223	<1	01/13/2020	
29964	FirstDraw	Tap	Rm 223	1	01/13/2020	
29965	FirstDraw	Tap	Rm 229	<1	01/13/2020	Note accidentally took sample 29966 before 29965
29966	FirstDraw	Bubbler	Rm 229	<1	01/13/2020	
29967	FirstDraw	Bubbler	Rm 224	<1	01/13/2020	
29968	FirstDraw	Tap	Rm 224	1	01/13/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29969	FirstDraw	Bubbler	Rm 228	<1	01/13/2020	
29970	Flush	Tap	Rm 228	1	01/13/2020	
29971	FirstDraw	Bubbler	Rm 225	<1	01/13/2020	
29972	FirstDraw	Tap	Rm 225	1	01/13/2020	
29973	FirstDraw	Bubbler	Rm 227	<1	01/13/2020	
29974	FirstDraw	Tap	Rm 227	1	01/13/2020	
29975	FirstDraw	Bubbler	Rm 226	<1	01/13/2020	
29976	FirstDraw	Tap	Rm 226	<1	01/13/2020	
29977	FirstDraw	Bubbler	Rm 221	<1	01/14/2020	
29978	FirstDraw	Tap	Rm 221	<1	01/14/2020	
29979	FirstDraw	Bubbler	Rm 220	<1	01/14/2020	
29980	FirstDraw	Tap	Rm 220	2	01/14/2020	
29981	FirstDraw	Bubbler	Rm 211	<1	01/14/2020	
29982	FirstDraw	Tap	Rm 211	1	01/14/2020	
29983	FirstDraw	Bubbler	Rm 219	<1	01/14/2020	
29984	FirstDraw	Tap	Rm 219	1	01/14/2020	
29985	FirstDraw	Bubbler	Rm 212	<1	01/14/2020	
29986	FirstDraw	Tap	Rm 212	2	01/14/2020	
29987	FirstDraw	Bubbler	Rm 213	<1	01/14/2020	
29988	FirstDraw	Tap	Rm 213	<1	01/14/2020	
29989	FirstDraw	Bubbler	Rm 218	<1	01/14/2020	
29990	FirstDraw	Tap	Rm 218	1	01/14/2020	
29991	FirstDraw	Bubbler	Rm 214	<1	01/14/2020	
29992	FirstDraw	Tap	Rm 214	<1	01/14/2020	
29993	FirstDraw	Bubbler	Rm 217	<1	01/14/2020	
29994	FirstDraw	Tap	Rm 217	1	01/14/2020	
29995	FirstDraw	Bubbler	Rm 215	<1	01/14/2020	
29996	FirstDraw	Tap	Rm 215	3	01/14/2020	
29997	FirstDraw	Bubbler	Rm 216	<1	01/14/2020	
29998	FirstDraw	Tap	Rm 216	2	01/14/2020	
29999	FirstDraw	Bubbler	Rm 230 library	<1	01/14/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30000	FirstDraw	Tap	Rm 230 library	1	01/14/2020	