



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Aberdeen School District

School Name: Stevens Elementary

School Code: 2791

Address: 301 S Farragut St Aberdeen WA 98520

Number of Samples Collected: 57

Date Collected: 4/13/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	5930	First Draw	Blank	Blank	<1	4/20/2018	Blank
Sample 2	5931	First Draw	Tap	Kitchen	1	4/20/2018	Had been used, Tap next to oven
Sample 3	5932	First Draw	Tap	Kitchen	2	4/20/2018	Had been used, Tap under window
Sample 4	5933	First Draw	Tap	Nurse	<1	4/20/2018	Restroom, only source of water available
Sample 5	5934	First Draw	Bubbler	Across From Office	<1	4/20/2018	
Sample 6	5935	First Draw	Tap	Rm. 1	<1	4/20/2018	
Sample 7	5936	First Draw	Bubbler	Rm. 2	<1	4/20/2018	
Sample 8	5937	First Draw	Tap	Rm. 2	<1	4/20/2018	
Sample 9	5938	First Draw	Bubbler	Rm. 3	<1	4/20/2018	
Sample 10	5939	First Draw	Tap	Rm. 3	<1	4/20/2018	
Sample 11	5940	First Draw	Bubbler	Rm. 4	<1	4/20/2018	
Sample 12	5989	First Draw	Tap	Rm. 4	<1	4/20/2018	
Sample 13	5990	First Draw	Bubbler	Rm. 5	<1	4/20/2018	
Sample 14	5991	First Draw	Tap	Rm. 5	<1	4/20/2018	
Sample 15	5992	First Draw	Bubbler	Rm. 6	<1	4/20/2018	
Sample 16	5993	First Draw	Tap	Rm. 6	<1	4/20/2018	
Sample 17	5994	First Draw	Bubbler	Rm. 7	32	4/20/2018	
Sample 18	5995	First Draw	Tap	Rm. 7	34	4/20/2018	
Sample 19	5996	First Draw	Bubbler	Rm. 8	11	4/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 20	5997	First Draw	Tap	Rm. 8	33	4/20/2018	
Sample 21	5998	First Draw	Bubbler	Rm. 9	93	4/20/2018	
Sample 22	5999	First Draw	Tap	Rm. 9	47	4/20/2018	
Sample 23	6000	First Draw	Bubbler	Rm. 10	19	4/20/2018	
Sample 24	6001	First Draw	Tap	Rm. 10	7	4/20/2018	
Sample 25	6002	First Draw	Tap	Rm. 14	26	4/20/2018	
Sample 26	6003	First Draw	Bubbler	Rm. 15	<1	4/20/2018	
Sample 27	6004	First Draw	Tap	Rm. 15	<1	4/20/2018	
Sample 28	6005	First Draw	Bubbler	Rm. 16	<1	4/20/2018	
Sample 29	6006	First Draw	Tap	Rm. 16	<1	4/20/2018	
Sample 30	6007	First Draw	Bubbler	Across From Gym	<1	4/20/2018	
Sample 31	6008	First Draw	Bottle Filler	Across From Gym	<1	4/20/2018	
Sample 32	5941	First Draw	Bubbler	Rm. 17	<1	4/20/2018	
Sample 33	5942	First Draw	Tap	Rm. 17	<1	4/20/2018	
Sample 34	5943	First Draw	Bubbler	Rm. 18	1	4/20/2018	
Sample 35	5944	First Draw	Tap	Rm. 18	<1	4/20/2018	
Sample 36	5945	First Draw	Bubbler	Rm. 19	<1	4/20/2018	
Sample 37	5946	First Draw	Tap	Rm. 19	<1	4/20/2018	
Sample 38	5947	First Draw	Bubbler	Rm. 20	<1	4/20/2018	
Sample 39	5948	First Draw	Tap	Rm. 10	<1	4/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 40	5949	First Draw	Bubbler	Rm. 21	<1	4/20/2018	
Sample 41	5950	First Draw	Tap	Rm. 21	1	4/20/2018	
Sample 42	5951	First Draw	Bubbler	Next to Custodial Office	2	4/20/2018	
Sample 43	5952	First Draw	Bubbler	Rm. 22	10	4/20/2018	
Sample 44	5953	First Draw	Tap	Rm. 22	8	4/20/2018	
Sample 45	5954	First Draw	Bubbler	Rm. 23	8	4/20/2018	
Sample 46	5955	First Draw	Tap	Rm. 23	15	4/20/2018	
Sample 47	5956	First Draw	Bubbler	Rm. 24	8	4/20/2018	
Sample 48	5957	First Draw	Tap	Rm. 24	6	4/20/2018	
Sample 49	5958	First Draw	Bubbler	Rm. 25	9	4/20/2018	
Sample 50	5959	First Draw	Tap	Rm. 25	9	4/20/2018	
Sample 51	5960	First Draw	Bubbler	Rm. 26	3	4/20/2018	
Sample 52	5961	First Draw	Tap	Rm. 26	15	4/20/2018	
Sample 53	5962	First Draw	Bubbler	Rm. 27	1	4/20/2018	
Sample 54	5963	First Draw	Tap	Rm. 27	6	4/20/2018	
Sample 55	5964	First Draw	Bubbler	Rm. 28	7	4/20/2018	
Sample 56	5965	First Draw	Tap	Rm. 28	12	4/20/2018	
Sample 57	5966	First Draw	Bubbler	Rm. 29	12	4/20/2018	
Sample 58	5967	First Draw	Tap	Rm. 29	29	4/20/2018	