



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: Mukilteo

School Name: Mukilteo Elementary

School Code: 4164

School Address: 2600 Mukilteo Speedway, Mukilteo Washington 98275

Number of Samples Collected: 59

Date Collected: 05/17/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23813	other	other		<1	06/07/2019	06729, 5:55 AM
23814	FirstDraw	WaterCooler	Health Clinic	<1	06/07/2019	
23815	FirstDraw	Tap	Kitchen	8	06/07/2019	Food Prep Area
23816	FirstDraw	Bubbler	Music Room	TB	NA	
23817	FirstDraw	Tap	Music Room	71	06/07/2019	No Aerator, Erratic Flow
23818	FirstDraw	Bubbler	Down the Hall from Cafeteria	10	06/07/2019	
23869	FirstDraw	Bubbler	Room 92	3	06/07/2019	
23870	FirstDraw	Tap	Room 92	1	06/07/2019	
23871	FirstDraw	Bubbler	Room 93	10	06/07/2019	Mineral deposits on bubbler mouth
23872	FirstDraw	Tap	Room 93	10	06/07/2019	
23873	FirstDraw	Bubbler	Room 94	1	06/07/2019	
23874	FirstDraw	Tap	Room 94	4	06/07/2019	
23875	FirstDraw	Bubbler	Room 95	7	06/07/2019	
23876	FirstDraw	Tap	Room 95	25	06/07/2019	
23877	FirstDraw	Bubbler	Room 96	4	06/07/2019	
23878	FirstDraw	Tap	Room 96	6	06/07/2019	Some paint on aerator
23879	FirstDraw	Bubbler	Room 97	3	06/07/2019	
23880	FirstDraw	Tap	Room 97	10	06/07/2019	
23881	FirstDraw	Bubbler	Room 113	8	06/07/2019	Mineral deposits on bubbler mouth
23882	FirstDraw	Tap	Room 113	9	06/07/2019	
23883	FirstDraw	Bubbler	Room 112	5	06/07/2019	
23884	FirstDraw	Tap	Room 112	12	06/07/2019	
23885	FirstDraw	Bubbler	Room 111	5	06/07/2019	Erratic flow
23886	FirstDraw	Tap	Room 111	3	06/07/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23887	FirstDraw	Bubbler	Room 110	4	06/07/2019	Some mineral deposits on bubbler mouth
23888	FirstDraw	Tap	Room 110	11	06/07/2019	
23889	FirstDraw	Bubbler	Room 109	3	06/07/2019	
23890	FirstDraw	Tap	Room 109	6	06/07/2019	
23891	FirstDraw	Bubbler	Room 108	4	06/07/2019	
23892	FirstDraw	Tap	Room 108	9	06/07/2019	
23893	FirstDraw	Bubbler	Library Office	16	06/07/2019	Erratic flow
23894	FirstDraw	Tap	Library Office	11	06/07/2019	
23895	FirstDraw	Bubbler	Room 68	9	06/07/2019	
23896	FirstDraw	Tap	Room 68	4	06/07/2019	Tap Dripping
23897	FirstDraw	Tap	Room 68	11	06/07/2019	Left Sink
23898	FirstDraw	Tap	Room 67	18	06/07/2019	Left Sink
23899	FirstDraw	Bubbler	Room 67	6	06/07/2019	Right Sink
23900	FirstDraw	Tap	Room 67	8	06/07/2019	Right Sink
23901	FirstDraw	Bubbler	Room 52	5	06/07/2019	
23902	FirstDraw	Tap	Room 52	4	06/07/2019	Paint on aerator
23903	FirstDraw	Bubbler	Room 53	2	06/07/2019	
23904	FirstDraw	Tap	Room 53	3	06/07/2019	
23905	FirstDraw	Bubbler	Room 54	1	06/07/2019	
23906	FirstDraw	Tap	Room 54	4	06/07/2019	
23907	FirstDraw	Bubbler	Room 55	3	06/07/2019	Erratic flow
23908	FirstDraw	Tap	Room 55	7	06/07/2019	
23909	FirstDraw	Bubbler	Room 56	2	06/07/2019	Erratic flow
23910	FirstDraw	Tap	Room 56	3	06/07/2019	
23911	FirstDraw	Bubbler	Room 57	4	06/07/2019	
23912	FirstDraw	Tap	Room 57	1	06/07/2019	
23913	FirstDraw	WaterCooler	Portable 10	<1	06/07/2019	
23914	FirstDraw	WaterCooler	Portable 9	<1	06/07/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23915	FirstDraw	WaterCooler	Portable 6	<1	06/07/2019	
23916	FirstDraw	WaterCooler	Portable 3	<1	06/07/2019	
23917	FirstDraw	WaterCooler	Portable 4	<1	06/07/2019	
23918	FirstDraw	WaterCooler	Portable 1	<1	06/07/2019	New bottle used for sample
23919	FirstDraw	WaterCooler	Portable 1	<1	06/07/2019	
23920	FirstDraw	WaterCooler	Portable 8	<1	06/07/2019	
23921	FirstDraw	WaterCooler	Portable 7	<1	06/07/2019	