



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Kent

**School Name:** Jenkins Creek Elementary

**School Code:** 2113

**School Address:** 26915 186th Ave SE, Covington Washington 98042

**Number of Samples Collected:** 53

**Date Collected:** 03/06/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
13821	FirstDraw	Bubbler	Room 211	<1	03/21/2019	
13822	FirstDraw	Tap	Room 211	18	03/21/2019	
13823	FirstDraw	Tap	Room 202	12	04/16/2019	
13824	FirstDraw	Bubbler	Room 202	1	03/21/2019	
13825	FirstDraw	Tap	Room 203	9	03/21/2019	
13826	FirstDraw	Bubbler	Room 203	<1	03/21/2019	
13827	FirstDraw	Bubbler	Room 210	<1	03/21/2019	
13828	FirstDraw	Tap	Room 210	14	03/21/2019	
13829	FirstDraw	Tap	Room 209	11	03/21/2019	
13830	FirstDraw	Bubbler	Room 209	1	03/21/2019	
13831	FirstDraw	Bubbler	Room 204	<1	03/21/2019	
13832	FirstDraw	Tap	Room 204	4	03/21/2019	
13833	FirstDraw	Tap	Outside room 204	62	04/16/2019	
13834	FirstDraw	Bubbler	Room 207	1	03/21/2019	
13835	FirstDraw	Tap	Room 207	3	03/21/2019	
13836	FirstDraw	Bubbler	Room 206	1	03/21/2019	
13837	FirstDraw	Tap	Room 206	2	03/21/2019	
13838	FirstDraw	Bubbler	Room 256	<1	03/21/2019	
13839	FirstDraw	Tap	Room 256	2	03/21/2019	
13840	FirstDraw	Tap	Outside room 256	11	03/21/2019	
13841	FirstDraw	Tap	Room 251	5	03/21/2019	
13842	FirstDraw	Bubbler	Room 251	1	03/21/2019	
13843	FirstDraw	Tap	Room 252	7	03/21/2019	
13844	FirstDraw	Bubbler	Room 252	<1	03/21/2019	
13845	FirstDraw	Tap	Room 254	<1	03/21/2019	
13846	FirstDraw	Bubbler	Room 254	<1	03/21/2019	
13847	FirstDraw	Tap	Room 253	1	03/21/2019	
13848	FirstDraw	Bubbler	Room 253	1	03/22/2019	
13849	FirstDraw	Tap	Room 302	72	04/16/2019	
13850	FirstDraw	Tap	Room 301	1	03/22/2019	Bubbler no pressure
13851	FirstDraw	Bubbler	Room 302	7	03/22/2019	
13852	FirstDraw	Bubbler	Room 308	<1	03/22/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
13853	FirstDraw	Tap	Room 308	11	03/22/2019	
13854	FirstDraw	Bubbler	Room 307	2	03/22/2019	
13855	FirstDraw	Tap	Room 307	15	03/22/2019	
13856	FirstDraw	Tap	Outside room 308	56	04/16/2019	
13857	FirstDraw	Tap	Room 306	6	03/22/2019	
13858	FirstDraw	Tap	Outside room 306	12	03/22/2019	
13859	FirstDraw	Tap	Room 303	1	03/22/2019	
13860	FirstDraw	Bubbler	Room 303	<1	03/22/2019	
13861	FirstDraw	Tap	Room 304	14	03/22/2019	
13862	FirstDraw	Bubbler	Room 304	<1	03/22/2019	
13863	FirstDraw	Bubbler	Room 219	1	03/22/2019	
13864	FirstDraw	Tap	Room 219	5	03/22/2019	
13865	FirstDraw	Bubbler	Room 218	<1	03/22/2019	
13866	FirstDraw	Tap	Room 218	1	03/22/2019	
13867	FirstDraw	Bubbler	Room 212	1	03/22/2019	
13868	FirstDraw	Tap	Kitchen	8	03/22/2019	Left
13869	FirstDraw	Tap	Kitchen	7	03/22/2019	Right
13870	FirstDraw	Bubbler	Gym	<1	03/22/2019	
13871	FirstDraw	Tap	Nurses station	1	03/22/2019	
13872	FirstDraw	Tap	Nurses station	5	03/22/2019	
13873	FirstDraw	other	Blank	<1	03/22/2019	
NA	FirstDraw			TB	NA	