



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school has participated in follow up testing and recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Highline

**School Name:** Madrona Elementary

**School Code:** 3278

**School Address:** 20301 32nd Ave South, SeaTac Washington 98198

**Number of Samples Collected:** 68

**Date Collected:** 01/25/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
19943	other	other		<1	02/01/2019	6:29 AM, 02633
19944	FirstDraw	Tap	Kitchenette in Cafeteria	<1	02/01/2019	
19945	FirstDraw	other	Kitchen	1	02/01/2019	Food Prep Area
19946	FirstDraw	Bubbler	Outside Cafeteria	<1	02/01/2019	Left Side
19947	FirstDraw	BottleFiller	Outside Cafeteria	<1	04/16/2019	Left Side
19948	FirstDraw	Bubbler	Outside Gym	<1	04/16/2019	Right Side
19949	FirstDraw	Tap	Room 116A	1	02/01/2019	Community Room
19950	FirstDraw	Tap	Room 117A	<1	02/01/2019	
19951	FirstDraw	Tap	Staff Lounge	<1	02/01/2019	
19952	FirstDraw	Tap	Staff Workroom	3	02/01/2019	
19953	FirstDraw	Tap	Nurses Office	<1	02/01/2019	Left Side Sink
19954	FirstDraw	Tap	Nurses Office	<1	02/01/2019	Right Side Sink
19955	FirstDraw	Tap	Library Workroom	1	02/01/2019	
19956	FirstDraw	Tap	Room 134	1	02/01/2019	
19957	FirstDraw	Tap	Room 132	3	02/01/2019	
19958	FirstDraw	Bubbler	Room 146	11	02/01/2019	
19959	FirstDraw	Tap	Room 146	<1	02/01/2019	
19960	FirstDraw	Bubbler	Room 158	2	02/01/2019	
19961	FirstDraw	Tap	Room 158	1	02/01/2019	
19962	FirstDraw	Bubbler	Room 156	<1	02/01/2019	
19963	FirstDraw	Tap	Room 156	<1	02/01/2019	
19964	FirstDraw	Bubbler	Room 155	1	02/01/2019	
19965	FirstDraw	Tap	Room 155	<1	02/01/2019	
19966	FirstDraw	Bubbler	Room 153	<1	02/01/2019	
19967	FirstDraw	Tap	Room 153	<1	02/01/2019	
19968	FirstDraw	Bubbler	Room 168	<1	02/01/2019	
19969	FirstDraw	Tap	Room 168	1	02/01/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
19970	FirstDraw	Bubbler	Room 166	1	02/01/2019	
19971	FirstDraw	Tap	Room 166	1	02/01/2019	
19972	FirstDraw	Bubbler	Room 165	<1	02/01/2019	
19973	FirstDraw	Tap	Room 165	1	02/01/2019	
19974	FirstDraw	Bubbler	Room 163	<1	02/01/2019	
19975	FirstDraw	Tap	Room 163	1	02/01/2019	
19976	FirstDraw	Bubbler	Room 177A	<1	02/01/2019	
19977	FirstDraw	Tap	Room 177A	1	02/01/2019	
19978	FirstDraw	Bubbler	Room 175	1	02/01/2019	
19979	FirstDraw	Tap	Room 175	<1	02/01/2019	
19980	FirstDraw	Bubbler	Room 173A	<1	02/01/2019	
19981	FirstDraw	Tap	Room 173A	2	02/01/2019	
19982	FirstDraw	Bubbler	Room 171A	2	02/01/2019	
19983	FirstDraw	Tap	Room 171A	1	02/01/2019	
19984	FirstDraw	Bubbler	Room 228	<1	02/01/2019	
19985	FirstDraw	Tap	Room 228	1	02/01/2019	
19986	FirstDraw	Bubbler	Room 226	<1	02/01/2019	
19987	FirstDraw	Tap	Room 226	1	02/01/2019	
19988	FirstDraw	Bubbler	Room 225A	1	02/01/2019	
19989	FirstDraw	Tap	Room 225A	3	02/01/2019	
19990	FirstDraw	Bubbler	Room 223	<1	02/01/2019	
19991	FirstDraw	Tap	Room 223	2	02/01/2019	
19992	FirstDraw	Tap	Room 203	3	02/01/2019	No Aerator
19993	FirstDraw	Bubbler	Room 238	<1	02/01/2019	
19994	FirstDraw	Tap	Room 238	1	02/01/2019	
19995	FirstDraw	Bubbler	Room 236	<1	02/01/2019	
19996	FirstDraw	Tap	Room 236	<1	02/01/2019	
19997	FirstDraw	Bubbler	Room 235A	<1	02/01/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
19998	FirstDraw	Tap	Room 235A	<1	02/01/2019	
19999	FirstDraw	Bubbler	Room 233	<1	02/01/2019	
20000	FirstDraw	Tap	Room 233	1	02/01/2019	
20001	FirstDraw	Bubbler	2nd Floor Hallway	<1	02/01/2019	Left Side
20002	FirstDraw	Bubbler	2nd Floor Hallway	<1	02/01/2019	Right Side
20003	FirstDraw	Bubbler	Room 248	<1	02/01/2019	
20004	FirstDraw	Tap	Room 248	<1	02/01/2019	
20005	FirstDraw	Bubbler	Room 246	1	02/02/2019	
20006	FirstDraw	Tap	Room 246	2	02/02/2019	
20007	FirstDraw	Bubbler	Room 245	<1	02/02/2019	
20008	FirstDraw	Tap	Room 245	<1	02/02/2019	Dripping, no Aerator
20009	FirstDraw	Bubbler	Room 243	<1	02/02/2019	
20010	FirstDraw	Tap	Room 243	<1	02/02/2019	