



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

School District: BainbridgeIsland

School Name: Ordway Elementary

School Code: 4062

School Address: 8555 Madison Ave NE, Bainbridge Island Washington 98110

Number of Samples Collected: 57

Date Collected: 11/07/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28627	other	other	Blank	<1	12/02/2019	
28628	FirstDraw	Tap	Room 105	17	12/02/2019	
28629	FirstDraw	Bubbler	Room 105	4	12/02/2019	
28630	FirstDraw	Tap	Room 106	8	12/02/2019	
28631	FirstDraw	Bubbler	Room 106	4	12/02/2019	
28632	FirstDraw	Tap	Room 104	13	12/02/2019	
28633	FirstDraw	Bubbler	Room 104	5	12/02/2019	Leaking from bottom of the fixture
28634	FirstDraw	Tap	Room 203	6	12/02/2019	
28635	FirstDraw	Bubbler	Room 103	3	12/02/2019	
28636	FirstDraw	Tap	Room 107	15	12/02/2019	
28637	FirstDraw	Bubbler	Room 107	3	12/02/2019	
28638	FirstDraw	Tap	Room 108	7	12/02/2019	
28639	FirstDraw	Bubbler	Room 108	2	12/02/2019	
28640	FirstDraw	Tap	Rm 100 right side fixtures	28	12/02/2019	
28641	FirstDraw	Bubbler	Room 100 right side	14	12/02/2019	
28642	FirstDraw	Tap	Room 100 left side	13	12/02/2019	
28643	FirstDraw	Bubbler	Room 100 left	9	12/02/2019	
28644	FirstDraw	Bubbler	Main hall south entrance	<1	12/02/2019	
28645	FirstDraw	Tap	Kitchen scullery sink	2	12/02/2019	
28646	FirstDraw	Bubbler	Gym bubbler	1	12/02/2019	
28647	FirstDraw	Tap	Staff rooms	2	12/02/2019	
28648	FirstDraw	Bubbler	Main central entrance	<1	12/02/2019	
28649	FirstDraw	Tap	Room 300	17	12/02/2019	
28650	FirstDraw	Bubbler	Room 300	3	12/02/2019	
28651	FirstDraw	Tap	Room 315	8	12/02/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28652	FirstDraw	Bubbler	Room 315	5	12/02/2019	
28653	FirstDraw	Tap	Room 301	18	12/02/2019	
28654	FirstDraw	Bubbler	Room 301	4	12/02/2019	
28655	FirstDraw	Tap	Room 302	10	12/02/2019	
28656	FirstDraw	Bubbler	Room 302	12	12/02/2019	
28657	FirstDraw	Tap	Room 314	12	12/02/2019	
28658	FirstDraw	Bubbler	Room 314	4	12/02/2019	
28659	FirstDraw	Tap	Room 313	8	12/02/2019	
28660	FirstDraw	Bubbler	Room 313	6	12/02/2019	
28661	FirstDraw	Bubbler	Main entrance south bubbler adjacent to boys RR	<1	12/02/2019	
28662	FirstDraw	Tap	Room 305	11	12/02/2019	
28663	FirstDraw	Bubbler	Room 305	7	12/02/2019	
28664	FirstDraw	Tap	Room 306	7	12/02/2019	
28665	FirstDraw	Bubbler	Room 306	5	12/02/2019	
28666	FirstDraw	Tap	Room 309	7	12/02/2019	
28667	FirstDraw	Bubbler	Room 309	4	12/02/2019	
28668	FirstDraw	Tap	Room 310	8	12/02/2019	
28669	FirstDraw	Bubbler	Room 310	4	12/02/2019	
28670	FirstDraw	Tap	Room 307	12	12/02/2019	
28671	FirstDraw	Bubbler	Room 307	7	12/02/2019	
28672	FirstDraw	Tap	Room 308	7	12/02/2019	
28673	FirstDraw	Bubbler	Room 308	3	12/02/2019	
28674	FirstDraw	Tap	Portable room D	7	12/02/2019	
28675	FirstDraw	Bubbler	Portable room D	7	12/02/2019	
28676	FirstDraw	Tap	Portable room E	<1	12/02/2019	
28677	FirstDraw	Bubbler	Portable room E	2	12/02/2019	
28678	FirstDraw	Tap	Portable room F	1	12/02/2019	Water aerated/foaming

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28679	FirstDraw	Bubbler	Portable room F	8	12/02/2019	Slightly less aerated than previous... soda-like
28680	FirstDraw	Tap	Kindergarten portable rm 48	1	12/02/2019	
28681	FirstDraw	Bubbler	Kindergarten portable rm 408	2	12/02/2019	
28682	FirstDraw	Tap	Kindergarten portable room 407	1	12/02/2019	
28683	FirstDraw	Bubbler	Kindergarten portable rm 407	1	12/02/2019	
NA	FirstDraw			TB	NA	