



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Wenatchee School District

School Name: Columbia Elementary School

School Code: 2301

Address: 600 Alaska St Wenatchee WA 98801

County: Chelan

Number of Samples Collected: 60

Date Collected: 4/11/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	3094	Tap	First Draw	Kitchen	4	7/18/2018	right side by dishwasher
Sample 2	3095	Tap	First Draw	Kitchen	12	7/18/2018	left side
Sample 3	3096	Tap	First Draw	Kitchen	1	7/18/2018	by phone
Sample 4	3097	Bubbler	First Draw	Cafeteria	<1	7/18/2018	
Sample 5	3098	Bubbler	First Draw	in gym	<1	7/18/2018	
Sample 6	3099	Tap	First Draw	Music	<1	7/18/2018	
Sample 7	3100	Bubbler	First Draw	Music	1	7/18/2018	
Sample 8	3101	Tap	First Draw	Room 105	2	7/18/2018	
Sample 9	3102	Bubbler	First Draw	outside Room 102	1	7/18/2018	
Sample 10	3103	Bubbler	First Draw	Room 103	<1	7/18/2018	
Sample 11	3104	Bubbler	First Draw	Room 103	2	7/18/2018	
Sample 12	3105	Tap	First Draw	Room 104	3	7/18/2018	
Sample 13	3106	Tap	First Draw	Room 104	1	7/18/2018	
Sample 14	3107	Bubbler	First Draw	Room 105	3	7/18/2018	
Sample 15	3108	Tap	First Draw	Room 106	2	7/18/2018	
Sample 16	3109	Tap	First Draw	Room 106	4	7/18/2018	
Sample 17	3110	Bubbler	First Draw	outside Room 107	1	7/18/2018	
Sample 18	3111	Bubbler	First Draw	Room 107	<1	7/18/2018	
Sample 19	3112	Bubbler	First Draw	Room 107	<1	7/18/2018	
Sample 20	3113	Tap	First Draw	Room 107	3	7/18/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	3114	Bubbler	First Draw	Room 108	2	7/18/2018	
Sample 22	3115	Tap	First Draw	Room 108	1	7/18/2018	
Sample 23	3116	Bubbler	First Draw	room 110	1	7/18/2018	
Sample 24	3117	Tap	First Draw	room 110	1	7/18/2018	
Sample 25	3118	Bubbler	First Draw	Room 109	1	7/18/2018	
Sample 26	3119	Tap	First Draw	Room 109	3	7/18/2018	
Sample 27	3120	Bubbler	First Draw	Room 201	1	7/18/2018	
Sample 28	3121	Tap	First Draw	Room 201	3	7/18/2018	
Sample 29	3122	Bubbler	First Draw	Room 202	<1	7/18/2018	
Sample 30	3123	Tap	First Draw	Room 202	2	7/18/2018	
Sample 31	3124	Bubbler	First Draw	outside room 203	1	7/18/2018	
Sample 32	3125	Tap	First Draw	Room 203	3	8/20/2018	
Sample 33	3126	Bubbler	First Draw	Room 203	1	7/18/2018	
Sample 34	3127	Tap	First Draw	Room 203	2	7/18/2018	
Sample 35	3128	Bubbler	First Draw	Room 204	1	7/18/2018	slight discoloration
Sample 36	3129	Tap	First Draw	Room 204	2	7/18/2018	
Sample 37	3130	Tap	First Draw	Room 205	<1	7/18/2018	
Sample 38	3131	Tap	First Draw	Room 205	12	7/18/2018	
Sample 39	3132	Tap	First Draw	Room 501	9	7/18/2018	Bathroom
Sample 40	3133	Tap	First Draw	Room 502	1	7/18/2018	Bathroom

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 41	3134	Bubbler	First Draw	Room 504	4	7/18/2018	Bathroom
Sample 42	3135	Tap	First Draw	Room 503	<1	7/18/2018	Bathroom
Sample 43	3136	Bubbler	First Draw	304	4	7/18/2018	
Sample 44	3137	Tap	First Draw	304	3	7/18/2018	
Sample 45	3138	Bubbler	First Draw	305	<1	7/18/2018	
Sample 46	3139	Tap	First Draw	305	2	7/18/2018	
Sample 47	3140	Bubbler	First Draw	306	1	7/18/2018	
Sample 48	3141	Tap	First Draw	306	2	7/18/2018	
Sample 49	3142	Bubbler	First Draw	307	1	7/18/2018	
Sample 50	3143	Tap	First Draw	307	2	7/18/2018	
Sample 51	3144	Bubbler	First Draw	308	1	7/18/2018	
Sample 52	3145	Tap	First Draw	308	2	7/18/2018	
Sample 53	3146	Bubbler	First Draw	309	2	7/18/2018	
Sample 54	3147	Tap	First Draw	309	2	7/18/2018	
Sample 55	3148	Bubbler	First Draw	310	2	7/18/2018	
Sample 56	3149	Tap	First Draw	310	2	7/18/2018	
Sample 57	3150	Bubbler	First Draw	312	1	7/18/2018	
Sample 58	3151	Tap	First Draw	312	2	7/18/2018	
Sample 59	3152	Bubbler	First Draw	311	1	7/18/2018	
Sample 60	3153	Tap	First Draw	311	1	7/18/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 61	3154	BLANK	BLANK	blank	1	7/18/2018	