



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

School District: Evaline

School Name: Evaline Elementary School

School Code: 2355

School Address: 111 Schoolhouse Rd, Winlock Washington 98596

Number of Samples Collected: 7

Date Collected: 11/13/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28757	other	other	Blank	1	11/23/2019	
28758	FirstDraw	Tap	Classroom 1	4	11/23/2019	
28759	FirstDraw	Bubbler	Classroom 1	2	11/23/2019	Bubbler used for brief period before first draw
28760	FirstDraw	Tap	Kitchen/kitchen food prep sink	23	11/23/2019	
28761	FirstDraw	Bubbler	Cafeteria bubbler: high	<1	11/23/2019	
28762	FirstDraw	Bubbler	Cafeteria bubbler: low sink	<1	11/23/2019	
28763	FirstDraw	Tap	Classroom 2	4	11/23/2019	Low pressure