



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Lynden School District

School Name: Fischer Elementary

School Code: 3417

Address: 501 14th St Lynden WA 98264

Number of Samples Collected: 74

Date Collected:4/11/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	6368	First Draw	Tap	Kitchen	<1	05/24/2018	Food prep sink
Sample 2	6414	First Draw	Bubbler	Room 287	5	05/24/2018	
Sample 3	6415	First Draw	Tap	Room 287	<1	05/24/2018	Leaks
Sample 4	6416	First Draw	Bubbler	Room 285	11	05/24/2018	
Sample 5	6417	First Draw	Tap	Room 285	18	05/24/2018	
Sample 6	6418	First Draw	Bubbler	Room 286	2	05/24/2018	
Sample 7	6419	First Draw	Tap	Room 286	12	05/24/2018	
Sample 8	6420	First Draw	Bubbler	Room 284	1	05/24/2018	
Sample 9	6421	First Draw	Tap	Room 284	1	05/24/2018	Leaks
Sample 10	6422	First Draw	Bubbler	Room 283	1	05/24/2018	
Sample 11	6423	First Draw	Tap	Room 283	1	05/24/2018	
Sample 12	6424	First Draw	Bubbler	Room 282	1	05/24/2018	
Sample 13	6425	First Draw	Tap	Room 282	1	05/24/2018	
Sample 14	6426	First Draw	Bubbler	Room 281	1	05/24/2018	
Sample 15	6427	First Draw	Tap	Room 281	1	05/24/2018	
Sample 16	6428	First Draw	Bubbler	Room 277	7	05/24/2018	
Sample 17	6429	First Draw	Tap	Room 277	1	05/24/2018	
Sample 18	6430	First Draw	Bubbler	Room 275	1	05/24/2018	
Sample 19	6431	First Draw	Tap	Room 275	2	05/24/2018	
Sample 20	6432	First Draw	Bubbler	Room 273	1	05/24/2018	
Sample 21	6433	First Draw	Tap	Room 273	1	05/24/2018	
Sample 22	6434	First Draw	Bubbler	Room 271	<1	05/24/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 23	6435	First Draw	Tap	Room 271	1	05/24/2018	
Sample 24	6436	First Draw	Bubbler	Room 264	1	05/24/2018	
Sample 25	6437	First Draw	Tap	Room 264	1	05/24/2018	
Sample 26	6438	First Draw	Bubbler	Room 263	<1	05/24/2018	
Sample 27	6439	First Draw	Tap	Room 263	1	05/24/2018	
Sample 28	6440	First Draw	Bubbler	Room 262	1	05/24/2018	
Sample 29	6441	First Draw	Tap	Room 262	1	05/24/2018	
Sample 30	6442	First Draw	Bubbler	Room 261	4	05/24/2018	
Sample 31	6467	First Draw	Tap	Room 261	10	05/24/2018	
Sample 32	6468	First Draw	Tap	Room 256	1	05/24/2018	
Sample 33	6469	First Draw	Drinking Fountain, left	Across from Elevator, 2nd floor	<1	05/24/2018	
Sample 34	6470	First Draw	Drinking Fountain, right	Across from Elevator, 2nd floor	<1	05/24/2018	
Sample 35	6471	First Draw	Bottle Filler	Across from Elevator, 2nd floor	<1	05/24/2018	
Sample 36	6472	First Draw	Tap	Room 118	1	05/24/2018	Nurse's Office
Sample 37	6473	First Draw	Tap	Main Office Workroom	1	05/24/2018	
Sample 38	6474	First Draw	Drinking Fountain, left	Outside of 140 and gym	<1	05/24/2018	
Sample 39	6475	First Draw	Drinking Fountain, right	Outside of 140 and gym	<1	05/24/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 40	6476	First Draw	Bottle Filler	Outside of 140 and gym	<1	05/24/2018	
Sample 41	6477	First Draw	Bubbler	Room 144	<1	05/24/2018	
Sample 42	6478	First Draw	Tap	Room 144	<1	05/24/2018	Tap Dripping
Sample 43	6479	First Draw	Drinking Fountain, left	Across from Elevator, 1st floor	<1	05/24/2018	
Sample 44	6480	First Draw	Drinking Fountain, right	Across from Elevator, 1st floor	<1	05/24/2018	
Sample 45	6481	First Draw	Bottle Filler	Across from Elevator, 1st floor	<1	05/24/2018	
Sample 46	6482	First Draw	Tap	Room 156	1	05/24/2018	
Sample 47	6483	First Draw	Bubbler	Room 161	1	05/24/2018	
Sample 48	6484	First Draw	Tap	Room 161	1	05/24/2018	
Sample 49	6485	First Draw	Bubbler	Room 162	<1	05/24/2018	
Sample 50	6486	First Draw	Tap	Room 162	<1	05/24/2018	
Sample 51	6487	First Draw	Bubbler	Room 163	1	05/24/2018	
Sample 52	6488	First Draw	Tap	Room 163	1	05/24/2018	Dripping
Sample 53	6489	First Draw	Bubbler	Room 164	<1	05/24/2018	
Sample 54	6490	First Draw	Tap	Room 164	1	05/24/2018	Used by staff
Sample 55	6491	First Draw	Bubbler	Room 171	1	05/24/2018	
Sample 56	6492	First Draw	Tap	Room 171	1	05/24/2018	
Sample 57	6495	First Draw	Bubbler	Room 173	<1	05/24/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 58	6496	First Draw	Tap	Room 173	1	05/25/2018	
Sample 59	6497	First Draw	Bubbler	Room 175	1	05/25/2018	
Sample 60	6498	First Draw	Tap	Room 175	1	05/25/2018	Tap Dripping
Sample 61	7230	First Draw	Bubbler	Room 177	1	05/25/2018	
Sample 62	7231	First Draw	Tap	Room 177	<1	05/25/2018	Tap Dripping
Sample 63	7232	First Draw	Bubbler	Room 181	1	05/25/2018	
Sample 64	7233	First Draw	Tap	Room 181	2	05/25/2018	
Sample 65	7234	First Draw	Bubbler	Room 182	<1	05/25/2018	
Sample 66	6493	First Draw	Tap	Room 182	<1	05/24/2018	
Sample 67	6494	First Draw	Bubbler	Room 183	<1	05/24/2018	
Sample 68	6499	First Draw	Tap	Room 183	2	05/25/2018	
Sample 69	6500	First Draw	Bubbler	Room 184	1	05/25/2018	
Sample 70	7221	First Draw	Tap	Room 184	3	05/25/2018	
Sample 71	7222	First Draw	Bubbler	Room 185	5	05/25/2018	
Sample 72	7223	First Draw	Tap	Room 185	<1	05/25/2018	
Sample 73	7224	First Draw	Bubbler	Room 186	1	05/25/2018	
Sample 74	7225	First Draw	Tap	Room 186	<1	05/25/2018	
Sample 75	7226		Blank		<1	05/25/2018	05815