



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The district has disabled all sinks and drinking fountains with detectable lead above 10ppb. The district plans on replacing all fixtures once testing is completed with the exception of Central Elementary where fixtures have already been replaced and is awaiting re-sampling. The district is currently cleaning and inspecting aerators and has implemented a flushing plan.

School District: SedroWoolley

School Name: State Street High School

School Code: 1537

School Address: 800 E State St, Sedro Woolley Washington 98284

Number of Samples Collected: 7

Date Collected: 11/20/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
27985	other	other		<1	11/26/2019	5:25 AM, 04202
27986	FirstDraw	Tap	Kitchen	<1	11/26/2019	Food Prep Area
27987	FirstDraw	other	Kitchen	1	11/26/2019	Food Prep Area
27988	FirstDraw	Tap	Tim McHughâ s Room	11	11/26/2019	
27989	FirstDraw	Tap	Portable, Room on Left	<1	11/26/2019	
27990	FirstDraw	Tap	Kitchen Between Rooms	<1	11/26/2019	
27991	FirstDraw	Tap	Portable, Room on Right	<1	11/26/2019	Water Filter on Tap