



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**Please note: The school has since notified the Department of Health that all fixtures higher than 1ppb were replaced and will be participating in further testing.**

**School District Name: Lakewood School District**

**School Name: English Crossing Elementary**

**School Code: 4477**

**Address: 16728 16th Dr NW Arlington WA 98223**

**County: Snohomish**

**Number of Samples Collected: 51**

**Date Collected: 5/10/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	9145	First Draw	Tap	Kitchen, Middle	18	09/05/2018	Food prep sink
Sample 2	9146	First Draw	Drinking Fountain	Gym	1	09/05/2018	
Sample 3	9147	First Draw	Tap	Music Room	5	09/05/2018	
Sample 4	9148	First Draw	Tap	Health Room	11	09/05/2018	
Sample 5	9149	First Draw	Drinking Fountain	Across from Main Office	2	09/05/2018	
Sample 6	9150	First Draw	Bubbler	Room 129	<1	09/05/2018	
Sample 7	9151	First Draw	Tap	Room 129	2	09/05/2018	
Sample 8	9152	First Draw	Bubbler	200 Pod	<1	09/05/2018	Stains on bubbler
Sample 9	9153	First Draw	Tap	200 Pod	<1	09/05/2018	Calcification on tap
Sample 10	9154	First Draw	Bubbler	Room 203	<1	09/05/2018	
Sample 11	9155	First Draw	Tap	Room 203	<1	09/05/2018	
Sample 12	9156	First Draw	Bubbler	Room 204	<1	09/05/2018	
Sample 13	9157	First Draw	Tap	Room 204	<1	09/05/2018	
Sample 14	9158	First Draw	Bubbler	Room 205	<1	09/05/2018	
Sample 15	9159	First Draw	Tap	Room 205	<1	09/05/2018	
Sample 16	9160	First Draw	Bubbler	Room 206	<1	09/05/2018	
Sample 17	9161	First Draw	Tap	Room 206	<1	09/05/2018	
Sample 18	9162	First Draw	Bubbler	Room 207	<1	09/05/2018	
Sample 19	9215	First Draw	Tap	Room 207	<1	09/05/2018	No aerator
Sample 20	9216	First Draw	Bubbler	Room 208	<1	09/05/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	9217	First Draw	Tap	Room 208	<1	09/05/2018	some calcification
Sample 22	9218	First Draw	Bubbler	Room 138	1	09/05/2018	room used for storage
Sample 23	9219	First Draw	Tap	Room 138	1	09/05/2018	calcification
Sample 24	9220	First Draw	Bubbler	300 Pod	<1	09/05/2018	
Sample 25	9221	First Draw	Tap	300 Pod	1	09/05/2018	
Sample 26	9222	First Draw	Bubbler	Room 303	<1	09/05/2018	
Sample 27	9223	First Draw	Tap	Room 303	<1	09/05/2018	calcification
Sample 28	9224	First Draw	Bubbler	Room 304	<1	09/05/2018	
Sample 29	9225	First Draw	Tap	Room 304	<1	09/05/2018	No aerator
Sample 30	9226	First Draw	Bubbler	Room 305	<1	09/05/2018	
Sample 31	9227	First Draw	Tap	Room 305	<1	09/05/2018	
Sample 32	9228	First Draw	Bubbler	Room 306	<1	09/05/2018	
Sample 33	9229	First Draw	Tap	Room 306	2	09/05/2018	
Sample 34	9230	First Draw	Bubbler	Room 307	<1	09/05/2018	
Sample 35	9231	First Draw	Tap	Room 307	46	09/05/2018	
Sample 36	9232	First Draw	Bubbler	Room 308	<1	09/05/2018	
Sample 37	9233	First Draw	Tap	Room 308	1	09/05/2018	
Sample 38	9234	First Draw	Bubbler	400 Pod	<1	09/05/2018	
Sample 39	9235	First Draw	Tap	400 Pod	1	09/05/2018	
Sample 40	9236	First Draw	Bubbler	Room 403	<1	09/05/2018	
Sample 41	9237	First Draw	Tap	Room 403	<1	09/05/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 42	9238	First Draw	Bubbler	Room 404	<1	09/05/2018	
Sample 43	9239	First Draw	Tap	Room 404	3	09/05/2018	Some calcification
Sample 44	9240	First Draw	Bubbler	Room 405	<1	09/05/2018	
Sample 45	9241	First Draw	Tap	Room 405	<1	09/05/2018	
Sample 46	9242	First Draw	Bubbler	Room 406	<1	09/05/2018	
Sample 47	9243	First Draw	Tap	Room 406	6	09/05/2018	
Sample 48	9244	First Draw	Bubbler	Room 407	<1	09/05/2018	
Sample 49	9245	First Draw	Tap	Room 407	<1	09/05/2018	
Sample 50	9246	First Draw	Bubbler	Room 408	<1	09/05/2018	
Sample 51	9247	First Draw	Tap	Room 408	<1	09/05/2018	
Sample 52	9248	First Draw	Blank		<1	09/05/2018	03387