



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Elma**  
**School Name: Elma Middle School**  
**School Code: 4245**  
**Address: 805 W Main St, Elma, WA 98541**  
**Number of Samples Collected: 26**  
**Date Collected: 06/01/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	9897	First Draw		Blank	<1	06/21/2018	
2.	9898	First Draw	Bubbler	Outside main office	2	06/21/2018	Left
3.	9899	First Draw	Bubbler	Outside main office	1	06/21/2018	
4.	9900	First Draw	Tap	Attendance office	8	06/21/2018	
5.	9901	First Draw	Tap	Nurse	3	06/21/2018	
6.	9902	First Draw	Tap	Library	11	06/21/2018	
7.	9903	First Draw	Tap	Rm 117	5	06/21/2018	
8.	9904	First Draw	Tap	Rm 125	2	06/22/2018	
9.	9905	First Draw	Bubbler	By stairs to lunchroom	2	06/22/2018	Left
10.	9906	First Draw	Bubbler	By stairs to lunchroom	2	06/22/2018	
11.	9907	First Draw	Bubbler	East hall	3	06/22/2018	Left
12.	9908	First Draw	Bubbler	East hall	<1	06/22/2018	Right, active leak
13.	9909	First Draw	Tap	Kitchen	2	06/22/2018	Single tap sink
14.	9910	First Draw	Tap	Kitchen	5	06/22/2018	Left tap in triple sink
15.	9911	First Draw	Tap	Kitchen	1	06/22/2018	Right tap in triple sink
16.	9912	First Draw	Tap	E Lock	2	06/22/2018	
17.	9913	First Draw	Bubbler	Across from Rm 105/Comp lab	3	06/22/2018	Left

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
18.	9914	First Draw	Bubbler	Across from Rm 105/comp room	2	06/22/2018	Right
19.	9915	First Draw	Bubbler	Room 105	5	06/22/2018	
20.	9916	First Draw	Tap	Rm 105	9	06/22/2018	
21.	9917	First Draw	Bubbler	Rm 101	8	06/22/2018	
22.	9918	First Draw	Tap	Rm 101	9	06/22/2018	
23.	9919	First Draw	Tap	Rm 104	53	06/22/2018	Possible irregular use
24.	9920	First Draw	Bubbler	Tan gym	7	06/22/2018	
25.	9921	First Draw	Bubbler	Wood floor gym	8	06/22/2018	Left
26.	9922	First Draw	Bubbler	Wood floor gym	3	06/22/2018	Right