



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school district is participating in follow up testing and is following all recommendation to reduce children's overall exposure to lead.

**School District:** Kent

**School Name:** Neely O Brien Elementary

**School Code:** 4356

**School Address:** 6300 South 236th St, Kent Washington 98032

**Number of Samples Collected:** 62

**Date Collected:** 03/05/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
20231	other	other		<1	03/13/2019	3:41 AM, 02626
20232	FirstDraw	Bubbler	Cafeteria	<1	03/13/2019	
20233	FirstDraw	Bubbler	Music Room	1	03/13/2019	
20234	FirstDraw	Tap	Music Room	4	03/13/2019	
20235	FirstDraw	Bubbler	Gym	<1	03/13/2019	
20236	FirstDraw	Bubbler	Across from Gym near Main Office	1	03/13/2019	
20237	FirstDraw	Tap	Nurses Office	<1	03/13/2019	
20238	FirstDraw	Tap	Backroom of Main Office	3	03/13/2019	
20239	FirstDraw	Tap	Staff Lounge	1	03/13/2019	Used this morning
20240	FirstDraw	Bubbler	Room 202	5	03/13/2019	
20241	FirstDraw	Tap	Room 202	2	03/13/2019	
20242	FirstDraw	Bubbler	Room 204	5	03/13/2019	
20243	FirstDraw	Tap	Room 204	1	03/13/2019	
20244	FirstDraw	Bubbler	Room 206	5	03/13/2019	
20245	FirstDraw	Tap	Room 206	3	03/13/2019	
20246	FirstDraw	Bubbler	Room 208	2	03/13/2019	
20247	FirstDraw	Tap	Room 208	1	03/13/2019	
20248	FirstDraw	Bubbler	Room 210	4	03/13/2019	
20249	FirstDraw	Tap	Room 210	3	03/13/2019	
20250	FirstDraw	Bubbler	Room 209	4	03/13/2019	
20251	FirstDraw	Tap	Room 209	2	03/13/2019	
20252	FirstDraw	Bubbler	Room 207	3	03/13/2019	
20253	FirstDraw	Tap	Room 207	2	03/13/2019	
20254	FirstDraw	Bubbler	Room 205	5	03/13/2019	
20255	FirstDraw	Tap	Room 205	2	03/14/2019	
20256	FirstDraw	Bubbler	Room 203	4	03/14/2019	
20257	FirstDraw	Tap	Room 203	2	03/14/2019	
20258	FirstDraw	Bubbler	Room 201	<1	03/14/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
20259	FirstDraw	Tap	Room 201	2	03/14/2019	
20260	FirstDraw	Tap	200 Wing	16	03/14/2019	
20501	FirstDraw	Tap	Staff Lounge	4	03/14/2019	No Aerator
20502	FirstDraw	Tap	Room 153	13	03/14/2019	Speech Pathologist Room
20503	FirstDraw	Bubbler	Room 402	3	03/14/2019	
20504	FirstDraw	Tap	Room 402	1	03/14/2019	
20505	FirstDraw	Bubbler	Room 404	3	03/14/2019	
20506	FirstDraw	Tap	Room 404	<1	03/14/2019	Tap Dripping
20507	FirstDraw	Bubbler	Room 406	1	03/14/2019	
20508	FirstDraw	Tap	Room 406	2	03/14/2019	
20509	FirstDraw	Bubbler	Room 405	2	03/14/2019	
20510	FirstDraw	Tap	Room 405	1	03/14/2019	No Aerator
20511	FirstDraw	Bubbler	Room 403	3	03/14/2019	
20512	FirstDraw	Tap	Room 403	54	03/14/2019	Tap Dripping
20513	FirstDraw	Bubbler	Room 401	1	03/14/2019	
20514	FirstDraw	Tap	Room 401	1	03/14/2019	
20515	FirstDraw	Tap	400 Wing	7	03/14/2019	
20516	FirstDraw	Bubbler	Room 152	4	03/14/2019	
20517	FirstDraw	Tap	Room 152	2	03/14/2019	
20518	FirstDraw	Tap	300 Wing	3	03/14/2019	Tap Dripping
20519	FirstDraw	Bubbler	Room 304	2	03/14/2019	
20520	FirstDraw	Tap	Room 304	1	03/14/2019	Tap used by teacher
20521	FirstDraw	Bubbler	Room 306	2	03/14/2019	
20522	FirstDraw	Tap	Room 306	1	03/14/2019	
20523	FirstDraw	Bubbler	Room 308	2	03/14/2019	
20524	FirstDraw	Tap	Room 308	1	03/14/2019	
20525	FirstDraw	Bubbler	Room 307	3	03/14/2019	
20526	FirstDraw	Tap	Room 307	1	03/14/2019	

*(continued)*

<b>Program ID</b>	<b>Sample Type</b>	<b>Description</b>	<b>Location</b>	<b>Lead Results (ppb)</b>	<b>Analysis Date</b>	<b>Comments</b>
20527	FirstDraw	Bubbler	Room 305	2	03/14/2019	Used this morning
20528	FirstDraw	Tap	Room 305	1	03/14/2019	Used this morning
20529	FirstDraw	Bubbler	Room 303	4	03/14/2019	
20530	FirstDraw	Tap	Room 303	1	03/14/2019	
20531	FirstDraw	Bubbler	Room 301	3	03/14/2019	
20532	FirstDraw	Tap	Room 301	2	03/14/2019	