



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Lakes Elementary

School Code: 3539

School District Name: North Thurston

Address: 6211 Mullen Rd SE, Lacey WA 98503

County: Thurston

Number of Samples Collected: 72

Date Collected: 10/18/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	15754	First Draw	Tap	Kitchen	16	10/30/2018	Left side of triple sink island, may have been used
2.	15755	First Draw	Tap	Kitchen	2	10/30/2018	Right side of triple sink island, may have been used
3.	15756	First Draw	Bubbler	Rm 101	<1	10/30/2018	
4.	15757	First Draw	Tap	Rm 101	8	10/30/2018	
5.	15758	First Draw	Bubbler	Rm 102	<1	10/30/2018	
6.	15759	First Draw	Tap	Rm 102	7	10/30/2018	
7.	15760	First Draw	Bubbler	Rm 103	2	10/30/2018	
8.	15761	First Draw	Tap	Rm 103	17	10/30/2018	
9.	15762	First Draw	Tap	100 Building Nurse	2	10/30/2018	
10.	15763	First Draw	Bubbler	202	<1	10/30/2018	
11.	15764	First Draw	Tap	Rm 202	7	10/30/2018	Lower left
12.	15765	First Draw	Tap	Rm 202	5	10/30/2018	Upper right
13.	15766	First Draw	Bubbler	Rm 209	<1	10/30/2018	
14.	15767	First Draw	Tap	Rm 209	10	10/30/2018	
15.	15768	First Draw	Bubbler	Rm 203	<1	10/30/2018	
16.	15769	First Draw	Tap	Rm 203	2	10/30/2018	
17.	15770	First Draw	Bubbler	Rm 204	<1	10/30/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
18.	15771	First Draw	Tap	Rm 204	6	10/30/2018	
19.	15772	First Draw	Bubbler	Rm 205	<1	10/30/2018	
20.	15773	First Draw	Tap	Rm 205	3	10/30/2018	
21.	15774	First Draw	Bubbler	Rm 206	<1	10/30/2018	
22.	15775	First Draw	Tap	Rm 206	9	10/30/2018	
23.	15776	First Draw	Bubbler	Rm 207	3	10/30/2018	
24.	15777	First Draw	Tap	Rm 207	8	10/30/2018	
25.	15778	First Draw	Bubbler	Rm 208	<1	10/30/2018	
26.	15779	First Draw	Tap	Rm 208	9	10/30/2018	
27.	15780	First Draw	Bubbler	Rm 301	<1	10/30/2018	
28.	15781	First Draw	Tap	Rm 301	8	10/30/2018	
29.	15782	First Draw	Bubbler	Rm 302	<1	10/30/2018	
30.	15783	First Draw	Tap	Rm 302	2	10/30/2018	Slow drip
31.	15784	First Draw	Bubbler	Rm 303	2	10/30/2018	
32.	15785	First Draw	Tap	Rm 303	5	10/30/2018	
33.	15786	First Draw	Bubbler	Rm 304	<1	10/30/2018	
34.	15787	First Draw	Tap	Rm 304	5	10/30/2018	
35.	15788	First Draw	Bubbler	Rm 305	1	10/30/2018	
36.	15789	First Draw	Tap	Rm 305	4	10/30/2018	
37.	15790	First Draw	Bubbler	Rm 306	<1	10/30/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
38.	15791	First Draw	Tap	Rm 306	8	10/30/2018	
39.	15792	First Draw	Tap	Rm 210	8	10/30/2018	Left most sink
40.	15793	First Draw	Bubbler	Rm 210	7	10/30/2018	
41.	15794	First Draw	Tap	Rm 210	3	10/30/2018	Right-hand sink
42.	15795	First Draw	Bubbler	Rm 401	1	10/30/2018	
43.	15796	First Draw	Tap	Rm 401	4	10/30/2018	
44.	15797	First Draw	Bubbler	Rm 402	<1	10/30/2018	
45.	15798	First Draw	Tap	Rm 402	5	10/30/2018	
46.	15799	First Draw	Bubbler	Rm 403	<1	10/30/2018	
47.	15800	First Draw	Tap	Rm 403	5	10/30/2018	
48.	15801	First Draw	Bubbler	Rm 404	4	10/30/2018	
49.	15802	First Draw	Tap	Rm 404	7	10/30/2018	
50.	15803	First Draw	Bubbler	Rm 405	<1	10/30/2018	
51.	15804	First Draw	Tap	Rm 404	6	10/30/2018	
52.	15805	First Draw	Bubbler	Rm 406	<1	10/30/2018	
53.	15806	First Draw	Tap	Rm 406	5	10/30/2018	
54.	15807	First Draw	Bubbler	Rm 407	<1	10/30/2018	
55.	15808	First Draw	Tap	Rm 407	4	10/30/2018	
56.	15809	First Draw	Bubbler	Portable 5	1	10/30/2018	
57.	15810	First Draw	Tap	Portable 5	8	10/30/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
58.	15811	First Draw	Bubbler	Portable 6	5	10/30/2018	
59.	15812	First Draw	Tap	Portable 6	2	10/30/2018	
60.	15813	First Draw	Bubbler	Portable 7	3	10/30/2018	
61.	15814	First Draw	Tap	Portable 7	3	10/30/2018	
62.	15815	First Draw	Bubbler	Portable 8	<1	10/31/2018	
63.	15816	First Draw	Tap	Portable 8	2	10/31/2018	
64.	15817	First Draw	Bubbler	Portable 10	1	10/31/2018	
65.	15818	First Draw	Tap	Portable 10	2	10/31/2018	
66.	15819	First Draw	Bubbler	Portable 9	2	10/31/2018	
67.	15820	First Draw	Tap	Portable 9	2	10/31/2018	
68.	15821	First Draw	Bubbler	Portable 11	2	10/31/2018	
69.	15822	First Draw	Tap	Portable 11	5	10/31/2018	
70.	15823	First Draw	Bubbler	Portable 12	8	10/31/2018	
71.	15824	First Draw	Tap	Portable 12	4	10/31/2018	
72.	15825		Blank		<1	10/31/2018	