



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

School District: SouthKitsap

School Name: Burley Glenwood Elementary School

School Code: 4029

School Address: 100 SW Lakeway Blvd, Port Orchard Washington 98367

Number of Samples Collected: 58

Date Collected: 01/22/2020

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
32006	FirstDraw		Blank	<1	02/04/2020	
32007	FirstDraw	PotFiller	Kitchen pot filler/spring spout	5	02/04/2020	
32008	FirstDraw	Tap	Kitchen double sink	2	02/04/2020	
32009	FirstDraw	Tap	Kitchen handwash sink	1	02/04/2020	
32010	FirstDraw	Bubbler	Gym bubbler	<1	02/04/2020	
32011	FirstDraw	Bubbler	Common area bubbler	2	02/04/2020	
32012	FirstDraw	Tap	Nurse station	9	02/04/2020	
32013	FirstDraw	Tap	Staff workroom in office	26	02/04/2020	
32014	FirstDraw	Tap	Staff lounge	<1	02/04/2020	
32015	FirstDraw	Tap	Rm 100: kindergarten	21	02/04/2020	
32016	FirstDraw	Bubbler	Rm 100: kindergarten	1	02/04/2020	
32017	FirstDraw	Tap	Rm 104: kindergarten	35	02/12/2020	
32018	FirstDraw	Tap	Rm 104: kindergarten	24	02/04/2020	
32019	FirstDraw	Bubbler	Rm 104: kindergarten	2	02/04/2020	
32020	FirstDraw	Tap	Rm 201	12	02/04/2020	
32021	FirstDraw	Bubbler	Rm 201	<1	02/04/2020	
32022	FirstDraw	Tap	Rm 202	53	02/12/2020	
32023	FirstDraw	Bubbler	Rm 202	7	02/04/2020	
32024	FirstDraw	Tap	Rm 203	27	02/04/2020	
32025	FirstDraw	Bubbler	Rm 203	7	02/04/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
32026	FirstDraw	Tap	Rm 204	41	02/04/2020	Sink drips
32027	FirstDraw	Bubbler	Rm 204	4	02/04/2020	
32028	FirstDraw	Tap	Rm 205	13	02/04/2020	
32029	FirstDraw	Bubbler	Rm 205	4	02/04/2020	
32030	FirstDraw	Tap	Rm 206	34	02/04/2020	
32031	FirstDraw	Bubbler	Rm 206	6	02/04/2020	
32032	FirstDraw	Tap	Rm 207	21	02/04/2020	
32033	FirstDraw	Bubbler	Rm 207	7	02/04/2020	
32034	FirstDraw	Tap	Rm 208	12	02/04/2020	
32035	FirstDraw	Bubbler	Rm 208	5	02/04/2020	
32036	FirstDraw	Bubbler	300 wing bubbler between restrooms	<1	02/04/2020	
32037	FirstDraw	Tap	300 wing lab area sink (kitchen present)	57	02/12/2020	
32038	FirstDraw	Tap	Rm 301	22	02/04/2020	
32039	FirstDraw	Bubbler	Rm 301	3	02/04/2020	
32040	FirstDraw	Tap	Rm 302	30	02/04/2020	
32041	FirstDraw	Bubbler	Rm 302	3	02/04/2020	
32042	FirstDraw	Tap	Rm 303	30	02/04/2020	
32043	FirstDraw	Bubbler	Rm 303	9	02/04/2020	
32044	FirstDraw	Tap	Rm 304	34	02/12/2020	
32045	FirstDraw	Bubbler	Rm 304	2	02/12/2020	
32046	FirstDraw	Tap	Rm 305	57	02/12/2020	
32047	FirstDraw	Bubbler	Rm 305	4	02/12/2020	
32048	FirstDraw	Tap	Rm 306	17	02/12/2020	
32049	FirstDraw	Bubbler	Rm 306	7	02/12/2020	
32050	FirstDraw	Tap	Rm 307	15	02/12/2020	
32051	FirstDraw	Bubbler	Rm 307	3	02/04/2020	
32052	FirstDraw	Tap	Rm 308	36	02/04/2020	
32053	FirstDraw	Bubbler	Rm 308	6	02/04/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
32054	FirstDraw	Bubbler	400 wing bubbler between bathrooms	1	02/04/2020	
32055	FirstDraw	Tap	Rm 401	92	02/04/2020	
32056	FirstDraw	Tap	Rm 402	91	02/04/2020	
32057	FirstDraw	Tap	Rm 403	27	02/04/2020	
32058	FirstDraw	Tap	Rm 404	35	02/04/2020	
32059	FirstDraw	Tap	400 wing kitchen area	4	02/04/2020	
32060	FirstDraw	Tap	Rm 405	21	02/04/2020	
32061	FirstDraw	Tap	Rm 406	402	02/05/2020	
32062	FirstDraw	Tap	Rm 407	23	02/04/2020	
32063	FirstDraw	Tap	Rm 408	20	02/04/2020	
NA	FirstDraw			TB	NA	