



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School Name:** Terminal Park Elementary

**School Code:** 2659

**School District Name:** Auburn

**Address:** 1101 D St SE, Auburn WA 98002

**County:** King

**Number of Samples Collected:** 42

**Date Collected:** 06/13/2018

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location                       | Lead Content (ppb) | Date of Analysis | Notes/Comments       |
|---------------|-----------|-------------|---------------------|--|--------------------|------------------|----------------------|
| 1.            | 10902     | First Draw  | Bubbler             | Gym                                    | <1                 | 08/10/2018       | 6:10 AM              |
| 2.            | 10903     | First Draw  | Tap                 | Kitchen Sink for Food Prep             | 3                  | 08/10/2018       |                      |
| 3.            | 10904     | First Draw  | Pot Filler          | Kitchen                                | 26                 | 08/10/2018       |                      |
| 4.            | 10905     | First Draw  | Bubble              | Left of 212 (Girls Bathroom)           | 1                  | 08/10/2018       |                      |
| 5.            | 10906     | First Draw  | Bubbler             | Across Hall from 212                   | 5                  | 08/10/2018       |                      |
| 6.            | 10907     | First Draw  | Bubbler             | Room 205                               | <1                 | 08/10/2018       | Bubbler and Tap Sink |
| 7.            | 10908     | First Draw  | Tap                 | Room 205                               | 3                  | 08/10/2018       | Bubbler and Tap Sink |
| 8.            | 10909     | First Draw  | Bubbler             | Room 205                               | 12                 | 08/10/2018       |                      |
| 9.            | 10910     | First Draw  | Bubbler             | Drinking fountain across from Room 204 | 9                  | 08/10/2018       |                      |
| 10.           | 10911     | First Draw  | Bubbler             | Right of 202 (girls bathroom)          | 1                  | 08/10/2018       |                      |
| 11.           | 10912     | First Draw  | Bubbler             | Room 203                               | 2                  | 08/10/2018       |                      |
| 12.           | 10913     | First Draw  | Tap                 | Room 203                               | 2                  | 08/10/2018       |                      |
| 13.           | 10914     | First Draw  | Bubbler             | Room 201                               | 8                  | 08/10/2018       |                      |
| 14.           | 10915     | First Draw  | Tap                 | Room 201                               | 9                  | 08/10/2018       |                      |
| 15.           | 10916     | First Draw  | Bubbler             | Room 200                               | 2                  | 08/10/2018       |                      |
| 16.           | 10917     | First Draw  | Tap , Blank         | Room 200                               | TB                 |                  | No aerator           |

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location     | Lead Content (ppb) | Date of Analysis | Notes/Comments |
|---------------|-----------|-------------|---------------------|----------------------|--------------------|------------------|----------------|
| 17.           | 10918     | First Draw  | Bubbler             | Next to 100 (Office) | 1                  | 08/10/2018       |                |
| 18.           | 10919     | First Draw  | Tap                 | Nurses Office        | 4                  | 08/10/2018       |                |
| 19.           | 10920     | First Draw  | Tap                 | Workroom             | 1                  | 08/10/2018       |                |
| 20.           | 10949     | First Draw  | Tap                 | Staff Lounge         | <1                 | 08/10/2018       |                |
| 21.           | 10950     | First Draw  | Bubbler             | Room 300             | 2                  | 08/10/2018       |                |
| 22.           | 10951     | First Draw  | Tap                 | Room 300             | 1                  | 08/10/2018       |                |
| 23.           | 10952     | First Draw  | Bubbler             | Room 301             | 1                  | 08/10/2018       |                |
| 24.           | 10953     | First Draw  | Tap                 | Room 301             | <1                 | 08/10/2018       |                |
| 25.           | 10954     | First Draw  | Bubbler             | Room 302             | 1                  | 08/10/2018       |                |
| 26.           | 10955     | First Draw  | Tap                 | Room 302             | <1                 | 08/10/2018       |                |
| 27.           | 10956     | First Draw  | Bubbler             | Room 303             | 1                  | 08/10/2018       |                |
| 28.           | 10957     | First Draw  | Tap                 | Room 303             | <1                 | 08/10/2018       | No aerator     |
| 29.           | 10958     | First Draw  | Bubbler             | Room 304             | 1                  | 08/10/2018       |                |
| 30.           | 10959     | First Draw  | Tap                 | Room 304             | 1                  | 08/10/2018       | No aerator     |
| 31.           | 10960     | First Draw  | Bubbler             | Room 305             | 2                  | 08/10/2018       |                |
| 32.           | 10961     | First Draw  | Tap                 | Room 305             | <1                 | 08/10/2018       | No aerator     |
| 33.           | 10962     | First Draw  | Bubbler             | Room 114             | 5                  | 08/10/2018       |                |
| 34.           | 10963     | First Draw  | Tap                 | Room 114             | 3                  | 08/10/2018       |                |
| 35.           | 10964     | First Draw  | Bubbler             | Room 116             | 1                  | 08/10/2018       |                |

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location   | Lead Content (ppb) | Date of Analysis | Notes/Comments    |
|---------------|-----------|-------------|---------------------|--------------------|--------------------|------------------|-------------------|
| 36.           | 10965     | First Draw  | Tap                 | Room 116           | TB                 | 08/10/2018       |                   |
| 37.           | 10966     | First Draw  | Bubbler             | Room 115           | 3                  | 08/10/2018       |                   |
| 38.           | 10967     | First Draw  | Tap                 | Room 115           | 5                  | 08/10/2018       |                   |
| 39.           | 10968     | First Draw  | Bubbler             | Next to Room 115   | 5                  | 08/10/2018       |                   |
| 40.           | 10969     | First Draw  | Tap                 | Library Workroom   | TB                 |                  | Very yellow water |
| 41.           | 10970     | First Draw  |                     | Emergency water    | TB                 |                  |                   |
| 42.           | 10971     | Blank       |                     | Near back entrance | <1                 | 08/10/2018       | 04226             |

TB= Further analysis required.