



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Belfair Elementary
School Code: 2662
School District Name: North Mason
Address: NE 22900 Hwy 3, Belfair WA 98528
County: Mason
Number of Samples Collected: 57
Date Collected: 06/19/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	11952	First Draw		Blank	<1	7/19/2018	
2.	11953	First Draw	Bubbler	Rm 26	<1	7/19/2018	
3.	11954	First Draw	Tap	Rm 26	2	7/19/2018	
4.	11955	First Draw	Bubbler	Rm 27	<1	7/19/2018	
5.	11956	First Draw	Tap	Rm 27	1	7/19/2018	
6.	11957	First Draw	Bubbler	2nd Floor next to elevator	<1	7/19/2018	
7.	11958	First Draw	Bubbler	Rm 25	<1	7/19/2018	
8.	11959	First Draw	Tap	Rm 25	5	7/19/2018	
9.	11960	First Draw	Bubbler	Rm 1	<1	7/19/2018	
10.	11961	First Draw	Tap	Rm 1	3	7/19/2018	
11.	11962	First Draw	Bubbler	Outside Rm 11	<1	7/19/2018	
12.	11963	First Draw	Bubbler	Rm 11	1	7/19/2018	
13.	11082	First Draw	Tap	Rm 11	2	7/19/2018	
14.	11965	First Draw	Bubbler	Rm 12	<1	7/19/2018	
15.	11966	First Draw	Tap	Rm 12	1	7/19/2018	
16.	11967	First Draw	Bubbler	Rm 2	<1	7/19/2018	
17.	11968	First Draw	Tap	Rm 2	1	7/19/2018	
18.	11969	First Draw	Bubbler	Rm 3	<1	7/19/2018	
19.	11970	First Draw	Tap	Rm 3	2	7/19/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
20.	11971	First Draw	Bubbler	Rm 4	<1	7/19/2018	
21.	11972	First Draw	Tap	Rm 4	2	7/19/2018	
22.	11973	First Draw	Bubbler	Rm 5	<1	7/19/2018	
23.	11974	First Draw	Tap	Rm 5	<1	7/19/2018	
24.	11975	First Draw	Bubbler	Rm 10	<1	7/19/2018	
25.	11976	First Draw	Tap	Rm 10	<1	7/19/2018	
26.	11977	First Draw	Bubbler	Rm 9	<1	7/19/2018	
27.	11978	First Draw	Tap	Rm 9	<1	7/19/2018	
28.	11979	First Draw	Bubbler	Rm 6	1	7/19/2018	
29.	11980	First Draw	Tap	Rm 6	<1	7/19/2018	
30.	11981	First Draw	Bubbler	Rm 8	<1	7/19/2018	
31.	11982	First Draw	Tap	Rm 8	1	7/19/2018	
32.	11983	First Draw	Bubbler	Rm 7	2	7/19/2018	
33.	11984	First Draw	Tap	Rm 7	17	7/19/2018	
34.	11985	First Draw	Bubbler	Gym	2	7/19/2018	
35.	11986	First Draw	Tap	Kitchen	<1	7/19/2018	Only tap
36.	11987	First Draw	Bubbler	Trident commons	1	7/19/2018	
37.	11988	First Draw	Tap	Trident commons	3	7/19/2018	
38.	11989	First Draw	Bubbler	Rm 16	<1	7/19/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
39.	11990	First Draw	Tap	Rm 16	<1	7/19/2018	
40.	11991	First Draw	Bubbler	Rm 19	<1	7/19/2018	
41.	11992	First Draw	Tap	Rm 19	<1	7/19/2018	
42.	11993	First Draw	Bubbler	Rm 20	3	7/19/2018	
43.	11994	First Draw	Tap	Rm 20	<1	7/19/2018	
44.	11995	First Draw	Bubbler	Rm 21	<1	7/19/2018	
45.	11996	First Draw	Tap	Rm 21	<1	7/19/2018	
46.	11997	First Draw	Bubbler	Rm 22	<1	7/19/2018	
47.	11998	First Draw	Tap	Rm 22	4	7/19/2018	
48.	11999	First Draw	Bubbler	Rm 15	3	7/19/2018	
49.	12000	First Draw	Tap	Rm 15	4	7/19/2018	
50.	12001	First Draw	Bubbler	Rm 14	<1	7/19/2018	
51.	12002	First Draw	Tap	Rm 14	<1	7/19/2018	
52.	12003	First Draw	Bubbler	Rm 23	<1	7/19/2018	
53.	12004	First Draw	Tap	Rm 23	14	7/19/2018	
54.	12005	First Draw	Tap	Rm 13	3	7/19/2018	Bubbler function too low to test
55.	12006	First Draw	Bubbler	Rm 24	4	7/19/2018	
56.	12007	First Draw	Tap	Rm 24	30	7/19/2018	
57.	12008	First Draw	Tap	Nurse	1	7/19/2018	

