



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Oak Harbor School District

School Name: Olympic View Elementary

School Code: 3566

Address: 380 NE Regatta Drive Oak Harbor WA 98277

Number of Samples Collected: 53

Date Collected: 3/3/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	1371	First Draw	Sink Tap	Health Room	1	3/26/2018	
Sample 2	1372	First Draw	Sink Tap	Kitchen	1	3/26/2018	Sink near far wall
Sample 3	1374	First Draw	Left Sink Tap	Kitchen	11	3/26/2018	2-sink
Sample 4	1375	First Draw	Right Sink Tap	Kitchen	5	3/26/2018	2-sink
Sample 5	1376	First Draw	1-sink sprayer	Kitchen	<1	3/26/2018	1-sink
Sample 6	1377	First Draw	2-sink sprayer	Kitchen	1	3/26/2018	2-sink
Sample 7	1378	First Draw	Dish Sprayer	Kitchen	4	3/26/2018	Left of 2-sink compartment
Sample 8	1379	First Draw	Sink Tap	Kitchen	4	3/26/2018	Rinsing Sink
Sample 9	1380	First Draw	Left Lower Drinking Fountain	Main End Hallway	<1	3/26/2018	
Sample 10	1381	First Draw	Right Upper Fountain	Main End Hallway	<1	3/26/2018	
Sample 11	1382	First Draw	Sink Tap	B104	5	3/26/2018	
Sample 12	1383	First Draw	Bubbler	B104	2	3/26/2018	
Sample 13	1384	First Draw	Sink Tap	B106	4	3/26/2018	
Sample 14	1385	First Draw	Bubbler	B106	1	3/26/2018	
Sample 15	1386	First Draw	Sink Tap	B109	11	3/26/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 16	1387	First Draw	Bubbler	B109	1	3/26/2018	
Sample 17	1388	First Draw	Sink Tap	B101	2	3/26/2018	
Sample 18	1389	First Draw	Bubbler	B101	2	3/26/2018	
Sample 19	1390	First Draw	Sink Tap	C109	1	3/26/2018	
Sample 20	1391	First Draw	Bubbler	C109	1	3/26/2018	
Sample 21	1392	First Draw	Sink Tap	C101	2	3/26/2018	
Sample 22	1393	First Draw	Bubbler	C101	<1	3/26/2018	
Sample 23	1394	First Draw	Sink Tap	C104	5	3/26/2018	
Sample 24	1396	First Draw	Bubbler	C104	<1	3/26/2018	
Sample 25	1397	First Draw	Sink Tap	C106	2	3/26/2018	
Sample 26	1398	First Draw	Bubbler	C106	1	3/26/2018	
Sample 27	1399	First Draw	Sink Tap	D109	1	3/26/2018	
Sample 28	1400	First Draw	Bubbler	D109	<1	3/26/2018	
Sample 29	1401	First Draw	Sink Tap	D101	<1	3/26/2018	
Sample 30	1402	First Draw	Bubbler	D101	2	3/26/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 31	1403	First Draw	Sink Tap	D104	6	3/26/2018	
Sample 32	1404	First Draw	Bubbler	D104	1	3/26/2018	
Sample 33	1405	First Draw	Sink Tap	D106	4	3/26/2018	
Sample 34	1406	First Draw	Bubbler	D106	1	3/26/2018	
Sample 35	1407	First Draw	Sink Tap	E109	2	3/26/2018	
Sample 36	1408	First Draw	Bubbler	E109	1	3/26/2018	
Sample 37	1409	First Draw	Sink Tap	E101	3	3/26/2018	
Sample 38	1410	First Draw	Bubbler	E101	1	3/26/2018	
Sample 39	1411	First Draw	Sink Tap	E106	3	3/26/2018	
Sample 40	1412	First Draw	Bubbler	E106	<1	3/26/2018	
Sample 41	1413	First Draw	Sink Tap	E104	38	3/26/2018	Art Room Sink
Sample 42	1414	First Draw	Drinking Fountain	Pod G	3	3/26/2018	
Sample 43	1415	First Draw	Sink Tap	East side Kitchenette	TB		G Pod
Sample 44	1416	First Draw	Sink Tap	West side kitchenette	TB		G Pod
Sample 45	1417	First Draw	Sink Tap	F104	4	3/26/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 46	1418	First Draw	Bubbler	F104	1	3/26/2018	
Sample 47	1419	First Draw	Sink Tap	F106	1	3/26/2018	
Sample 48	1420	First Draw	Bubbler	F106	2	3/26/2018	
Sample 49	1421	First Draw	Sink Tap	F109	3	3/26/2018	
Sample 50	1422	First Draw	Bubbler	F109	1	3/26/2018	
Sample 51	1423	First Draw	Sink Tap	F101	3	3/26/2018	
Sample 52	1424	First Draw	Bubbler	F101	1	3/26/2018	Type: HAWS
Sample 53	1425		Blank		<1	3/26/2018	

TB= Turbidity. Further analysis is required.