



**Lead Sample Collection Information**

**School District Name: Kahlotus School District**

**School Name: Kahlotus Elementary/High School**

**School Code: 3214**

**Address: 100 W. Martin St. Kahlotus, WA 99335**

**Number of Samples Collected: 22**

**Date Collected: 2/16/2018**

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location                      | Lead Content (ppb) | Date of Analysis | Notes/Comments                               |
|---------------|-----------|-------------|---------------------|---------------------------------------|--------------------|------------------|--|
| Sample 1      | 671       | First Draw  | Bubbler             | Next to girls bathroom outside Office | <1                 | 02/28/2018       | High School                                  |
| Sample 2      | 672       | First Draw  | Sink                | Science Room                          | 3                  | 02/28/2018       | Sink under the Hood                          |
| Sample 3      | 673       | First Draw  | Sink                | Science Room                          | 1                  | 02/28/2018       | Sink with eyewash station                    |
| Sample 4      | 674       | First Draw  | Sink                | Science Room                          | 1                  | 02/28/2018       | Left sink, back wall                         |
| Sample 5      | 675       | First Draw  | Sink                | Science Room                          | 1                  | 02/28/2018       | Right sink, back wall                        |
| Sample 6      | 676       | First Draw  | Sink                | Business Room in the High School      | 1                  | 02/28/2018       | Left most sink, when facing inside of class  |
| Sample 7      | 677       | First Draw  | Sink                | Business Room in the High School      | 4                  | 02/28/2018       | Middle Sink, when facing inside of class     |
| Sample 8      | 678       | First Draw  | Bubbler             | Business Room in the High School      | 1                  | 02/28/2018       | Middle Sink, when facing inside of class     |
| Sample 9      | 679       | First Draw  | Sink                | Business Room in the High School      | TB                 | 02/28/2018       | Right most Sink, when facing inside of class |
| Sample 10     | 680       | First Draw  | Bubbler             | Ag Shop                               | <1                 | 02/28/2018       |  |
| Sample 11     | 681       | First Draw  | Sink                | Ag Shop                               | <1                 | 02/28/2018       |  |
| Sample 12     | 682       | First Draw  | Sink                | Grades K, 1, 2                        | 1                  | 02/28/2018       |  |

| Sample number | Sample ID | Sample Type | Fixture Description | Fixture Location                | Lead Content (ppb) | Date of Analysis | Notes/Comments                     |
|---------------|-----------|-------------|---------------------|---------------------------------|--------------------|------------------|------------------------------------|
| Sample 13     | 683       | First Draw  | Sink                | 3rd-4th grade Room              | 2                  | 02/28/2018       |                                    |
| Sample 14     | 684       | First Draw  | Sink                | 5th-6th grade Room              | TB                 | 02/28/2018       |                                    |
| Sample 15     | 685       | First Draw  | Sink                | Pre-school                      | TB                 | 02/28/2018       | Low pressure after a while         |
| Sample 16     | 686       | First Draw  | Bubbler             | Between Special Education Rooms | <1                 | 02/28/2018       |                                    |
| Sample 17     | 687       | First Draw  | Sink                | Special Education/Health Room   | 2                  | 02/28/2018       | Right Room when entering building  |
| Sample 18     | 688       | First Draw  | Sink                | Kitchen                         | <1                 | 02/28/2018       | Used. Main Sink, Right Side Faucet |
| Sample 19     | 689       | First Draw  | Sink                | Kitchen                         | <1                 | 02/28/2018       | Used. Main Sink, Left Side Faucet  |
| Sample 20     | 690       | First Draw  | Sink                | Kitchen                         | <1                 | 02/28/2018       | Handwashing Sink                   |
| Sample 21     | 691       | First Draw  | Bubbler             | Gym                             | <1                 | 02/28/2018       |                                    |
| Sample 22     | 692       | First Draw  | Bottle Filler       | Gym                             | <1                 | 02/28/2018       |                                    |