



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school has participated in follow up testing and recommended remediation to help reduce children's exposure to lead in drinking water.

School District: FederalWay

School Name: Uptown Square - ECEAP

School Code: NA

School Address: 1066 South 320th St, Building E, Federal Way Washington 98003

Number of Samples Collected: 12

Date Collected: 11/19/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28021	other	other		<1	11/25/2019	04227, 7:06 AM
28022	FirstDraw	Tap	Blue Room	<1	11/25/2019	Left Sink
28023	FirstDraw	Tap	Blue Room	<1	11/25/2019	Right Sink
28024	FirstDraw	Tap	Green Room	<1	11/25/2019	Left Sink
28025	FirstDraw	Tap	Green Room	<1	11/25/2019	Right Sink
28026	FirstDraw	Tap	Yellow Room	<1	11/25/2019	Left Sink, Room 01
28027	FirstDraw	Tap	Yellow Room	<1	11/25/2019	Right Sink, Room 01
28028	FirstDraw	Tap	Kitchen	<1	11/26/2019	Food Prep Sink
28029	FirstDraw	other	Kitchen	<1	11/26/2019	Food Prep Sink
28030	FirstDraw	WaterCooler	Kitchen	<1	11/26/2019	
28031	FirstDraw	Tap	Room 20A	<1	11/26/2019	
28032	FirstDraw	other	Room 20 A	<1	11/26/2019	Water Dispenser in Room