



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: Mukilteo
School Name: Explorer Middle School
School Code: 4231
School Address: 9600 Sharon Dr, Everett Washington 98204
Number of Samples Collected: 68
Date Collected: 05/18/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23928	other	other		<1	06/13/2019	7:15 AM, 06685
23929	FirstDraw	Tap	Health Clinic	TB	NA	Low flow
23930	FirstDraw	Tap	Kitchen (Food Prep Area)	3	06/13/2019	Dripping a little
23931	FirstDraw	other	Kitchen (Food Prep Area)	3	06/13/2019	
23932	FirstDraw	Bubbler	Hallway	TB	NA	Outside student office in House 4
23933	FirstDraw	Bubbler	Room 429	TB	NA	Low pressure
23934	FirstDraw	Tap	Room 429	TB	NA	
23935	FirstDraw	Tap	Room 428	<1	06/13/2019	Living Skills Room
23936	FirstDraw	Bubbler	Room 421	3	06/13/2019	
23937	FirstDraw	Tap	Room 421	<1	06/13/2019	
23938	FirstDraw	Bubbler	Outside Gym	<1	06/13/2019	Left Side
23939	FirstDraw	Bubbler	Outside Gym	<1	06/13/2019	Right Side
23940	FirstDraw	Bubbler	Girls Locker Room	TB	NA	
23941	FirstDraw	Bubbler	Outside Pool	<1	06/13/2019	
23942	FirstDraw	Bubbler	Pool Room	TB	NA	Left
23943	FirstDraw	Bubbler	Pool Room	<1	06/13/2019	Right
23944	FirstDraw	Bubbler	Northeast Hallway (House 2)	1	06/13/2019	Left Fountain
23945	FirstDraw	Bubbler	Northeast Hallway (House 2)	1	06/13/2019	Middle Fountain
23946	FirstDraw	Bubbler	Northeast Hallway (House 2)	<1	06/13/2019	Right Fountain

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23947	FirstDraw	Bubbler	Northwest Corner Hall (House 2)	<1	06/13/2019	Left Fountain near Room 213
23948	FirstDraw	Bubbler	Northwest Corner Hall (House 2)	<1	06/13/2019	Middle Fountain near Room 213
23949	FirstDraw	Bubbler	Northwest Corner Hall (House 2)	TB	NA	Right Founta
23950	FirstDraw	Tap	Art Room, Sink on Far Left	3	06/13/2019	Front of classroom
23951	FirstDraw	Tap	Art Room, Sink on Far Right	<1	06/13/2019	Middle sink not used due to plunger
23952	FirstDraw	Tap	Room 217, Station 7	<1	06/13/2019	Filter on tap, suspect drinking water use, leaky
23953	FirstDraw	Tap	Room 217, Station 6	7	06/13/2019	Unthreaded at Base, may or may not be used for drinking water
23954	FirstDraw	Tap	Room 217, Station 5	9	06/13/2019	May or may not be used for drinking water
23955	FirstDraw	Tap	Room 217, Station 4	12	06/13/2019	May or may not be used for drinking water

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23956	FirstDraw	Tap	Room 217, Station 3	TB	NA	May or may not be used for drinking water
23957	FirstDraw	Tap	Room 217, Station 1	13	06/13/2019	May or may not be used for drinking water
23958	FirstDraw	Tap	Room 218, Station 1	7	06/13/2019	May or may not be used for drinking water
23959	FirstDraw	Tap	Room 218, Station 2	4	06/13/2019	May or may not be used for drinking water
23960	FirstDraw	Tap	Room 218, Station 3	6	06/13/2019	May or may not be used for drinking water
23961	FirstDraw	Tap	Room 218, Station 4	TB	NA	May or may not be used for drinking water
23962	FirstDraw	Tap	Room 218, Station 5	10	06/13/2019	May or may not be used for drinking water
23963	FirstDraw	Tap	Room 218, Station 6	5	06/13/2019	May or may not be used for drinking water
23964	FirstDraw	Tap	Room 218, Station 7	TB	NA	May or may not be used for drinking water

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
23965	FirstDraw	Tap	Room 223, Lab 1	7	06/13/2019	Filter on tap, suspect only on this tap in classroom
23966	FirstDraw	Bubbler	Southwest Corner Hallway (House 2)	<1	06/13/2019	Left Fountain
23967	FirstDraw	Bubbler	Southwest Corner Hallway (House 2)	<1	06/13/2019	Middle Fountain
23968	FirstDraw	Bubbler	Southwest Corner Hallway (House 2)	1	06/13/2019	Right Fountain
23969	FirstDraw	Tap	Front Sink in Room 225	TB	NA	
24028	FirstDraw	Tap	Room 225, Station 1	<1	06/13/2019	
24029	FirstDraw	Tap	Room 225, Station 2	<1	06/13/2019	
24030	FirstDraw	Tap	Room 225, Station 3	<1	06/13/2019	
24031	FirstDraw	Tap	Room 225, Station 4	<1	06/13/2019	
24032	FirstDraw	Tap	Room 225, Station 5	<1	06/13/2019	
24033	FirstDraw	Tap	Room 225, Station 6	<1	06/13/2019	
24034	FirstDraw	Tap	Room 233, Library Office	TB	NA	Discolored Water
24035	FirstDraw	Bubbler	Southeast Corner (House 2)	2	06/13/2019	Left Fountain
24036	FirstDraw	Bubbler	Southeast Corner (House 2)	<1	06/13/2019	Middle Fountain

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
24037	FirstDraw	Bubbler	Southeast Corner (House 2)	1	06/13/2019	Right Fountain
24038	FirstDraw	Bubbler	Across from Room 316	<1	06/13/2019	Left Fountain, Used this morning
24039	FirstDraw	Bubbler	Across from Room 316	<1	06/13/2019	Right Fountain
24040	FirstDraw	Bubbler	Room 303	<1	06/13/2019	
24041	FirstDraw	Tap	Room 303	<1	06/13/2019	
24042	FirstDraw	Tap	MBCS Room	2	06/13/2019	Left Tap
24043	FirstDraw	Tap	MBCS Room	4	06/13/2019	Right Tap
24044	FirstDraw	WaterCooler	MBCS Room	<1	06/13/2019	
24045	FirstDraw	Bubbler	Band Room (House 3)	<1	06/13/2019	Sink in Room
24046	FirstDraw	Tap	Band Room (House 3)	1	06/13/2019	Sink in Room
24047	FirstDraw	Bubbler	Band Room (House 3)	<1	06/13/2019	Water Fountain in Room
24048	FirstDraw	Bubbler	Across from Room 351 (House 3)	<1	06/13/2019	Left Fountain, Used this morning
24049	FirstDraw	Bubbler	Across from Room 351 (House 3)	<1	06/13/2019	Right Fountain
24050	FirstDraw	WaterCooler	Portable 1	<1	06/13/2019	
24051	FirstDraw	WaterCooler	Portable 2	<1	06/13/2019	
24052	FirstDraw	WaterCooler	Portable 3	<1	06/13/2019	
24053	FirstDraw	WaterCooler	Portable 4	<1	06/13/2019	