



Lead Sample Collection Information

School District Name: Bremerton School District
School Name: Armin Jahr Elementary School
School Code: 3641
Address: 800 Dibb Street, Bremerton, WA 98310
Number of Samples Collected: 67
Date Collected: 2/21/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	1749	First Draw	Bubbler	Rm. 31	<1	3/2/2018	
Sample 2	1750	First Draw	Tap	Rm. 31	<1	3/2/2018	
Sample 3	1751	First Draw	Bubbler	Rm. 32	<1	3/2/2018	
Sample 4	1752	First Draw	Tap	Rm. 32	<1	3/2/2018	
Sample 5	1753	First Draw	Bubbler	Rm. 29	<1	3/2/2018	
Sample 6	1754	First Draw	Tap	Rm. 29	<1	3/2/2018	
Sample 7	1755	First Draw	Bubbler	Rm. 30	1	3/2/2018	
Sample 8	1756	First Draw	Tap	Rm. 30	<1	3/2/2018	
Sample 9	1757	First Draw	Tap	Rm. 27	<1	3/2/2018	In classroom
Sample 10	1758	First Draw	Tap	Rm. 27	<1	3/2/2018	Bathroom
Sample 11	1759	First Draw	Tap	Rm. 26	<1	3/2/2018	In classroom
Sample 12	1760	First Draw	Tap	Rm. 26	<1	3/2/2018	Bathroom
Sample 13	1761	First Draw	Tap	Rm. 25	<1	3/2/2018	In classroom
Sample 14	1762	First Draw	Water Cooler	Rm. 25	<1	3/2/2018	
Sample 15	1763	First Draw	Tap	Rm. 24	<1	3/2/2018	In classroom
Sample 16	1764	First Draw	Water Cooler	Rm. 24	<1	3/2/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 17	1765	First Draw	Bubbler	Rm. 22	4	3/2/2018	
Sample 18	1766	First Draw	Tap	Rm. 22	2	3/2/2018	
Sample 19	1767	First Draw	Bubbler	Rm. 23	3	3/2/2018	
Sample 20	1768	First Draw	Tap	Rm. 23	1	3/2/2018	
Sample 21	1769	First Draw	Bubbler	Rm. 20	4	3/2/2018	
Sample 22	1770	First Draw	Tap	Rm. 20	1	3/2/2018	
Sample 23	1771	First Draw	Bubbler	Rm. 21	2	3/2/2018	
Sample 24	1772	First Draw	Tap	Rm. 21	10	3/2/2018	
Sample 25	1773	First Draw	Bubbler	Rm. 19	4	3/2/2018	
Sample 26	1774	First Draw	Tap	Rm. 19	1	3/2/2018	
Sample 27	1775	First Draw	Bubbler	Rm. 18	11	3/2/2018	Room appears to be less regularly used
Sample 28	1776	First Draw	Tap	Rm. 18	1	3/2/2018	Room appears to be less regularly used
Sample 29	1777	First Draw	Bubbler	Rm. 17	<1	3/2/2018	
Sample 30	1778	First Draw	Tap	Rm. 17	1	3/2/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 31	1779	First Draw	Bubbler	Rm. 16	<1	3/2/2018	
Sample 32	1780	First Draw	Tap	Rm. 16	<1	3/2/2018	
Sample 33	1781	First Draw	Bubbler	Across from Rm. 18	<1	3/2/2018	Lower Left, Lower Function
Sample 34	1782	First Draw	Bubbler	Across from Rm. 19	<1	3/2/2018	Upper Right, Lower Function
Sample 35	1783	First Draw	Tap	Kitchen	11	3/2/2018	Left-hand Tap, In Corner Near Breaker Switch Box
Sample 36	1784	First Draw	Tap	Kitchen	3	3/2/2018	Right-hand Tap, In Corner Near Breaker Switch Box
Sample 37	1785	First Draw	Bubbler	Gym/Cafeteria	<1	3/2/2018	Low Function
Sample 38	1786	First Draw	Bubbler	Rm. 4	<1	3/2/2018	
Sample 39	1787	First Draw	Tap	Rm. 4	1	3/2/2018	
Sample 40	1788	First Draw	Bubbler	Rm. 5	<1	3/2/2018	
Sample 41	1789	First Draw	Tap	Rm. 5	3	3/2/2018	
Sample 42	1790	First Draw	Bubbler	Rm. 6	5	3/2/2018	
Sample 43	1791	First Draw	Tap	Rm. 6	4	3/2/2018	
Sample 44	1792	First Draw	Bubbler	Across from Rm. 6	<1	3/2/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 45	1793	First Draw	Bottle Filler	Across from Rm. 6	<1	3/2/2018	
Sample 46	1794	First Draw	Bubbler	Rm. 7	2	3/2/2018	
Sample 47	1795	First Draw	Tap	Rm. 7	5	3/2/2018	
Sample 48	1796	First Draw	Bubbler	Rm. 8	8	3/2/2018	
Sample 49	1797	First Draw	Tap	Rm. 8	6	3/2/2018	
Sample 50	1798	First Draw	Bubbler	Rm. 9	<1	3/2/2018	
Sample 51	1799	First Draw	Tap	Rm. 9	2	3/2/2018	
Sample 52	1800	First Draw	Bubbler	Rm. 11	<1	3/2/2018	
Sample 53	1801	First Draw	Tap	Rm. 11	4	3/3/2018	
Sample 54	1802	First Draw	Bubbler	Rm. 12	<1	3/3/2018	
Sample 55	1803	First Draw	Tap	Rm. 12	6	3/3/2018	
Sample 56	1804	First Draw	Bubbler	Rm. 13	<1	3/3/2018	
Sample 57	1805	First Draw	Tap	Rm. 13	1	3/3/2018	
Sample 58	1806	First Draw	Bubbler	Rm. 14	<1	3/3/2018	
Sample 59	1807	First Draw	Tap	Rm. 14	1	3/3/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 60	1808	First Draw	Bubbler	Nurse	4	3/3/2018	
Sample 61	1809	First Draw	Tap	Nurse	6	3/3/2018	
Sample 62	1810	First Draw	Tap	Rm. 15	3	3/3/2018	Possibly Irregular Use
Sample 63	1811	First Draw	Tap	Rm. 15A	13	3/3/2018	Possibly Irregular Use
Sample 64	1812	First Draw	Bubbler	Rm. 2	2	3/3/2018	
Sample 65	1813	First Draw	Tap	Rm. 2	13	3/3/2018	
Sample 66	1814	First Draw	Bubbler	Rm. 3	3	3/3/2018	
Sample 67	1815	First Draw	Tap	Rm. 3	9	3/3/2018	