



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name:   Bremerton School District**  
**School Name:            Kitsap Lake Elementary**  
**School Code:            4421**  
**Address:                111 Carr Blvd Bremerton WA 98312**  
**Number of Samples Collected: 60**  
**Date Collected:      3/23/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	4836	First Draw	Blank	Blank	<1	04/19/2018	Blank
Sample 2	4837	First Draw	Bubbler	Rm. 207	2	04/19/2018	
Sample 3	4838	First Draw	Tap	Rm. 207	4	04/19/2018	
Sample 4	4839	First Draw	Bubbler	Rm. 208	7	04/19/2018	
Sample 5	4840	First Draw	Tap	Rm. 208	3	04/19/2018	
Sample 6	4841	First Draw	Bubbler	Rm. 209	2	04/19/2018	
Sample 7	4842	First Draw	Tap	Rm. 209	6	04/19/2018	
Sample 8	4843	First Draw	Bubbler	Rm. 206	2	04/19/2018	
Sample 9	4844	First Draw	Tap	Rm. 206	5	04/19/2018	
Sample 10	4845	First Draw	Bubbler	Rm. 205	TB		
Sample 11	4846	First Draw	Tap	Rm. 205	TB		
Sample 12	4847	First Draw	Bubbler	Rm. 204	4	04/19/2018	
Sample 13	4848	First Draw	Tap	Rm. 204	9	04/19/2018	
Sample 14	4849	First Draw	Bubbler	2nd Floor Next to Elevator	<1	04/19/2018	
Sample 15	4850	First Draw	Bubbler	Rm .203	2	04/19/2018	
Sample 16	4851	First Draw	Tap	Rm. 203	3	04/19/2018	
Sample 17	4852	First Draw	Bubbler	Rm. 202	2	04/19/2018	
Sample 18	4853	First Draw	Tap	Rm. 202	3	04/19/2018	
Sample 19	4854	First Draw	Bubbler	Rm. 201	2	04/19/2018	
Sample 20	4855	First Draw	Tap	Rm. 201	5	04/19/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	4856	First Draw	Tap	Kitchen	7	04/19/2018	To right of dishwasher, left-hand tap
Sample 22	4857	First Draw	Tap	Kitchen	7	04/19/2018	To right of dishwasher, right-hand tap
Sample 23	4858	First Draw	Bubbler	Rm. 100	7	04/19/2018	Music
Sample 24	4859	First Draw	Tap	Rm. 100	9	04/19/2018	Music
Sample 25	4860	First Draw	Bubbler	Gym	<1	04/19/2018	
Sample 26	4861	First Draw	Bubbler	Next to custodian office	<1	04/19/2018	In between restrooms
Sample 27	4862	First Draw	Bubbler	Rm. 101	5	04/19/2018	Low Function
Sample 28	4863	First Draw	Tap	Rm. 101	4	04/19/2018	
Sample 29	4864	First Draw	Bubbler	Rm. 102	4	04/19/2018	
Sample 30	4865	First Draw	Tap	Rm. 102	5	04/19/2018	
Sample 31	4866	First Draw	Bubbler	Rm. 103	1	04/19/2018	
Sample 32	4867	First Draw	Tap	Rm. 103	3	04/19/2018	
Sample 33	4868	First Draw	Bubbler	Rm. 104	1	04/19/2018	
Sample 34	4869	First Draw	Tap	Rm. 104	2	04/19/2018	
Sample 35	4870	First Draw	Bubbler	Across from Library	<1	04/19/2018	
Sample 36	4871	First Draw	Bottle Filler	Across from Library	<1	04/19/2018	
Sample 37	4872	First Draw	Bubbler	Rm. 106	3	04/19/2018	
Sample 38	4873	First Draw	Tap	Rm. 106	4	04/19/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 39	4874	First Draw	Bubbler	Rm. 107	1	04/19/2018	
Sample 40	4875	First Draw	Tap	Rm. 107	3	04/19/2018	
Sample 41	4876	First Draw	Bubbler	Rm. 108	TB		
Sample 42	4877	First Draw	Tap	Rm. 108	14	04/19/2018	
Sample 43	4878	First Draw	Bubbler	Rm. 109	5	04/19/2018	Did not test ceramic handwashing sink
Sample 44	4879	First Draw	Tap	Rm. 109	3	04/19/2018	Did not test ceramic handwashing sink
Sample 45	4880	First Draw	Bubbler	Rm. 110	1	04/19/2018	Did not test ceramic handwashing sink
Sample 46	4881	First Draw	Tap	Rm. 110	2	04/19/2018	Did not test ceramic handwashing sink
Sample 47	4882	First Draw	Tap	Rm. 112	1	04/19/2018	Tested ceramic sink, only water in room
Sample 48	4883	First Draw	Bubbler	Rm. 111	<1	04/19/2018	
Sample 49	4884	First Draw	Tap	Rm. 111	2	04/19/2018	
Sample 50	4885	First Draw	Tap	Rm. 111	2	04/19/2018	Kitchen sink in back
Sample 51	4886	First Draw	Bubbler	Portable 3	<1	04/19/2018	
Sample 52	4887	First Draw	Tap	Portable 3	<1	04/19/2018	
Sample 53	4888	First Draw	Bubbler	Portable 4	<1	04/19/2018	
Sample 54	4889	First Draw	Tap	Portable 4	<1	04/19/2018	
Sample 55	4890	First Draw	Bubbler	Portable 1	1	04/19/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 56	4891	First Draw	Tap	Portable 1	<1	04/19/2018	
Sample 57	4892	First Draw	Tap	Portable 2	3	04/19/2018	
Sample 58	4893	First Draw	Bubbler	Portable 5	<1	04/19/2018	
Sample 59	4894	First Draw	Tap	Portable 5	<1	04/19/2018	
Sample 60	4895	First Draw	Bubbler	Portable 6	<1	04/19/2018	
Sample 61	4896	First Draw	Tap	Portable 6	<1	04/19/2018	

TB= Turbidity, further analysis required