



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Kiona Benton School District
School Name: Kiona Benton Primary School
School Code: 3502
Address: 913 Horne Drive Benton City WA 98320
Number of Samples Collected: 88
Date Collected: 5/1/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	6901	First Draw	Water Bottle Station	outside kitchen	1	05/25/2018	
Sample 2	6902	First Draw	Bubbler	outside kitchen	1	05/25/2018	
Sample 3	6903	First Draw	Bubbler	Outside facility lounge	1	05/25/2018	
Sample 4	6904	First Draw	Bubbler	Room 129	4	05/25/2018	
Sample 5	6905	First Draw	Tap	Room 129	11	05/25/2018	
Sample 6	6906	First Draw	Bubbler	Room 133	125	05/25/2018	
Sample 7	6907	First Draw	Tap	Room 133	87	05/25/2018	
Sample 8	6908	First Draw	Bubbler	Room 130	12	05/25/2018	
Sample 9	6909	First Draw	Tap	Room 130	7	05/25/2018	
Sample 10	6910	First Draw	Bubbler	Room 132	6	05/25/2018	
Sample 11	6911	First Draw	Tap	Room 132	52	05/25/2018	
Sample 12	6912	First Draw	Bubbler	Room 131	7	05/25/2018	
Sample 13	6913	First Draw	Tap	Room 131	30	05/25/2018	
Sample 14	6914	First Draw	Bubbler	Outside Room 131	5	05/25/2018	
Sample 15	6915	First Draw	Tap	Room 139	13	05/25/2018	
Sample 16	6916	First Draw	Bubbler	Room 139	4	05/25/2018	
Sample 17	6917	First Draw	Tap	Room 134	5	05/25/2018	
Sample 18	6918	First Draw	Bubbler	Room 134	5	05/25/2018	
Sample 19	6919	First Draw	Tap	Room 138	16	05/25/2018	
Sample 20	6920	First Draw	Bubbler	Room 138	3	05/25/2018	
Sample 21	6921	First Draw	Tap	Room 135	33	05/25/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 22	6922	First Draw	Bubbler	Room 135	3	05/25/2018	
Sample 23	6923	First Draw	Tap	Room 137	6	05/25/2018	
Sample 24	6924	First Draw	Bubbler	Room 137	5	05/25/2018	
Sample 25	6925	First Draw	Bubbler	Outside Room 115	<1	05/25/2018	left
Sample 26	6926	First Draw	Bubbler	Outside Room 115	<1	05/25/2018	right
Sample 27	6927	First Draw	Tap	Room 116	5	05/25/2018	
Sample 28	6928	First Draw	Bubbler	Room 116	<1	05/25/2018	
Sample 29	6929	First Draw	Tap	Room 122	2	05/25/2018	
Sample 30	6930	First Draw	Bubbler	Room 122	<1	05/25/2018	
Sample 31	6931	First Draw	Tap	Room 117	2	05/25/2018	
Sample 32	6932	First Draw	Bubbler	Room 117	<1	05/25/2018	
Sample 33	6933	First Draw	Tap	Room 118	2	05/25/2018	
Sample 34	6934	First Draw	Bubbler	Room 118	<1	05/25/2018	
Sample 35	6935	First Draw	Tap	Room 121	3	05/25/2018	
Sample 36	6936	First Draw	Bubbler	Room 121	<1	05/25/2018	
Sample 37	6937	First Draw	Tap	Room 120	4	05/25/2018	
Sample 38	6938	First Draw	Bubbler	Room 120	<1	05/25/2018	
Sample 39	6939	First Draw	Tap	Room 119	1	05/25/2018	
Sample 40	6940	First Draw	Bubbler	Room 119	3	05/25/2018	
Sample 41	6941	First Draw	Tap	Room 106	4	05/25/2018	
Sample 42	6942	First Draw	Bubbler	Room 106	<1	05/25/2018	
Sample 43	6943	First Draw	Tap	Room 115	3	05/25/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 44	6944	First Draw	Bubbler	Room 115	<1	05/25/2018	
Sample 45	6945	First Draw	Tap	Room 114	2	05/25/2018	
Sample 46	6946	First Draw	Bubbler	Room 114	<1	05/25/2018	
Sample 47	6947	First Draw	Tap	Room 107	1	05/25/2018	
Sample 48	6948	First Draw	Bubbler	Room 107	<1	05/25/2018	
Sample 49	6949	First Draw	Tap	Room 108	2	05/25/2018	
Sample 50	6950	First Draw	Bubbler	Room 108	<1	05/25/2018	
Sample 51	6951	First Draw	Tap	Room 113	5	05/25/2018	
Sample 52	6952	First Draw	Bubbler	Room 113	<1	05/25/2018	
Sample 53	6953	First Draw	Tap	Room 112	2	05/25/2018	
Sample 54	6954	First Draw	Bubbler	Room 112	<1	05/25/2018	
Sample 55	6955	First Draw	Tap	Room 109	<1	05/25/2018	
Sample 56	6956	First Draw	Bubbler	Room 109	<1	05/25/2018	
Sample 57	6957	First Draw	Tap	Room 110	2	05/25/2018	
Sample 58	6958	First Draw	Bubbler	Room 110	<1	05/25/2018	
Sample 59	6959	First Draw	Tap	Room 111	<1	05/25/2018	
Sample 60	6960	First Draw	Bubbler	Room 111	<1	05/25/2018	
Sample 61	6961	First Draw	Bubbler	Room 102	2	05/25/2018	left
Sample 62	6962	First Draw	Bubbler	Room 102	TB	TB	right
Sample 63	6963	First Draw	Tap	Room 101	4	05/25/2018	
Sample 64	6964	First Draw	Bubbler	Room 101	<1	05/25/2018	
Sample 65	6965	First Draw	Tap	Room 105	1	05/25/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 66	6966	First Draw	Bubbler	Room 105	1	05/25/2018	
Sample 67	6967	First Draw	Tap	Room 104	2	05/25/2018	left
Sample 68	6968	First Draw	Tap	Room 104	<1	05/25/2018	right
Sample 69	6969	First Draw	Tap	Nurse Station	1	05/25/2018	
Sample 70	6970	First Draw	Bubbler	Room 153	<1	05/25/2018	
Sample 71	6971	First Draw	Tap	Room 153	3	05/25/2018	
Sample 72	6972	First Draw	Tap	Room 154	<1	05/25/2018	left
Sample 73	6973	First Draw	Tap	Room 154	11	05/25/2018	right
Sample 74	6974	First Draw	BLANK	BLANK	<1	05/25/2018	
Sample 75	6975	First Draw	Tap	Room 152	13	05/25/2018	
Sample 76	6976	First Draw	Bubbler	Room 155	<1	05/25/2018	
Sample 77	6977	First Draw	Tap	Room 155	<1	05/25/2018	
Sample 78	6978	First Draw	Bubbler	Room 151	<1	05/25/2018	left
Sample 79	6979	First Draw	Bubbler	Room 151	<1	05/25/2018	right
Sample 80	6980	First Draw	Bubbler	Room 156	8	05/25/2018	
Sample 81	6981	First Draw	Bubbler	Room 157	5	05/26/2018	
Sample 82	6982	First Draw	Bubbler	Room 157	<1	05/26/2018	
Sample 83	6983	First Draw	Bubbler	Room 158	<1	05/26/2018	
Sample 84	6984	First Draw	Bubbler	Room 159	<1	05/26/2018	
Sample 85	6985	First Draw	Water Bottle Station	outside 158	<1	05/26/2018	
Sample 86	6986	First Draw	Bubbler	outside 158	6	05/26/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 87	6987	First Draw	Bubbler	Room 204	<1	05/26/2018	
Sample 88	6988	First Draw	Bubbler	Room 201	<1	05/26/2018	

Tb= Turbidity, further analysis required