



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Tacoma Schools

School Name: Madison Head Start

School Code:

Address: 3101 South 43rd St Tacoma 98409

County: Pierce

Number of Samples Collected: 22

Date Collected: 3/28/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	6207	First Draw	Tap	Kitchen Food Prep Area	7	8/9/2018	
Sample 2	6208	First Draw	Sprayer	Kitchen Food Prep Area	5	4/7/2018	
Sample 3	6209	First Draw	Tap	Room 9	17	8/9/2018	
Sample 4	6210	First Draw	Bubbler	Room 9	99	8/9/2018	slightly discolored
Sample 5	6212	First Draw	Tap	Room 10	<1	4/7/2018	
Sample 6	6213	First Draw	Bubbler	Room 10	6	4/7/2018	
Sample 7	6214	First Draw	Tap	Room 11	1	8/9/2018	
Sample 8	6215	First Draw	Bubbler	Room 11	5	4/7/2018	
Sample 9	6216	First Draw	Water Cooler	Room 11	<1	4/7/2018	
Sample 10	6217	First Draw	Tap	Room 12	3	8/9/2018	
Sample 11	6218	First Draw	Bubbler	Room 12	17	8/9/2018	
Sample 12	6219	First Draw	Water Cooler	Room 12	<1	4/7/2018	
Sample 13	6220	First Draw	Tap	Room 13	74	8/9/2018	
Sample 14	6221	First Draw	Bubbler	Room 13	13	8/9/2018	
Sample 15	6222	First Draw	Water Cooler	Room 13	<1	4/7/2018	
Sample 16	6223	First Draw	Drinking Fountain	West Entrance Hallway	3	4/7/2018	left
Sample 17	6224	First Draw	Drinking Fountain	West Entrance Hallway	2	4/7/2018	Right. water discolored
Sample 18	6228	First Draw	Tap	Room 3	23	8/9/2018	
Sample 19	6229	First Draw	Bubbler	Room 3	35	8/9/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 20	6225	First Draw	Tap	Room 4	7	4/7/2018	
Sample 21	6226	First Draw	Bubbler	Room 4	21	8/9/2018	
Sample 22	6227	First Draw	Drinking Fountain	Round building entrance	2	4/7/2018	
Sample 23	6230	First Draw	Blank	Front Entrance Hall	<1	4/7/2018	05920