



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Cheney High School

School Code: 3610

School District Name: Cheney

Address: 460 N 6th St, Cheney WA 99004

County: Spokane

Number of Samples Collected: 18

Date Collected: 10/09/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	12900	First Draw	Bubbler	Outside administration	<1	10/17/2018	
2.	12901	First Draw	Bottle Filler	Outside administration	<1	10/17/2018	
3.	12902	First Draw	Bubbler	Outside room 221	<1	10/17/2018	
4.	12904	First Draw	Bubbler	Outside room 602	<1	10/17/2018	
5.	12904	First Draw	Bottle Filler	Outside room 602	<1	10/17/2018	
6.	12905	First Draw	Tap	Nurses station	1	10/17/2018	
7.	12906	First Draw	Tap	Kitchen	<1	10/17/2018	Left
8.	12907	First Draw	Tap	Kitchen	4	10/17/2018	Right
9.	12908	First Draw	Bubbler	Gym	<1	10/17/2018	Under score board
10.	12909	First Draw	Bubbler	Gym	<1	10/17/2018	By girls locker room
11.	12910	First Draw	Bubbler	Outside room 404	<1	10/17/2018	
12.	12911	First Draw	Bottle Filler	outside Room 404	<1	10/17/2018	
13.	12912	First Draw	Bubbler	Outside room 509	<1	10/17/2018	
14.	12913	First Draw	Bottle Filler	Outside room 509	<1	10/17/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
15.	12914	First Draw	Bubbler	Outside room 400	<1	10/17/2018	
16.	12915	First Draw	Bottle Filler	Outside room 400	<1	10/17/2018	
17.	12916	First Draw	Bubbler	Outside room 310	8	10/17/2018	
18.	12917	First Draw	Blank	Blank	<1	10/17/2018	