



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Federal Way
School Name: Lake Grove Elementary
School Code: 3568
Address: 303 SW 308th St, Federal Way WA 98023
Number of Samples Collected: 49
Date Collected: 05/30/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	9727	First Draw	Tap	Health Room	13	06/20/2018	6:15 AM
2.	9730	First Draw	Bubbler	In hallway next to Health Room	14	06/20/2018	
3.	9744	First Draw	Bubbler	Room 103	9	06/20/2018	
4.	9745	First Draw	Tap	Room 103	5	06/20/2018	
5.	9746	First Draw	Bubbler	Room 105	14	06/20/2018	
6.	9747	First Draw	Tap	Room 105	14	06/20/2018	
7.	9748	First Draw	Bubbler	Room 107	3	06/20/2018	
8.	9749	First Draw	Tap	Room 107	4	06/20/2018	
9.	9750	First Draw	Bubbler	Room 109	17	06/20/2018	
10.	9751	First Draw	Tap	Room 109	8	06/20/2018	
11.	9752	First Draw	Bubbler	Room 111	8	06/20/2018	
12.	9753	First Draw	Tap	Room 111	6	06/20/2018	
13.	9754	First Draw	Bubbler	Room 113	14	06/20/2018	
14.	9755	First Draw	Tap	Room 113	19	06/20/2018	
15.	9756	First Draw	Bubbler	Room 112	15	06/20/2018	
16.	9757	First Draw	Tap	Room 112	7	06/20/2018	
17.	9758	First Draw	Bubbler	Room 110	15	06/20/2018	
18.	9759	First Draw	Tap	Room 110	11	06/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	9760	First Draw	Bubbler	Room 108	11	06/20/2018	
20.	9761	First Draw	Tap	Room 108	16	06/20/2018	
21.	9762	First Draw	Bubbler	Room 106	12	06/20/2018	
22.	9763	First Draw	Tap	Room 106	8	06/20/2018	
23.	9764	First Draw	Bubbler	Between 108 and 106	9	06/20/2018	
24.	9765	First Draw	Bubbler	Room 201	11	06/20/2018	
25.	9766	First Draw	Tap	Room 201	9	06/20/2018	
26.	9767	First Draw	Bubbler	Room 203	14	06/20/2018	
27.	9768	First Draw	Tap	Room 203	7	06/20/2018	
28.	9769	First Draw	Bubbler	Room 205	7	06/20/2018	
29.	9770	First Draw	Tap	Room 205	15	06/20/2018	
30.	9771	First Draw	Bubbler	Room 207	11	06/20/2018	
31.	9772	First Draw	Tap	Room 207	5	06/20/2018	
32.	9773	First Draw	Bubbler	Room 209	5	06/20/2018	
33.	9774	First Draw	Tap	Room 209	3	06/20/2018	
34.	9775	First Draw	Bubbler	Room 211	14	06/20/2018	
35.	9776	First Draw	Tap	Room 211	5	06/20/2018	
36.	9777	First Draw	Bubbler	Room 212	3	06/20/2018	
37.	9778	First Draw	Tap	Room 212	1	06/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
38.	9779	First Draw	Tap	Room 214	4	06/20/2018	No bubbler
39.	9780	First Draw	Bubbler	Room 210	19	06/20/2018	
40.	10501	First Draw	Tap	Room 210	5	06/20/2018	06045
41.	10502	First Draw	Bubbler	Room 208	10	06/20/2018	06048
42.	10503	First Draw	Tap	Room 208	4	06/20/2018	06055
43.	10504	First Draw	Bubbler	Between 208 and 206	16	06/20/2018	06056
44.	10505	First Draw	Bubbler	Room 206	12	06/20/2018	06061
45.	10506	First Draw	Tap	Room 206	6	06/20/2018	06063
46.	10507	First Draw	Bubbler	Room 204	17	06/20/2018	06081
47.	10508	First Draw	Pot Filler	Room 204	6	06/20/2018	06069
48.	10509	First Draw	Bubbler	Outside gym and kitchen	15	06/20/2018	06073
49.	10510	Blank	Blank	Near entrance	<1	06/20/2018	03462