



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

School District: Wapato

School Name: Adams Elementary School

School Code: 4518

School Address: 1309 S Camas Ave, Wapato Washington 98951

Number of Samples Collected: 7

Date Collected: 06/13/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
26000	FirstDraw	Bubbler	Across from Main Office	<1	06/27/2019	
26001	FirstDraw	Bubbler	Next to 6	<1	06/27/2019	
26002	FirstDraw	Bubbler	Across from 13	<1	06/27/2019	
26003	FirstDraw	Tap	Kitchen	2	06/27/2019	Triple sink left tap
26004	FirstDraw	Tap	Kitchen	<1	06/27/2019	Single tap with sprayer under window
26005	FirstDraw	Tap	Teachers lounge	<1	06/27/2019	
26007	FirstDraw	Tap	Nurse	TB	NA	Note*** All classroom drinking water shut off