



Lead Sample Collection Information

School District Name: Oakville School District
School Name: Oakville Elementary and High School
School Code: 2922
Address: 103 School St. Oakville, Washington 98568
Number of Samples Collected: 21
Date Collected: 2/2/2018

Sample number	Sample Id	Sample Type	Fixture Description	Fixture Location	Lead Content ppb	Date of Analysis	Notes/comments
Sample 1	197	First Draw	Tap	Room M3	4	02/13/2018	
Sample 2	198	First Draw	Tap	Room M4	3	02/13/2018	
Sample 3	199	First Draw	Tap	Room M6	5	02/13/2018	
Sample 4	200	First Draw	Tap	Room M6	TB	02/13/2019	possibly a dish sink
Sample 5	201	First Draw	Tap	Room M9	3	02/13/2018	
Sample 6	202	First Draw	Tap	Room M10	3	02/13/2018	
Sample 7	203	First Draw	Tap	Room M11	6	02/13/2018	
Sample 8	204	First Draw	Bubbler	Gym	7	02/13/2018	irregular function
Sample 9	205	First Draw	Water Cooler	Room M5	<1	02/13/2018	free standing fixture
Sample 10	206	First Draw	Water Cooler	Room M6	<1	02/13/2018	free standing fixture
Sample 11	207	First Draw	Bubbler	Next to H15	3	02/13/2018	
Sample 12	208	First Draw	Bubbler	Next to H19	2	02/13/2018	
Sample 13	209	First Draw	Water Cooler	High School Office	<1	02/13/2018	free standing fixture
Sample 14	210	First Draw	Bubbler	Next to H4	14	02/13/2018	in student commons
Sample 15	211	First Draw	Bubbler	Next to Field Storage room	2	02/13/2018	
Sample 16	212	First Draw	Water Cooler	Room H22	<1	02/13/2018	free standing fixture
Sample 17	213	First Draw	Tap	Kitchen	2	02/13/2018	left-hand higher tap
Sample 18	214	First Draw	Tap	Kitchen	6	02/13/2018	right-hand lower tap

Sample number	Sample Id	Sample Type	Fixture Description	Fixture Location	Lead Content ppb	Date of Analysis	Notes/comments
Sample 19	215	First Draw	Water Cooler	Admin Building	<1	02/13/2018	lobby, free standing fixture
Sample 20	216	First Draw	Bubbler	Admin Building P3	12	02/13/2018	irregular Use
Sample 21	217	First Draw	Tap	Admin Building P3	29	02/13/2018	irregular Use

TB= Turbidty