



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Seattle Public Schools**

**School Name: Maple Elementary**

**School Code: 2353**

**Address: 4925 Corson Ave S Seattle WA 98108**

**Number of Samples Collected: 47**

**Date Collected: 4/5/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	6189	First Draw	Tap	Kitchen	1	04/11/2018	24, single sink
Sample 2	6190	First Draw	Tap	Kitchen, Left Sink	2	04/11/2018	23, 2-sink compartment
Sample 3	6191	First Draw	Tap	Kitchen, Right Sink	1	04/11/2018	23A, 2-sink compartment
Sample 4	6237	First Draw	Left Drinking Fountain	Outside Gym	<1	04/11/2018	37
Sample 5	6238	First Draw	Right Drinking Fountain	Outside Gym	4	04/11/2018	38
Sample 6	6239	First Draw	Tap	Room 140	<1	04/11/2018	33
Sample 7	6240	First Draw	Bubbler	Room 140	<1	04/11/2018	33
Sample 8	6241	First Draw	Tap	Room 142	1	04/11/2018	34
Sample 9	6242	First Draw	Bubbler	Room 142	<1	04/11/2018	34
Sample 10	6243	First Draw	Tap	Room 144	2	04/11/2018	35
Sample 11	6244	First Draw	Bubbler	Room 144	<1	04/11/2018	35
Sample 12	6245	First Draw	Tap	Staff Lounge	<1	04/11/2018	25, same building as gym
Sample 13	6246	First Draw	Tap	Nurse's Office	7	04/11/2018	18
Sample 14	6247	First Draw	Tap	Main Office	3	04/11/2018	21, Britta Filter attached
Sample 15	6248	First Draw	Drinking Fountain	Main Hallway, across from entrance	<1	04/11/2018	01 on map
Sample 16	6249	First Draw	Tap	Pod B	10	04/11/2018	04 on map
Sample 17	6250	First Draw	Bubbler	Pod B	4	04/11/2018	04 on map
Sample 18	6251	First Draw	Tap	Pod B-C, Outside	<1	04/11/2018	5, 1st sink on left

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
				Bathrooms			
Sample 19	6252	First Draw	Bubbler	Pod B-C, Outside Bathrooms	<1	04/11/2018	5, 1st sink on left
Sample 20	6253	First Draw	Tap	Pod B-C, Outside Bathrooms	1	04/11/2018	5A, 2nd sink on left, 5A
Sample 21	6254	First Draw	Tap	Pod B-C, Outside Bathrooms	<1	04/11/2018	6A, 3rd sink from left
Sample 22	6255	First Draw	Bubbler	Pod B-C, Outside Bathrooms	<1	04/11/2018	6, 4th sink from left
Sample 23	6257	First Draw	Tap	Pod B-C, Outside Bathrooms	1	04/11/2018	6, 4th sink from left
Sample 24	6259	First Draw	Bubbler	Pod C	6	04/11/2018	07
Sample 25	6261	First Draw	Tap	Pod C	4	04/11/2018	07
Sample 26	6262	First Draw	Bubbler	Outside Bathroom near Pod D	4	04/11/2018	51
Sample 27	6263	First Draw	Bubbler	Outside Bathroom near Pod D	1	04/11/2018	52
Sample 28	6264	First Draw	Bubbler	Pod E	5	04/11/2018	11
Sample 29	6265	First Draw	Tap	Pod E	3	04/11/2018	11
Sample 30	6266	First Draw	Bubbler	Pod E-F, Outside Bathrooms	<1	04/12/2018	10A

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 31	6267	First Draw	Tap	Pod E-F, Outside Bathrooms	<1	04/12/2018	10A
Sample 32	6268	First Draw	Tap	Pod E-F, Outside Bathrooms	<1	04/12/2018	10
Sample 33	6269	First Draw	Tap	Pod E-F, Outside Bathrooms	9	04/12/2018	9A
Sample 34	6270	First Draw	Bubbler	Pod E-F, Outside Bathrooms	2	04/12/2018	9
Sample 35	6271	First Draw	Tap	Pod E-F, Outside Bathrooms	3	04/12/2018	9
Sample 36	6272	First Draw	Bubbler	Pod F	9	04/12/2018	08
Sample 37	6273	First Draw	Tap	Pod F	7	04/12/2018	08
Sample 38	6274	First Draw	Tap	Room 033 in Pod F	8	04/12/2018	44
Sample 39	6276	First Draw	Bubbler	Pod A	7	04/12/2018	42
Sample 40	6277	First Draw	Tap	Pod A	4	04/12/2018	42
Sample 41	6278	First Draw	Tap	Pod A, Outside Bathrooms	<1	04/12/2018	20A
Sample 42	6279	First Draw	Bubbler	Pod A, Outside Bathrooms	<1	04/12/2018	20A
Sample 43	6280	First Draw	Tap	Pod A, Outside Bathrooms	1	04/12/2018	20

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 44	6281	First Draw	Bubbler	A2	6	04/12/2018	02, used this morning
Sample 45	6282	First Draw	Tap	A2	6	04/12/2018	02, used this morning
Sample 46	6284	First Draw	Tap	A1	1	04/12/2018	43, used this morning
Sample 47	6285	First Draw	Bubbler	A1	1	04/12/2018	43, used this morning
Sample 48	6286		Blank		<1	04/12/2018	

Numbers in comments identify each fixture according to the school map