



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Elma

School Name: Elma High School

School Code: 2137

Address: 1235 Monte-Elma Rd, Elma WA 98541

Number of Samples Collected: 36

Date Collected: 06/01/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	9923	First Draw	Tap	Kitchen	4	6/20/2018	Single sink near door to loading dock
2.	9924	First Draw	Pot Filler		30	6/20/2018	
3.	9925	First Draw	Tap	Kitchen	4	6/20/2018	Double sink left tap
4.	9926	First Draw	Tap	Kitchen	6	6/20/2018	Double sink right tap
5.	9927	First Draw	Tap	Kitchen	2	6/20/2018	Hand washing sink/ used for filling
6.	9928	First Draw	Bubbler	Outside office	11	6/20/2018	Left
7.	9929	First Draw	Bubbler	Outside office	2	6/20/2018	Right
8.	9930	First Draw	Tap	Office sink	31	6/20/2018	
9.	9931	First Draw	Tap	Nurse	6	6/20/2018	
10.	9932	First Draw	Tap	CTE Secretary office	37	6/20/2018	
11.	9933	First Draw	Tap	Staff lounge	4	6/20/2018	
12.	9934	First Draw	Bubbler	2nd Floor next to elevator	<1	6/20/2018	
13.	9935	First Draw	Bottle Filler	2nd Floor next to elevator	<1	6/20/2018	
14.	9936	First Draw	Tap	Rm 157	20	6/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
15.	9937	First Draw	Tap	Rm 160	7	6/20/2018	
16.	9938	First Draw	Tap	Food lab	12	6/20/2018	Student sink 1 clockwise
17.	9939	First Draw	Tap	Food lab	26	6/20/2018	Student sink 2
18.	9940	First Draw	Tap	Food lab	23	6/20/2018	Student sink 3
19.	9941	First Draw	Tap	Food lab	24	6/20/2018	Student sink 5
20.	9942	First Draw	Tap	Food lab	13	6/20/2018	Student sink 6
21.	9943	First Draw	Tap	Food lab	10	6/20/2018	Teacher sink
22.	9944	First Draw	Tap	Food lab	49	6/20/2018	Pantry sink
23.	9945	First Draw	Bubbler	Annex	23	6/20/2018	
24.	9946	First Draw	Tap	Library office	26	6/20/2018	
25.	9947	First Draw	Bubbler	Outside laundry room	<1	6/20/2018	Left
26.	9948	First Draw	Bottle Filler	Outside laundry room	<1	6/20/2018	
27.	9949	First Draw	Bubbler	Outside laundry room	14	6/20/2018	Right
28.	9950	First Draw	Bubbler	Gym	5	6/20/2018	
29.	9951	First Draw	Bubbler	Wrestling room	3	6/20/2018	
30.	9952	First Draw	Bubbler	Band room	1	6/20/2018	
31.	9953	First Draw	Bubbler	Wood shop	3	6/20/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
32.	9954	First Draw	Bubbler	Outside weight room	<1	6/20/2018	
33.	9955	First Draw	Bottle Filler	Outside weight room	<1	6/20/2018	
34.	9956	First Draw	Bubbler	Metal shop	3	6/20/2018	
35.	9957	First Draw	Bubbler	Aircraft fabrication	2	6/20/2018	
36.	9960	First Draw	Blank	Blank	<1	6/20/2018	