



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school has participated in follow up testing and recommended remediation to help reduce children's exposure to lead in drinking water. The school was sampled on two separate days due to its size and to ensure testing in compliance with EPA 3ts.

School District: FederalWay

School Name: Decatur High School

School Code: 3766

School Address: 2800 SW 320th ST, Federal Way Washington 98023

Number of Samples Collected: 24

Date Collected: 12/17/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30147	other			<1	01/02/2020	
30148	FirstDraw	Bubbler	Gym: girl locker room (PE side) bubbler	3	01/02/2020	
30149	FirstDraw	Bubbler	Gym: girl locker room (Sports side)	<1	01/02/2020	
30150	FirstDraw	Bubbler	Gym: boy locker room (PE side)	2	01/02/2020	
30151	FirstDraw	Bubbler	Gym: boy locker room (Sports side)	<1	01/02/2020	
30152	FirstDraw	Bubbler	Gym: boy locker room (Sports side) weight room bubbler	<1	01/02/2020	
30153	FirstDraw	Bubbler	Gym	<1	01/02/2020	
30154	FirstDraw	Tap	Rm 510: instructor tap	4	01/02/2020	
30155	FirstDraw	Tap	Rm 510 front wall tap closest to door	6	01/02/2020	
30156	FirstDraw	Tap	Rm 510 front wall (where entry door is) left tap	17	01/02/2020	
30157	FirstDraw	Tap	Rm 510 side wall (4 taps located on this side): rightmost tap	92	01/02/2020	Cold water not functional: taken from hot side (water still cool)

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30158	FirstDraw	Tap	Rm 510 side wall, tap left of rightmost tap	23	01/02/2020	
30159	FirstDraw	Tap	Rm 510:side wall tap right of leftmost tap	74	01/02/2020	
30160	FirstDraw	Tap	Rm 510 side wall leftmost tap	90	01/02/2020	
30161	FirstDraw	Tap	Rm 510: wall with exit door: right tap	9	01/02/2020	
30162	FirstDraw	Tap	Rm 510: wall with exit door, left tap	26	01/02/2020	
30163	FirstDraw	Tap	Rm 509: wall with entry door, leftmost tap (closest to door)	30	01/02/2020	
30164	FirstDraw	Tap	Rm 509: wall with entry door, tap to right of leftmost tap	43	01/02/2020	
30165	FirstDraw	Tap	Rm 509: wall with entry door, tap left of rightmost tap	19	01/02/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
30166	FirstDraw	Tap	Rm 509: wall with entry door, rightmost tap	15	01/02/2020	
30167	FirstDraw	Tap	Rm 509: wall with exit door, rightmost tap	54	01/02/2020	
30168	FirstDraw	Tap	Rm 509: wall with exit door, tap left of rightmost door	15	01/02/2020	
30169	FirstDraw	Tap	Rm 509: wall with exit door, tap right of leftmost tap	35	01/02/2020	
30170	FirstDraw	Tap	Rm 509: wall with exit door, leftmost tap	15	01/02/2020	
NA	FirstDraw			TB	NA	