



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school district is following recommended measures to reduce children's overall exposure to lead.

School District: Kent

School Name: Sunrise Elementary School

School Code: 4420

School Address: 22300 132nd Ave SE, Kent Washington 98042

Number of Samples Collected: 60

Date Collected: 03/20/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
14239	FirstDraw	Bubbler	Room 210	1	04/08/2019	
14240	FirstDraw	Tap	Room 210	2	04/08/2019	
14241	FirstDraw	Tap	Room 211	4	04/08/2019	
14242	FirstDraw	Bubbler	Room 211	1	04/08/2019	
14243	FirstDraw	Bubbler	Room 212	1	04/08/2019	
14244	FirstDraw	Tap	Room 212	6	04/08/2019	
14245	FirstDraw	Tap	Room 213	1	04/08/2019	
14246	FirstDraw	Bubbler	Room 213	<1	04/08/2019	
14247	FirstDraw	Bubbler	Room 214	<1	04/08/2019	
14248	FirstDraw	Tap	Room 214	2	04/08/2019	
14249	FirstDraw	Bubbler	Outside room 189	<1	04/08/2019	
14250	FirstDraw	Bubbler	Outside room 146	<1	04/08/2019	
14251	FirstDraw	Bubbler	Room 209	1	04/08/2019	
14252	FirstDraw	Tap	Room 209	3	04/08/2019	
14253	FirstDraw	Bubbler	Room 217	<1	04/08/2019	
14254	FirstDraw	Bubbler	Outside room 203	<1	04/08/2019	
14255	FirstDraw	Bubbler	Room 218	<1	04/08/2019	
14256	FirstDraw	Tap	Room 217	2	04/08/2019	
14257	FirstDraw	Tap	Room 219	2	04/08/2019	
14258	FirstDraw	Tap	Room 218	2	04/08/2019	
14259	FirstDraw	Tap	Room 220	<1	04/08/2019	
14260	FirstDraw	Bubbler	Room 219	<1	04/08/2019	
14261	FirstDraw	Bubbler	Room 220	3	04/08/2019	
14262	FirstDraw	Tap	Room 221	3	04/08/2019	
14263	FirstDraw	Bubbler	Room 221	1	04/08/2019	
14264	FirstDraw	Tap	Room 222	2	04/08/2019	
14265	FirstDraw	Bubbler	Room 222	<1	04/08/2019	
14266	FirstDraw	Bubbler	Room 188	<1	04/08/2019	
14267	FirstDraw	Tap	Room 188	3	04/08/2019	
14268	FirstDraw	Tap	Room 187	2	04/08/2019	
14269	FirstDraw	Bubbler	Room 187	<1	04/08/2019	
14270	FirstDraw		Room 186	1	04/08/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
14271	FirstDraw	Tap	Room 186	2	04/08/2019	
14272	FirstDraw	Tap	Room 185	2	04/08/2019	
14273	FirstDraw	Bubbler	Room 185	<1	04/08/2019	
14274	FirstDraw	other	Blank	<1	04/08/2019	
14275	FirstDraw	Tap	Room 184	1	04/08/2019	
14276	FirstDraw	Bubbler	Room 183	<1	04/08/2019	
14277	FirstDraw	Bubbler	Room 184	<1	04/08/2019	
14278	FirstDraw	Tap	Room 183	1	04/08/2019	
14279	FirstDraw	Tap	Nurses station	1	04/08/2019	
14280	FirstDraw	Bubbler	Room 123	<1	04/08/2019	
14281	FirstDraw	Tap	Room 122	5	04/08/2019	
14282	FirstDraw	Tap	Room 123	1	04/08/2019	
14283	FirstDraw	Bubbler	Room 124	1	04/08/2019	
14284	FirstDraw	Bubbler	Room 128	1	04/08/2019	
14285	FirstDraw	Tap	Room 128	2	04/08/2019	
14286	FirstDraw	Tap	Kitchen	6	04/08/2019	Left
14287	FirstDraw	Bubbler	Room 129	1	04/08/2019	
14288	FirstDraw	Tap	Room 129	3	04/08/2019	
14289	FirstDraw	Bubbler	Room 130	<1	04/08/2019	
14290	FirstDraw	Tap	Room 130	2	04/08/2019	
14291	FirstDraw	Bubbler	Room 144	1	04/08/2019	
14292	FirstDraw	Tap	Room 144	6	04/08/2019	
14293	FirstDraw	Tap	Room 124	2	04/08/2019	
14294	FirstDraw	Tap	Kitchen	13	04/08/2019	Right
14295	FirstDraw	Bubbler	Gym	<1	04/08/2019	Near office
14296	FirstDraw	Bubbler	Gym	<1	04/08/2019	
14297	FirstDraw	Bubbler	Room 168	TB	NA	
14298	FirstDraw	Tap	Room 168	7	04/08/2019	