



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Evergreen School District

School Name: Riverview Elementary School

School Code: 3995

Address: 12601 SE Riverridge Dr Vancouver WA 98683

County: Clark

Number of Samples Collected: 52

Date Collected: 3/14/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	4551	First Draw	Blank	Blank	<1	4/30/2018	Blank
Sample 2	4554	First Draw	Tap	Kitchen	110	8/6/2018	Under Window, Right-hand Tap
Sample 3	4555	First Draw	Tap	Kitchen	2	4/30/2018	Under Window, Left-hand Tap
Sample 4	4556	First Draw	Bubbler	Rm. 101	4	4/30/2018	
Sample 5	4557	First Draw	Tap	Rm. 101	3	4/30/2018	
Sample 6	4558	First Draw	Bubbler	Rm. 103	2	4/30/2018	
Sample 7	4559	First Draw	Tap	Rm. 103	3	4/30/2018	
Sample 8	4560	First Draw	Bubbler	Rm. 104	5	4/30/2018	
Sample 9	4561	First Draw	Tap	Rm. 104	2	4/30/2018	
Sample 10	4562	First Draw	Bubbler	Rm. 105	6	4/30/2018	
Sample 11	4563	First Draw	Tap	Rm. 105	7	4/30/2018	
Sample 12	4564	First Draw	Tap	Rm. 131	1	4/30/2018	
Sample 13	4565	First Draw	Bubbler	Rm. 106	4	4/30/2018	
Sample 14	4566	First Draw	Tap	Rm. 106	3	4/30/2018	
Sample 15	4567	First Draw	Bubbler	Rm. 107	5	4/30/2018	
Sample 16	4568	First Draw	Tap	Rm. 107	4	5/1/2018	
Sample 17	4569	First Draw	Bubbler	Rm. 108	2	5/1/2018	
Sample 18	4570	First Draw	Tap	Rm. 108	8	5/1/2018	
Sample 19	4571	First Draw	Bubbler	Rm. 109	4	5/1/2018	
Sample 20	4572	First Draw	Tap	Rm. 109	8	5/1/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	4573	First Draw	Bubbler	Rm. 110	5	5/1/2018	
Sample 22	4574	First Draw	Tap	Rm. 110	31	5/1/2018	
Sample 23	4575	First Draw	Bubbler	Rm. 111	4	5/1/2018	
Sample 24	4576	First Draw	Tap	Rm. 111	5	5/1/2018	
Sample 25	4577	First Draw	Bubbler	Rm. 112	2	5/1/2018	
Sample 26	4578	First Draw	Tap	Rm. 112	3	5/1/2018	
Sample 27	4579	First Draw	Bubbler	Rm. 113	2	5/1/2018	
Sample 28	4580	First Draw	Tap	Rm. 113	4	5/1/2018	Leaks During Use
Sample 29	4581	First Draw	Bubbler	Rm. 135	2	5/1/2018	
Sample 30	4582	First Draw	Tap	Rm. 135	6	5/1/2018	
Sample 31	4583	First Draw	Tap	Rm. 114	9	5/1/2018	Bubbler Labeled "Do Not Use"
Sample 32	4584	First Draw	Water Cooler	Rm. 114	<1	5/1/2018	
Sample 33	4585	First Draw	Bubbler	Rm. 115	9	5/1/2018	
Sample 34	4586	First Draw	Tap	Rm. 115	7	5/1/2018	
Sample 35	4587	First Draw	Tap	Rm. 116	3	5/1/2018	Bubbler Labeled "Do Not Use"
Sample 36	4588	First Draw	Water Cooler	Rm. 116	<1	5/1/2018	
Sample 37	4589	First Draw	Bubbler	Rm. 117	6	5/1/2018	
Sample 38	4590	First Draw	Tap	Rm. 117	13	5/1/2018	
Sample 39	4591	First Draw	Bubbler	Rm. 118	5	5/1/2018	
Sample 40	4592	First Draw	Tap	Rm. 118	5	5/1/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 41	4593	First Draw	Tap	Rm. 119	3	5/1/2018	Bubbler Labeled "Do Not Use"
Sample 42	4594	First Draw	Water Cooler	Rm. 119	<1	5/1/2018	
Sample 43	4595	First Draw	Bubbler	Rm. 120	6	5/1/2018	
Sample 44	4596	First Draw	Tap	Rm. 120	6	5/1/2018	
Sample 45	4597	First Draw	Bubbler	Rm. 121	2	5/1/2018	
Sample 46	4598	First Draw	Tap	Rm. 121	2	5/1/2018	
Sample 47	4599	First Draw	Bubbler	Rm. 122	7	5/1/2018	
Sample 48	4600	First Draw	Tap	Rm. 122	6	5/1/2018	
Sample 49	4601	First Draw	Bubbler	Next to Music and P. E.	<1	5/1/2018	
Sample 50	4602	First Draw	Bubbler	Next to Front Desk	<1	5/1/2018	
Sample 51	4603	First Draw	Bottle Filler	Next to Front Desk	<1	5/1/2018	
Sample 52	4604	First Draw	Tap	Nurse	2	5/1/2018	