



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school has replaced fixtures with elevated levels and is participating in follow up testing and recommendations

School Name: Rocky Ridge Elementary

School Code: 4227

School District Name: Bethel

Address: 6514 260th St E, Graham WA 98338

County: Pierce

Number of Samples Collected: 23

Date Collected: 09/14/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	11851	Flush	Bubbler	Room 1	5	09/18/2018	6:40 AM
2.	11852	Flush	Tap	Room 1	2	09/18/2018	
3.	11853	Flush	Bubbler	Room 2	51	09/18/2018	
4.	11854	Flush	Bubbler	Room 3	6	09/18/2018	
5.	11855	Flush	Bubbler	Room 5	3	09/18/2018	
6.	11856	Flush	Tap	Room 5	3	09/18/2018	
7.	11857	Flush	Tap	Room 7	3	09/18/2018	
8.	11858	Flush	Bubbler	Room 8	3	09/18/2018	
9.	11859	Flush	Bubbler	Room 131	5	09/18/2018	
10.	11860	Flush	Tap	Room 9	4	09/18/2018	
11.	14501	Flush	Tap	Room 10	2	09/18/2018	
12.	14502	Flush	Tap	Room 12	3	09/18/2018	
13.	14503	Flush	Tap	Room 13	3	09/18/2018	
14.	14504	Flush	Bubbler	Room 15	7	09/18/2018	
15.	14505	Flush	Tap	Room 15	2	09/18/2018	
16.	14506	Flush	Tap	Room 16	3	09/18/2018	
17.	14507	Flush	Bubbler	Room 17	2	09/18/2018	
18.	14508	Flush	Bubbler	Room 18	2	09/18/2018	
19.	14509	Flush	Bubbler	Room 19	4	09/18/2018	
20.	14510	Flush	Tap	Room 19	3	09/18/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
21.	14511	Flush	Tap	Room 20	2	09/18/2018	
22.	14512	Flush	Tap	Room 21	3	09/18/2018	
23.	14513			Room 21	<1	09/18/2018	03480