



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Oak Harbor District**

**School Name: Clover Valley Elementary**

**School Code: N/A**

**Address: 600 Cherokee Street**

**County: Island**

**Number of Samples Collected: 45**

**Date Collected: 3/20/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	4999	First Draw	Sprayer	Kitchen	4	04/03/2018	
Sample 2	5197	First Draw	Tap	Main Sink in Kitchen	3	04/03/2018	
Sample 3	5198	First Draw	Drinking Fountain	Gym	<1	04/03/2018	
Sample 4	5199	First Draw	Tap	Health Room	7	8/6/2018	
Sample 5	5200	First Draw	Water Cooler	Health Room	<1	04/03/2018	
Sample 6	5201	First Draw	Lower Left Drinking Fountain	Entryway	<1	04/03/2018	
Sample 7	5202	First Draw	Upper Right Drinking Fountain	Entryway	<1	04/03/2018	
Sample 8	5203	First Draw	Tap	Room 112	3	04/03/2018	
Sample 9	5204	First Draw	Bubbler	Room 112	1	04/03/2018	
Sample 10	5205	First Draw	Tap	Room 113	5	04/03/2018	
Sample 11	5206	First Draw	Bubbler	Room 113	2	04/03/2018	
Sample 12	5207	First Draw	Drinking Fountain	Main Hallway	<1	04/03/2018	
Sample 13	5208	First Draw	Tap	Room 114	1	04/03/2018	
Sample 14	5209	First Draw	Bubbler	Room 114	<1	04/03/2018	
Sample 15	5210	First Draw	Tap	Room 115	3	8/6/2018	
Sample 16	5211	First Draw	Bubbler	Room 115	<1	8/6/2018	
Sample 17	5212	First Draw	Tap	Room 116	1	04/03/2018	
Sample 18	5213	First Draw	Bubbler	Room 116	1	04/03/2018	
Sample 19	5214	First Draw	Tap	Room 117	4	04/03/2018	
Sample 20	5215	First Draw	Bubbler	Room 117	1	04/03/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	5216	First Draw	Tap	Room 121	2	04/03/2018	
Sample 22	5217	First Draw	Bubbler	Near Room 121	<1	04/03/2018	
Sample 23	5218	First Draw	Tap	Near Room 121	<1	04/03/2018	
Sample 24	5219	First Draw	Water Cooler	Room 123	<1	8/6/2018	
Sample 25	5220	First Draw	Water Cooler	Room 129	1	04/03/2018	
Sample 26	5221	First Draw	Tap	Room 129	<1	8/6/2018	
Sample 27	5222	First Draw	Tap	Room 130	2	04/03/2018	
Sample 28	5223	First Draw	Bubbler	Room 130	4	8/6/2018	
Sample 29	5224	First Draw	Tap	Room 131	3	04/03/2018	
Sample 30	5225	First Draw	Bubbler	Room 131	2	04/03/2018	
Sample 31	5226	First Draw	Tap	Room 135	<1	04/03/2018	
Sample 32	5227	First Draw	Bubbler	Room 135	6	04/03/2018	
Sample 33	5228	First Draw	Tap	Room 136	6	04/03/2018	
Sample 34	5229	First Draw	Bubbler	Room 136	4	04/03/2018	
Sample 35	5230	First Draw	Tap	Room 137	2	04/03/2018	
Sample 36	5231	First Draw	Bubbler	Room 137	1	04/03/2018	
Sample 37	5232	First Draw	Tap	Room 141	5	04/03/2018	
Sample 38	5233	First Draw	Tap	Room 142	10	04/03/2018	
Sample 39	5234	First Draw	Tap	Room 143	6	8/6/2018	
Sample 40	5235	First Draw	Bubbler	Room 143	4	8/6/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 41	5236	First Draw	Drinking Fountain	Near Room 143	1	04/03/2018	
Sample 42	5237	First Draw	Tap	Room 147	3	04/03/2018	
Sample 43	5238	First Draw	Bubbler	Room 147	2	04/03/2018	
Sample 44	5239	First Draw	Blank	Room 147	<1	04/03/2018	
Sample 45	5240	First Draw	Tap	Room 154	34	8/6/2018	