



### **Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**School District Name: Wenatchee School District**

**School Name: Castle Rock Early Childhood Learning Center**

**School Code: 3269**

**Address: 112 South Elliot Wenatchee WA 98801**

**Number of Samples Collected: 27**

**Date Collected: 4/19/2018**

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	6744	Bubbler	First Draw	Room 403	1	5/4/2018	
Sample 2	6745	Tap	First Draw	Health Room	6	5/4/2018	
Sample 3	6746	Tap	First Draw	Room 403	<1	5/4/2018	
Sample 4	6747	Tap	First Draw	Room 403	<1	5/4/2018	
Sample 5	6748	Bubbler	First Draw	Room 402	3	5/4/2018	
Sample 6	6749	Tap	First Draw	Room 402	<1	5/4/2018	
Sample 7	6750	Tap	First Draw	Room 402	<1	5/4/2018	
Sample 8	6751	water bottle station	First Draw	Outside Bathroom 203	<1	5/4/2018	
Sample 9	6752	Bubbler	First Draw	Outside Bathroom 203	<1	5/4/2018	
Sample 10	6753	Bubbler	First Draw	Outside Bathroom 203	<1	5/4/2018	
Sample 11	6754	Bubbler	First Draw	Room 404	<1	5/4/2018	
Sample 12	6755	Tap	First Draw	Room 404	<1	5/4/2018	
Sample 13	6756	Tap	First Draw	Room 404	<1	5/4/2018	
Sample 14	6757	Tap	First Draw	Room 405	1	5/4/2018	
Sample 15	6758	Bubbler	First Draw	Room 405	2	5/4/2018	
Sample 16	6759	Tap	First Draw	Room 405	<1	5/4/2018	
Sample 17	6760	Bubbler	First Draw	Room 406	1	5/4/2018	
Sample 18	6761	Tap	First Draw	Room 406	<1	5/4/2018	
Sample 19	6762	Tap	First Draw	Room 406	1	5/4/2018	
Sample 20	6763	Tap	First Draw	Room 407	1	5/4/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	6764	Bubbler	First Draw	Room 407	<1	5/4/2018	
Sample 22	6765	Tap	First Draw	Room 407	<1	5/4/2018	
Sample 23	6766	Bubbler	First Draw	Room 409	1	5/4/2018	
Sample 24	6767	Tap	First Draw	Room 409	<1	5/4/2018	
Sample 25	6768	Tap	First Draw	Room 409	TB	TB	
Sample 26	6769	Tap	First Draw	Room 410	<1	5/4/2018	
Sample 27	6770	Bubbler	First Draw	Room 410	2	5/4/2018	
Sample 28	6771	BLANK		BLANK	TB	TB	

TB= Turbidity, further analysis required.