



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Blaine Elementary

School Code: 2713

School District Name: Blaine

Address: 836 Mitchell Ave, Blaine WA 98230

County: Whatcom

Number of Samples Collected: 11

Date Collected: 11/01/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	15464	First Draw	Tap	Room 431	2	12/19/2018	8:00 AM, Retest after fixture replacement
2.	15479	First Draw	Tap	Room 432	8	11/09/2018	
3.	15480	First Draw	Tap	Room 433	17	11/09/2018	
4.	15481	First Draw	Tap	Room 416	2	11/09/2018	
5.	16525	First Draw	Tap	Room 419	<1	11/09/2018	Used by staff this morning
6.	16526	First Draw	Tap	Room 420	<1	11/09/2018	
7.	16527	First Draw	Tap	Room 418	<1	11/09/2018	Used by staff this morning
8.	16528	First Draw	Tap	Room 423 1/2	<1	11/09/2018	
9.	16529	First Draw	Tap	Room 412	2	11/09/2018	
10.	16530	First Draw	Tap	Room 413	11	11/09/2018	
11.	16531	Blank	Blank		<1	11/09/2018	06263