



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: Bremerton School District

School Name: Crownhill Elementary School

School Code: 3108

Address: 1500 Rocky Point Rd NW Bremerton WA 98312

Number of Samples Collected: 60

Date Collected: 2/27/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	2069	First Draw	Tap	Kitchen	1	3/21/2018	Only tap used for cooking
Sample 2	2070	First Draw	Bubbler	Next to Kitchen	<1	3/21/2018	
Sample 3	2071	First Draw	Bottle Filler	Next to Kitchen	1	3/21/2018	
Sample 4	2072	First Draw	Tap	Cafeteria	1	3/21/2018	
Sample 5	2073	First Draw	Bubbler	Music Room	1	3/21/2018	
Sample 6	2074	First Draw	Tap	Music Room	25	3/21/2018	
Sample 7	2075	First Draw	Tap	Nurse	<1	3/21/2018	
Sample 8	2076	First Draw	Bubbler	Rm. 101	1	3/21/2018	
Sample 9	2077	First Draw	Tap	Rm. 101	23	3/21/2018	
Sample 10	2078	First Draw	Bubbler	Rm. 102	2	3/21/2018	
Sample 11	2079	First Draw	Tap	Rm. 102	25	3/21/2018	
Sample 12	2080	First Draw	Bubbler	Rm. 103	2	3/21/2018	
Sample 13	2081	First Draw	Tap	Rm. 103	16	3/21/2018	
Sample 14	2082	First Draw	Bubbler	Rm. 104	19	3/21/2018	
Sample 15	2083	First Draw	Tap	Rm. 104	17	3/21/2018	
Sample 16	2084	First Draw	Bubbler	Rm. 105	4	3/21/2018	
Sample 17	2085	First Draw	Tap	Rm. 105	29	3/21/2018	
Sample 18	2086	First Draw	Bubbler	Rm. 106	2	3/21/2018	
Sample 19	2087	First Draw	Tap	Rm. 106	32	3/21/2018	
Sample 20	2088	First Draw	Bubbler	Library	5	3/21/2018	Very Low Function

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 21	2089	First Draw	Bubbler	Rm. 107	2	3/21/2018	
Sample 22	2090	First Draw	Tap	Rm. 107	19	3/22/2018	
Sample 23	2091	First Draw	Bubbler	Rm. 108	2	3/22/2018	
Sample 24	2092	First Draw	Tap	Rm. 108	30	3/22/2018	
Sample 25	2093	First Draw	Bubbler	Rm. 109	5	3/22/2018	
Sample 26	2094	First Draw	Tap	Rm. 109	24	3/22/2018	
Sample 27	2095	First Draw	Bubbler	Speech	13	3/22/2018	Low Function
Sample 28	2096	First Draw	Tap	Speech	10	3/22/2018	
Sample 29	2097	First Draw	Bubbler	Rm. 110	7	3/22/2018	Low function
Sample 30	2098	First Draw	Tap	Rm. 110	20	3/22/2018	
Sample 31	2099	First Draw	Bubbler	Rm. 111	4	3/22/2018	
Sample 32	2100	First Draw	Tap	Rm. 111	10	3/22/2018	
Sample 33	2101	First Draw	Bubbler	Rm. 200	7	3/22/2018	
Sample 34	2102	First Draw	Tap	Rm. 200	47	3/22/2018	
Sample 35	2103	First Draw	Bubbler	Rm. 201	47	3/22/2018	
Sample 36	2104	First Draw	Tap	Rm. 201	8	3/22/2018	
Sample 37	2105	First Draw	Bubbler	Rm. 202	6	3/22/2018	
Sample 38	2106	First Draw	Tap	Rm. 202	28	3/22/2018	
Sample 39	2107	First Draw	Water Cooler	Rm. 202	<1	3/22/2018	
Sample 40	2108	First Draw	Bubbler	Rm. 203	3	3/22/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 41	2109	First Draw	Tap	Rm. 203	26	3/22/2018	
Sample 42	2110	First Draw	Bubbler	2nd Floor	<1	3/22/2018	Next to elevator, Lower Left
Sample 43	2111	First Draw	Bubbler	2nd Floor	117	3/22/2018	Next to elevator, Upper Right
Sample 44	2112	First Draw	Bubbler	Rm. 204	3	3/22/2018	
Sample 45	2113	First Draw	Tap	Rm. 204	22	3/22/2018	
Sample 46	2114	First Draw	Bubbler	Rm. 205	2	3/22/2018	
Sample 47	2115	First Draw	Tap	Rm. 205	20	3/22/2018	
Sample 48	2116	First Draw	Bubbler	Rm. 206	1	3/22/2018	
Sample 49	2117	First Draw	Tap	Rm. 206	22	3/22/2018	
Sample 50	2118	First Draw	Bubbler	Rm. 207	1	3/22/2018	
Sample 51	2119	First Draw	Tap	Rm. 207	18	3/22/2018	
Sample 52	2120	First Draw	Bubbler	Rm. 208	1	3/22/2018	
Sample 53	2121	First Draw	Tap	Rm. 208	35	3/22/2018	
Sample 54	2122	First Draw	Bubbler	Rm. 209	<1	3/22/2018	
Sample 55	2123	First Draw	Tap	Rm. 209	30	3/22/2018	
Sample 56	2125	First Draw	Bubbler	Rm. 210	3	3/22/2018	
Sample 57	2126	First Draw	Tap	Rm. 210	12	3/22/2018	
Sample 58	2127	Other	Tap	Portable 2	<1	3/22/2018	Tap had been used
Sample 59	2128	First Draw	Bubbler	Portable 4	<1	3/22/2018	
Sample 60	2129	First Draw	Bubbler	Portable 3	<1	3/22/2018	