



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School Name: Onalaska Elementary School

School Code: 3239

School District Name: Onalaska

Address: 540 Carlisle Ave, Onalaska WA 98570

County: Lewis

Number of Samples Collected: 41

Date Collected: 05/31/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	9855	Blank			<1	08/10/2018	
2.	9856	First Draw	Tap	Kitchen	1	08/10/2018	Single tap next to mixer
3.	9857	First Draw	Tap	Kitchen	<1	08/10/2018	Double tap left side
4.	9858	First Draw	Tap	Kitchen	2	08/10/2018	Double tap right side
5.	9859	First Draw	Bubbler	Cafeteria	<1	08/10/2018	Left
6.	9860	First Draw	Bubbler	Cafeteria	<1	08/10/2018	Right
7.	9861	First Draw	Bubbler	Rm 211	<1	08/10/2018	
8.	9862	First Draw	Tap	Rm 211	2	08/10/2018	
9.	9863	First Draw	Bubbler	Rm 201	<1	08/10/2018	
10.	9864	First Draw	Tap	Rm 201	2	08/10/2018	
11.	9865	First Draw	Bubbler	Rm 202	<1	08/10/2018	
12.	9866	First Draw	Tap	Rm 202	2	08/10/2018	
13.	9867	First Draw	Bubbler	Rm 212	<1	08/10/2018	
14.	9868	First Draw	Tap	Rm 212	1	08/10/2018	
15.	9869	First Draw	Bubbler	Rm 213	<1	08/10/2018	
16.	9870	First Draw	Tap	Rm 213	3	08/10/2018	
17.	9871	First Draw	Bubbler	Rm 221	<1	08/10/2018	
18.	9872	First Draw	Tap	Rm 221	3	08/10/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	9873	First Draw	Bubbler	Rm 222	<1	08/10/2018	
20.	9874	First Draw	Tap	Rm 222	3	08/10/2018	
21.	9875	First Draw	Bubbler	Rm 223	<1	08/10/2018	
22.	9876	First Draw	Tap	Rm 223	4	08/10/2018	
23.	9877	First Draw	Bubbler	Across from 248	<1	08/10/2018	Left
24.	9878	First Draw	Bubbler	Across from 248	<1	08/10/2018	Right
25.	9879	First Draw	Tap	Nurse	1	08/10/2018	In restroom across hall
26.	9880	First Draw	Bubbler	Rm 246	<1	08/10/2018	Left sink
27.	9881	First Draw	Tap	Rm 246	2	08/10/2018	Left sink
28.	9882	First Draw	Bubbler	Rm 246	<1	08/10/2018	Right sink
29.	9883	First Draw	Tap	Rm 246	2	08/10/2018	Right sink
30.	9884	First Draw	Bubbler	Rm 232	<1	08/10/2018	
31.	9885	First Draw	Tap	Rm 232	5	08/10/2018	
32.	9886	First Draw	Bubbler	Rm 231	<1	08/10/2018	
33.	9887	First Draw	Tap	Rm 231	2	08/10/2018	
34.	9888	First Draw	Bubbler	Rm 233	<1	08/10/2018	
35.	9889	First Draw	Tap	Rm 233	4	08/10/2018	
36.	9890	First Draw	Bubbler	Rm 241	<1	08/10/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
37.	9891	First Draw	Tap	Rm 241	3	08/10/2018	
38.	9892	First Draw	Bubbler	Rm 242	<1	08/10/2018	
39.	9893	First Draw	Tap	Rm 242	4	08/10/2018	
40.	9894	First Draw	Bubbler	Rm 242	<1	08/10/2018	
41.	9895	First Draw	Tap	Rm 242	5	08/10/2018	