



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school has participated in follow up testing and recommended remediation to help reduce children's exposure to lead in drinking water.

School Name: North Star Elementary School

School Code: 4538

School District Name: Bethel

Address: 7719 224th St E, Graham WA 98338

County: Pierce

Number of Samples Collected: 50

Date Collected: 06/13/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	10074	Blank			<1	8/22/2018	
2.	10081	First Draw	Tap	Kitchen	3	8/20/2018	Triple sink left tap
3.	10082	First Draw	Tap	Kitchen	5	08/22/2018	Triple sink right tap
4.	10083	First Draw	Bubbler	Outside kitchen	<1	08/22/2018	Left
5.	10084	First Draw	Bubbler	Outside kitchen	<1	08/22/2018	Right
6.	10085	First Draw	Bubbler	Rm 9	3	08/22/2018	
7.	10086	First Draw	Tap	Rm 9	5	08/22/2018	
8.	10087	First Draw	Bubbler	Rm 8	1	08/22/2018	
9.	10088	First Draw	Tap	Rm 8	2	08/22/2018	
10.	10089	First Draw	Bubbler	Rm 24	3	08/22/2018	
11.	10090	First Draw	Tap	Rm 24	4	08/22/2018	
12.	10091	First Draw	Bubbler	Rm 7	4	08/22/2018	
13.	10092	First Draw	Tap	Rm 7	2	08/22/2018	
14.	10093	First Draw	Bubbler	Rm 6	1	08/22/2018	
15.	10094	First Draw	Tap	Rm 6	3	08/22/2018	
16.	10095	First Draw	Bubbler	Rm 5	2	08/22/2018	
17.	10096	First Draw	Tap	Rm 5	1	08/22/2018	
18.	10097	First Draw	Bubbler	Rm 4	1	08/22/2018	
19.	10098	First Draw	Tap	Rm 4	2	08/22/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
20.	10099	First Draw	Bubbler	Rm 3	5	08/22/2018	
21.	10100	First Draw	Tap	Rm 3	3	08/22/2018	
22.	10981	First Draw	Bubbler	Rm 2	3	08/22/2018	
23.	10982	First Draw	Tap	Rm 2	1	08/22/2018	
24.	10983	First Draw	Bubbler	Rm 1	2	08/22/2018	
25.	10984	First Draw	Tap	Rm 1	1	08/22/2018	
26.	10985	First Draw	Bubbler	Rm 10	2	08/22/2018	
27.	10986	First Draw	Tap	Rm 10	1	08/22/2018	
28.	10987	First Draw	Bubbler	Rm 11	2	08/22/2018	
29.	10988	First Draw	Tap	Rm 11	2	08/22/2018	
30.	10989	First Draw	Bubbler	Rm 12	2	08/22/2018	
31.	10990	First Draw	Tap	Rm 12	5	08/22/2018	
32.	10991	First Draw	Bubbler	Rm 13	2	08/22/2018	
33.	10992	First Draw	Tap	Rm 13	3	08/22/2018	
34.	10993	First Draw	Bubbler	Rm 14	2	08/22/2018	
35.	10994	First Draw	Tap	Rm 14	2	08/22/2018	
36.	10995	First Draw	Bubbler	Rm 16	2	08/22/2018	
37.	10996	First Draw	Tap	Rm 16	1	08/22/2018	
38.	10997	First Draw	Bubbler	LAP Room	15	08/22/2018	
39.	10998	First Draw	Tap	LAP Room	14	08/22/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
40.	10999	First Draw	Bubbler	Rm 17	2	08/22/2018	
41.	11000	First Draw	Tap	Rm 17	3	08/22/2018	
42.	11001	First Draw	Bubbler	Rm 18	3	08/22/2018	
43.	11002	First Draw	Tap	Rm 18	1	08/23/2018	
44.	11003	First Draw	Bubbler	Rm 19	1	08/23/2018	
45.	11004	First Draw	Tap	Rm 19	1	08/23/2018	
46.	11005	First Draw	Bubbler	Rm 20	<1	08/23/2018	
47.	11006	First Draw	Tap	Rm 20	2	08/23/2018	
48.	11007	First Draw	Bubbler	Rm 21	1	08/23/2018	
49.	11008	First Draw	Tap	Rm 21	2	08/23/2018	
50.	11009	First Draw	Tap	Nurse	1	08/23/2018	