



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following all recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Renton

**School Name:** Cascade Elementary School

**School Code:** 3337

**School Address:** 16022 116th Ave SE, Renton Washington 98058

**Number of Samples Collected:** 60

**Date Collected:** 04/19/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
21704	other			<1	05/07/2019	
21705	FirstDraw	Bubbler	Outside of cafeteria	<1	05/07/2019	Left
21706	FirstDraw	Bubbler	Outside of cafeteria	<1	05/07/2019	Right
21707	FirstDraw	Tap	Speech	20	05/07/2019	
21708	FirstDraw	Tap	Rm 312	1	05/07/2019	
21709	FirstDraw	Bubbler	Rm 313	4	05/07/2019	
21710	FirstDraw	Tap	Rm 313	7	05/07/2019	
21711	FirstDraw	Bubbler	Rm 311	<1	05/07/2019	
21712	FirstDraw	Tap	Rm 311	15	05/07/2019	
21713	FirstDraw	Bubbler	Rm 308	1	05/07/2019	
21714	FirstDraw	Tap	Rm 308	27	05/07/2019	
21715	FirstDraw	Tap	Kitchen	10	05/07/2019	
21716	FirstDraw	Bubbler	Rm 306	1	05/07/2019	
21717	FirstDraw	Tap	Rm 306	43	05/07/2019	
21718	FirstDraw	Bubbler	Rm 309	1	05/07/2019	
21719	FirstDraw	Tap	Rm 309	7	05/07/2019	
21720	FirstDraw	Bubbler	Rm 307	<1	05/07/2019	
21721	FirstDraw	Tap	Rm 307	29	05/07/2019	
21722	FirstDraw	Bubbler	Rm 414	4	05/07/2019	
21723	FirstDraw	Tap	Rm 414	26	05/07/2019	
21724	FirstDraw	Bubbler	Rm 412	2	05/07/2019	
21725	FirstDraw	Tap	Rm 412	20	05/07/2019	
21726	FirstDraw	Bubbler	Rm 415	<1	05/07/2019	
21727	FirstDraw	Tap	Rm 415	20	05/07/2019	
21728	FirstDraw	Bubbler	Rm 413	1	05/07/2019	
21729	FirstDraw	Tap	Rm 413	33	05/07/2019	
21730	FirstDraw	Bubbler	Rm 410	2	05/07/2019	
21731	FirstDraw	Tap	Rm 410	19	05/07/2019	
21732	FirstDraw	Bubbler	Rm 408	1	05/07/2019	
21733	FirstDraw	Tap	Rm 408	23	05/07/2019	
21734	FirstDraw	Bubbler	Rm 411	1	05/07/2019	
21735	FirstDraw	Tap	Rm 411	18	05/07/2019	
21736	FirstDraw	Bubbler	Rm 409	1	05/07/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
21737	FirstDraw	Tap	Rm 409	3	05/07/2019	
21738	FirstDraw	Bubbler	Rm 514	<1	05/07/2019	
21739	FirstDraw	Tap	Rm 514	27	05/07/2019	
21740	FirstDraw	Bubbler	Rm 512	2	05/07/2019	
21741	FirstDraw	Tap	Rm 512	9	05/07/2019	
21742	FirstDraw	Bubbler	Rm 513	3	05/07/2019	Low sink
21743	FirstDraw	Tap	Rm 513	45	05/07/2019	Low sink
21744	FirstDraw	Tap	Rm 513	49	05/07/2019	High sink
21745	FirstDraw	Bubbler	Rm 510	1	05/07/2019	
21746	FirstDraw	Tap	Rm 510	28	05/07/2019	
21747	FirstDraw	Bubbler	Rm 511A	3	05/07/2019	
21748	FirstDraw	Tap	Rm 511A	13	05/07/2019	
21749	FirstDraw	Bubbler	Rm 508	1	05/07/2019	
21750	FirstDraw	Tap	Rm 508	25	05/07/2019	
21751	FirstDraw	Bubbler	Rm 506	2	05/07/2019	
21752	FirstDraw	Tap	Rm 506	26	05/07/2019	
21753	FirstDraw	Bubbler	Rm 509	1	05/07/2019	
21754	FirstDraw	Tap	Rm 509	28	05/07/2019	
21755	FirstDraw	Bubbler	Rm 507	<1	05/07/2019	
21756	FirstDraw	Tap	Rm 507	4	05/07/2019	
21757	FirstDraw	Bubbler	Next to Library	<1	05/07/2019	Left
21758	FirstDraw	Bubbler	Next to Library	<1	05/07/2019	Right
21759	FirstDraw	Tap	Library Office	28	05/07/2019	
21760	FirstDraw	Tap	Staff Lounge	2	05/07/2019	
21761	FirstDraw	Tap	Nurse	18	05/07/2019	
21762	FirstDraw	Bubbler	Music	10	05/07/2019	
21763	FirstDraw	Tap	Music	60	05/07/2019	