



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

**School District:** Pomeroy

**School Name:** Pomeroy Junior Senior High School

**School Code:** 2241

**School Address:** 1090 Pataha Street, Pomeroy Washington 99347

**Number of Samples Collected:** 17

**Date Collected:** 12/06/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29843	other	other	Blank	<1	12/12/2019	Blank
29844	FirstDraw	Tap	Kitchen	1	12/12/2019	Right sink note thought I thought I was testing spray nozzle but came out of tap. This sample is out of tap so sample not initial draw
29845	FirstDraw	other	Kitchen	11	12/12/2019	See notes 29844 not certain if sample size big enough. Sampled residual water in spray nozzle hose.
29846	FirstDraw	Tap	Kitchen	<1	12/12/2019	Left sink 2
29847	FirstDraw	Tap	Kitchen	1	12/12/2019	Sink 3
29848	FirstDraw		Hallway 13	<1	12/12/2019	Drinking fountain low
29849	FirstDraw	Bubbler	Hallway 13	<1	12/12/2019	Drinking fountain tall
29850	FirstDraw	Tap	Rm 406	23	12/12/2019	
29851	FirstDraw	Bubbler	Hallway across from office	<1	12/12/2019	Drinking fountain
29852	FirstDraw	Bubbler	Hallway across from office	<1	12/12/2019	Hydration station
29853	FirstDraw	BottleFiller	Hallway across from office	<1	12/12/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
29854	FirstDraw	Bubbler	Gym	<1	12/12/2019	Drinking fountain lower one
29855	FirstDraw	Bubbler	Gym	<1	12/12/2019	Drinking fountain tall
29856	FirstDraw	Bubbler	Wrestling Deck	<1	12/12/2019	Drinking fountain lower one
29857	FirstDraw	Bubbler	Wrestling deck	<1	12/12/2019	Drinking fountain tall
29858	FirstDraw	Bubbler	Ag Building	<1	12/12/2019	Drinking fountain
29859	FirstDraw	Bubbler	Industrial Arts Building hallway	<1	12/12/2019	