



Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road Southeast, Tumwater Washington 98501

## Lead Sample Collection Information

**DISCLAIMER:** Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

The school district is following all recommended remediation to help reduce children's overall exposure to lead in drinking water.

**School District:** Highline

**School Name:** Cedarhurst Elementary

**School Code:** 2926

**School Address:** 611 South 132nd St, Burien Washington 98168

**Number of Samples Collected:** 81

**Date Collected:** 12/12/2018

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
17500	other	other		<1	01/07/2019	02620, 6:25 AM
18121	FirstDraw	Tap	Room 1250	2	01/07/2019	
18122	FirstDraw	Bubbler	Room 1270	7	01/07/2019	Low flow, water collected under bubbler
18123	FirstDraw	Tap	Room 1270	10	01/07/2019	
18124	FirstDraw	Bubbler	Room 1280	2	01/07/2019	
18125	FirstDraw	Tap	Room 1280	2	01/07/2019	
18126	FirstDraw	Tap	Room 1410	13	02/16/2019	
18127	FirstDraw	Tap	Room 1203	10	01/07/2019	
18128	FirstDraw	other	Kitchen	1	01/07/2019	Food Prep in Back of Kitchen
18129	FirstDraw	Bubbler	Outside 1530	<1	01/07/2019	Left Side Fountain
18130	FirstDraw	Bubbler	Outside 1530	<1	01/07/2019	Right Side Fountain
18131	FirstDraw	Bubbler	Outside 1301 (outside bathroom)	<1	01/07/2019	Left Side Fountain
18132	FirstDraw	Bubbler	Outside 1301 (outside bathroom)	<1	01/07/2019	Right Side Fountain
18133	FirstDraw	Bubbler	Room 1310	2	01/07/2019	
18134	FirstDraw	Tap	Room 1310	4	01/07/2019	
18135	FirstDraw	Bubbler	Room 1320	2	01/07/2019	
18136	FirstDraw	Tap	Room 1320	3	01/07/2019	
18137	FirstDraw	Bubbler	Room 1340	12	01/07/2019	
18138	FirstDraw	Tap	Room 1340	9	01/07/2019	
18139	FirstDraw	Tap	Room 1350	1	01/07/2019	
18140	FirstDraw	Tap	1300 Pod	12	01/07/2019	
18141	FirstDraw	Bubbler	Room 1360	1	01/07/2019	
18142	FirstDraw	Tap	Room 1360	2	01/07/2019	
18143	FirstDraw	Tap	Room 1353	<1	01/07/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
18144	FirstDraw	Tap	Room 1370	59	01/07/2019	
18145	FirstDraw	Bubbler	Room 1380	<1	01/07/2019	Faucet non-functioning
18147	FirstDraw	Bubbler	Room 1390	<1	01/07/2019	
18148	FirstDraw	Tap	Room 1390	3	01/07/2019	
18149	FirstDraw	Tap	Room 2030	<1	01/07/2019	
18150	FirstDraw	Tap	Library	3	01/07/2019	
18151	FirstDraw	Bubbler	Outside 2202 (outside bathroom)	<1	01/07/2019	Left Side Fountain
18152	FirstDraw	Bubbler	Outside 2202 (outside bathroom)	<1	01/07/2019	Right Side Fountain
18153	FirstDraw	Bubbler	Room 2210	2	01/07/2019	
18154	FirstDraw	Tap	Room 2210	2	01/07/2019	
18155	FirstDraw	Bubbler	Room 2220	2	01/07/2019	
18156	FirstDraw	Tap	Room 2220	3	01/07/2019	
18157	FirstDraw	Tap	Room 2230	23	01/07/2019	
18158	FirstDraw	Bubbler	Room 2240	2	01/07/2019	
18159	FirstDraw	Tap	Room 2240	5	01/07/2019	
18160	FirstDraw	Bubbler	Room 2250	1	01/07/2019	
18161	FirstDraw	Tap	Room 2250	4	01/07/2019	
18162	FirstDraw	Bubbler	Room 2260	1	01/07/2019	
18163	FirstDraw	Tap	Room 2260	3	01/07/2019	
18164	FirstDraw	Bubbler	Room 2270	2	01/07/2019	
18165	FirstDraw	Tap	Room 2270	3	01/07/2019	
18166	FirstDraw	Tap	2200 Pod	6	01/07/2019	
18167	FirstDraw	Bubbler	Room 2280	1	01/07/2019	
18168	FirstDraw	Tap	Room 2280	5	01/07/2019	
18169	FirstDraw	Bubbler	Outside 2302 (outside bathroom)	<1	01/07/2019	Right Side (left side not working)

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
18170	FirstDraw	Bubbler	Room 2310	2	01/07/2019	
18202	FirstDraw	Tap	Community Room	<1	01/07/2019	
18203	FirstDraw	Tap	Music Room	10	01/07/2019	Across from Community Room
18204	FirstDraw	Tap	Nurseâ s Room	2	01/07/2019	
18205	FirstDraw	Tap	Workroom	9	01/07/2019	
18206	FirstDraw	Tap	Room 1020	7	01/07/2019	
18207	FirstDraw	Tap	Room 1160	<1	01/07/2019	
18208	FirstDraw	Bubbler	Outside 1202	<1	01/07/2019	Left Side Fountain
18209	FirstDraw	Bubbler	Outside 1202	<1	01/07/2019	Right Side Fountain
18210	FirstDraw	Bubbler	Room 1210	2	01/07/2019	
18211	FirstDraw	Tap	Room 1210	3	01/08/2019	
18212	FirstDraw	Bubbler	Room 1220	2	01/08/2019	
18213	FirstDraw	Tap	Room 1220	3	01/08/2019	
18214	FirstDraw	Bubbler	Room 1230	2	01/08/2019	
18215	FirstDraw	Tap	Room 1230	2	01/08/2019	
18216	FirstDraw	Tap	1200 Pod	2	01/08/2019	
18217	FirstDraw	Bubbler	Room 1250	5	01/08/2019	
18218	FirstDraw	Tap	Room 2310	4	01/08/2019	
18219	FirstDraw	Bubbler	Room 2320	3	01/08/2019	
18220	FirstDraw	Tap	Room 2320	2	01/08/2019	
18221	FirstDraw	Bubbler	Room 2330	3	01/08/2019	
18222	FirstDraw	Tap	Room 2330	2	01/08/2019	
18223	FirstDraw	Bubbler	Room 2340	2	01/08/2019	
18224	FirstDraw	Tap	Room 2340	1	01/08/2019	
18225	FirstDraw	Bubbler	Room 2350	1	01/08/2019	
18226	FirstDraw	Tap	Room 2350	1	01/08/2019	
18227	FirstDraw	Tap	Room 2360	9	01/08/2019	
18228	FirstDraw	Tap	2300 Pod	5	01/08/2019	
18229	FirstDraw	Bubbler	Room 2370	1	01/08/2019	

*(continued)*

<b>Program ID</b>	<b>Sample Type</b>	<b>Description</b>	<b>Location</b>	<b>Lead Results (ppb)</b>	<b>Analysis Date</b>	<b>Comments</b>
18230	FirstDraw	Tap	Room 2370	2	01/08/2019	
18231	FirstDraw	Bubbler	Room 2380	2	01/08/2019	
18232	FirstDraw	Tap	Room 2380	5	01/08/2019	