



**Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road SE, Tumwater WA 98501**

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please note: The school has implemented flushing program to help reduce overall children's exposure to lead in drinking water.

School Name: Showalter Middle School

School Code: 2564

School District Name: Tukwila

Address: 4628 S 144th St, Tukwila WA 98168

County: King

Number of Samples Collected: 61

Date Collected: 10/25/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	15223	First Draw	Tap	Kitchen	<1	11/13/2018	Main Food Prep Sink, 6:10 AM
2.	15224	First Draw	Tap	Kitchen	2	11/13/2018	Occasional use for food
3.	15225	First Draw	Pot Filler	Kitchen	6	11/13/2018	Left Pot Filler
4.	15226	First Draw	Pot Filler	Kitchen	8	11/13/2018	Right Pot Filler
5.	15289	First Draw	Tap	Health Office	1	11/13/2018	
6.	15290	First Draw	Bubbler	Near Room A134	3	11/13/2018	Left Side, Right Side not Flowing well
7.	15291	First Draw	Bubbler	Across from Room A175	2	11/13/2018	Left Side
8.	15292	First Draw	Bubbler	Across from Room A175	1	11/13/2018	Right Side
9.	15293	First Draw	Bubbler	Room A170	<1	11/13/2018	
10.	15294	First Draw	Tap	Room A170	3	11/13/2018	No Aerator
11.	15295	First Draw	Bubbler	Room A173	<1	11/13/2018	
12.	15296	First Draw	Tap	Room A173	5	11/13/2018	
13.	15297	First Draw	Bubbler	Room A174	<1	11/13/2018	
14.	15298	First Draw	Tap	Room A174	1	11/13/2018	No Aerator
15.	15301	First Draw	Bubbler	Room A175	<1	11/13/2018	
16.	15302	First Draw	Tap	Room A175	1	11/13/2018	No Aerator

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
17.	15303	First Draw	Bubbler	Room A176	<1	11/13/2018	
18.	15304	First Draw	Tap	Room A176	3	11/13/2018	No Aerator
19.	15305	First Draw	Bubbler	Room A125	<1	11/13/2018	
20.	15306	First Draw	Tap	Room A125	4	11/13/2018	
21.	15307	First Draw	Tap	Room A126	<1	11/13/2018	
22.	15308	First Draw	Bubbler	Across from Room B106	1	11/13/2018	Left Side
23.	15309	First Draw	Bubbler	Across from Room B106	<1	11/13/2018	Right Side
24.	15310	First Draw	Tap	Room B108	7	11/13/2018	
25.	15311	First Draw	Tap	Room B111	8	11/13/2018	Left Sink, no Aerator
26.	15312	First Draw	Tap	Room B111	11	11/13/2018	Middle Sink, No Aerator
27.	15313	First Draw	Tap	Room B111	9	11/13/2018	Right Side Sink
28.	15314	First Draw	Tap	Room B118	1	11/13/2018	
29.	15315	First Draw	Bubbler	Near Room A217	2	11/13/2018	Left Side
30.	15316	First Draw	Bubbler	Near Room A217	1	11/13/2018	Right Side
31.	15317	First Draw	Bubbler	Room A223	<1	11/13/2018	Left Side Sink
32.	15318	First Draw	Tap	Room A223	4	11/13/2018	Left Side Sink

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
33.	15319	First Draw	Bubbler	Room A223	<1	11/13/2018	Right Side Sink
34.	15320	First Draw	Tap	Room A223	6	11/13/2018	Right Side Sink, no Aerator
35.	15321	First Draw	Bubbler	Room A226	<1	11/13/2018	
36.	15322	First Draw	Tap	Room A226	2	11/13/2018	No Aerator
37.	15323	First Draw	Bubbler	Room A227	<1	11/13/2018	
38.	15324	First Draw	Tap	Room A227	3	11/13/2018	No Aerator
39.	15325	First Draw	Bubbler	Room A228	<1	11/13/2018	
40.	15326	First Draw	Tap	Room A228	3	11/13/2018	Bubbler or Tap
41.	15327	First Draw	Bubbler	Room A229	2	11/13/2018	Bubbler or tap
42.	15328	First Draw	Tap	Room A229	<1	11/13/2018	
43.	15329	First Draw	Bubbler	Room A204	<1	11/13/2018	
44.	15330	First Draw	Tap	Room A204	3	11/13/2018	No Aerator
45.	15331	First Draw	Bubbler	Room A205	<1	11/13/2018	
46.	15332	First Draw	Tap	Room A205	2	11/13/2018	No Aerator
47.	15333	First Draw	Bubbler	Room A206	<1	11/13/2018	
48.	15334	First Draw	Tap	Room A206	3	11/13/2018	No Aerator
49.	15335	First Draw	Bubbler	Room A208	<1	11/13/2018	
50.	15336	First Draw	Tap	Room A208	1	11/13/2018	
51.	15337	First Draw	Bubbler	Room A213	<1	11/13/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
52.	15338	First Draw	Tap	Room A213	4	11/13/2018	
53.	15339	First Draw	Bubbler	Room A212	<1	11/13/2018	
54.	15340	First Draw	Tap	Room A212	4	11/13/2018	Filter on tap
55.	15341	First Draw	Bubbler	Room A211	<1	11/13/2018	
56.	15342	First Draw	Tap	Room A211	2	11/13/2018	
57.	15343	First Draw	Bubbler	Room A209	<1	11/13/2018	
58.	15344	First Draw	Tap	Room A209	2	11/13/2018	
59.	15345	First Draw	Bubbler	Gym	<1	11/13/2018	
60.	15346	First Draw	Bottle Filler	Gym	<1	11/13/2018	
61.	15347				<1	11/13/2018	06286