



Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

School District Name: East Valley School District

School Name: Trent Elementary School

School Code: 2653

Address: 3303 N. Pines Rd Spokane WA 99206

Number of Samples Collected: 81

Date Collected: 5/18/2018

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 1	8112	First Draw	BLANK	BLANK	<1	08/06/2018	
Sample 2	8113	First Draw	Tap	Kitchen	4	08/06/2018	Middle Island Near Cooler
Sample 3	8114	First Draw	Tap	Kitchen	1	08/06/2018	Personal Handwashing Sink Next to the Freezer
Sample 4	8115	First Draw	Tap	Kitchen	1	08/06/2018	Back Area Sink Near Dishwasher. Left Tap
Sample 5	8116	First Draw	Tap	Kitchen	2	08/06/2018	Back Area Sink Near Dishwasher. Right Tap
Sample 6	8117	First Draw	Tap	Cafeteria	1	08/06/2018	Sink Left of the Stove
Sample 7	8118	First Draw	Tap	Cafeteria	<1	08/06/2018	Sinks Right of the Stove. Left Sink
Sample 8	8119	First Draw	Tap	Cafeteria	1	08/06/2018	Sinks Right of the Stove. Right Sink
Sample 9	8120	First Draw	Bubbler	Gym	1	08/06/2018	
Sample 10	8121	First Draw	Bottle Filler	Near room 102	<1	08/06/2018	
Sample 11	8122	First Draw	Bubbler	Near room 102	<1	08/06/2018	
Sample 12	8123	First Draw	Tap	Clinic	<1	08/06/2018	
Sample 13	8124	First Draw	Bubbler	Room 406	<1	08/06/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 14	8125	First Draw	Tap	Room 406	TB	08/06/2018	
Sample 15	8126	First Draw	Tap	Stage	1	08/06/2018	
Sample 16	8127	First Draw	Bubbler	Near Room 407	<1	08/06/2018	Left Bubbler
Sample 17	8128	First Draw	Bubbler	Near Room 407	<1	08/06/2018	Right Bubbler
Sample 18	8129	First Draw	Tap	Room 407	<1	08/06/2018	
Sample 19	8130	First Draw	Bubbler	Room 407	<1	08/06/2018	
Sample 20	8131	First Draw	Tap	Room 404	1	08/06/2018	
Sample 21	8132	First Draw	Bubbler	Room 404	<1	08/06/2018	
Sample 22	8133	First Draw	Tap	Room 402	1	08/06/2018	
Sample 23	8134	First Draw	Bubbler	Room 402	<1	08/06/2018	
Sample 24	8135	First Draw	Tap	Room 401	<1	08/06/2018	
Sample 25	8136	First Draw	Bubbler	Room 401	<1	08/06/2018	
Sample 26	8137	First Draw	Tap	Room 305	<1	08/06/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 27	8138	First Draw	Bubbler	Room 305	<1	08/06/2018	
Sample 28	8139	First Draw	Tap	Room 306	<1	08/06/2018	
Sample 29	8140	First Draw	Bubbler	Room 306	<1	08/06/2018	
Sample 30	8141	First Draw	Tap	Room 304	<1	08/06/2018	
Sample 31	8142	First Draw	Bubbler	Room 304	<1	08/06/2018	
Sample 32	8143	First Draw	Tap	Room 307	<1	08/06/2018	
Sample 33	8144	First Draw	Bubbler	Room 307	<1	08/06/2018	
Sample 34	8145	First Draw	Bubbler	Room 308	<1	08/06/2018	
Sample 35	8146	First Draw	Tap	Room 308	<1	08/06/2018	
Sample 36	8147	First Draw	Bubbler	Room 309	<1	08/06/2018	
Sample 37	8148	First Draw	Tap	Room 309	<1	08/06/2018	
Sample 38	8149	First Draw	Bubbler	Room 310	<1	08/06/2018	
Sample 39	8150	First Draw	Tap	Room 310	<1	08/06/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 40	8151	First Draw	Bubbler	Room 205	TB	08/06/2018	
Sample 41	8152	First Draw	Tap	Room 205	<1	08/06/2018	
Sample 42	8153	First Draw	Bubbler	Room 206	<1	08/06/2018	
Sample 43	8154	First Draw	Tap	Room 206	<1	08/06/2018	
Sample 44	8155	First Draw	Bubbler	Room 207	<1	08/06/2018	
Sample 45	8156	First Draw	Tap	Room 207	1	8/6/2018	
Sample 46	8157	First Draw	Bubbler	Room 204	<1	8/6/2018	
Sample 47	8158	First Draw	Tap	Room 204	<1	08/07/2018	
Sample 48	8159	First Draw	Bubbler	Room 203	1	08/07/2018	
Sample 49	8160	First Draw	Tap	Room 203	<1	08/07/2018	
Sample 50	8161	First Draw	Bubbler	Room 202	<1	08/07/2018	
Sample 51	8162	First Draw	Tap	Room 202	<1	08/07/2018	
Sample 52	8163	First Draw	Bubbler	Room 201	<1	08/07/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 53	8164	First Draw	Tap	Room 201	2	08/07/2018	
Sample 54	8165	First Draw	Tap	Room 604	1	08/07/2018	M1
Sample 55	8166	First Draw	Tap	Room 603	1	08/07/2018	M1
Sample 56	8167	First Draw	Tap	Room 602	<1	08/07/2018	M1
Sample 57	8168	First Draw	Tap	Room 601	<1	08/07/2018	M1
Sample 58	8169	First Draw	Bubbler	M1	<1	08/07/2018	Left Bubbler
Sample 59	8170	First Draw	Bubbler	M1	<1	08/07/2018	Right Bubbler
Sample 60	8171	First Draw	Tap	M2	2	08/07/2018	
Sample 61	8172	First Draw	Tap	Room 101	<1	08/07/2018	
Sample 62	8173	First Draw	Bubbler	Room 101	<1	08/07/2018	
Sample 63	8174	First Draw	Tap	Room 102	<1	08/07/2018	
Sample 64	8175	First Draw	Bubbler	Room 102	<1	08/07/2018	
Sample 65	8176	First Draw	Bubbler	Room 103	<1	08/07/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 66	8177	First Draw	Tap	Room 103	<1	08/07/2018	
Sample 67	8178	First Draw	Bubbler	Room 104	<1	08/07/2018	
Sample 68	8179	First Draw	Tap	Room 104	<1	08/07/2018	
Sample 69	8180	First Draw	Bubbler	Room 105	<1	08/07/2018	
Sample 70	8181	First Draw	Tap	Room 105	<1	08/07/2018	
Sample 71	8182	First Draw	Bubbler	Room 106	<1	08/07/2018	
Sample 72	8183	First Draw	Tap	Room 106	<1	08/07/2018	
Sample 73	8184	First Draw	Bubbler	Room 108	<1	08/07/2018	
Sample 74	8185	First Draw	Tap	Room 108	<1	08/07/2018	
Sample 75	8186	First Draw	Bubbler	Room 109	<1	08/07/2018	
Sample 76	8187	First Draw	Tap	Room 109	<1	08/07/2018	
Sample 77	8188	First Draw	Bubbler	Room 112	<1	08/07/2018	
Sample 78	8189	First Draw	Tap	Room 112	<1	08/07/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
Sample 79	8190	First Draw	Bubbler	Room 110	<1	08/07/2018	
Sample 80	8191	First Draw	Tap	Room 110	<1	08/07/2018	
Sample 81	8192	First Draw	Bubbler	Room 111	<1	08/07/2018	
Sample 82	8193	First Draw	Tap	Room 111	<1	08/07/2018	